

Guidant Renewal3 radiated

S/N	FREQ (MHz)	LEVEL (dBm)	AFCL (dB)	POL	dBuV/m	F/S	MARGIN (dB)	Medium	Verdict
966119	914.00	-85.0	36.7	V	58.7	860.994	-35.3	liquid	PASS
	1828.00	-135.0	33.5	V	5.5	1.884	-48.5	liquid	PASS
	2742.00	-135.0	36.2	V	8.2	2.570	-45.8	liquid	PASS
	3656.00	-135.0	38.5	V	10.5	3.350	-43.5	liquid	PASS
	4570.00	-135.0	41.5	V	13.5	4.732	-40.5	liquid	PASS
	914.00	-72.0	36.7	V	71.7	3845.918	-22.3	Air	PASS
	1828.00	-100.0	33.5	V	40.5	105.925	-13.5	Air	PASS
966109	914.00	-84.0	32.6	V	55.6	602.560	-38.4	liquid	PASS
	1828.00	-135.0	33.5	V	5.5	1.884	-48.5	liquid	PASS
	2742.00	-126.1	36.2	V	17.1	7.161	-36.9	liquid	PASS
	3656.00	-135.0	38.5	V	10.5	3.350	-43.5	liquid	PASS
	4570.00	-135.0	41.5	V	13.5	4.732	-40.5	liquid	PASS
	914.00	-73.7	32.6	V	65.9	1972.423	-28.1	Air	PASS
	1828.00	-102.0	33.5	V	38.5	84.140	-15.5	Air	PASS
966108	914.00	-85.0	32.6	V	54.6	537.032	-39.4	liquid	PASS
	1828.00	-135.0	33.5	V	5.5	1.884	-48.5	liquid	PASS
	2742.00	-135.0	36.2	V	8.2	2.570	-45.8	liquid	PASS
	3656.00	-135.0	38.5	V	10.5	3.350	-43.5	liquid	PASS
	4570.00	-135.0	41.5	V	13.5	4.732	-40.5	liquid	PASS
	914.00	-74.0	32.6	V	65.6	1905.461	-28.4	Air	PASS
	1828.00	-101.9	33.5	V	38.6	85.114	-15.4	Air	PASS

Model: Renewal 3 RF
H210
Lab: PCTEST
Date: 5.26.04

In- and out-of-liquid Radiated Test Photos







