




**Medtronic Inc.**  
**9538/9539 Patient Assistant**  
**FCC 15:209:2012**

**Report #: MDTR0304.1 Rev. 1**



Report Prepared By Northwest EMC Inc.

NORTHWEST EMC – (888) 364-2378 – [www.nwemc.com](http://www.nwemc.com)

California – Minnesota – Oregon – New York – Washington

# CERTIFICATE OF TEST

**Last Date of Test: January 13, 2014**  
**Medtronic, Inc.**  
**Model: 9538/9539 Patient Assistant**

## Emissions

Test Description	Specification	Test Method	Pass/Fail
Field Strength of Fundamental	FCC 15.209:2014	ANSI C63.10:2009	Pass
Spurious Radiated Emissions	FCC 15.209:2014	ANSI C63.10:2009	Pass

## Deviations From Test Standards

None

**Approved By:**



Tim O'Shea, Operations Manager



**NVLAP Lab Code: 200881-0**

*This report must not be used to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the federal government of the United States of America.*

*Product compliance is the responsibility of the client, therefore the tests and equipment modes of operation represented in this report were agreed upon by the client, prior to testing. This Report may only be duplicated in its entirety. The results of this test pertain only to the sample(s) tested. The specific description is noted in each of the individual sections of the test report supporting this certificate of test.*

# REVISION HISTORY

Revision Number	Description	Date	Page Number
00	None		
01	Corrected Model Number	2/11/2014	Cover, 2, 7, 8, 11, 12, 14-17

## Barometric Pressure

The recorded barometric pressure has been normalized to sea level.

---

## United States

**FCC** - Designated by the FCC as a Telecommunications Certification Body (TCB). Certification chambers, Open Area Test Sites, and conducted measurement facilities are listed with the FCC.

**A2LA** - Accredited by A2LA to ISO / IEC Guide 65 as a product certifier. This allows Northwest EMC to certify transmitters to FCC and IC specifications.

**NVLAP** - Each laboratory is accredited by NVLAP to ISO 17025

---

## Canada

**IC** - Recognized by Industry Canada as a Certification Body (CB). Certification chambers and Open Area Test Sites are filed with IC.

---

## European Union

**European Commission** – Validated by the European Commission as a Conformity Assessment Body (CAB) under the EMC directive and as a Notified Body under the R&TTE Directive.

---

## Australia/New Zealand

**ACMA** - Recognized by ACMA as a CAB for the acceptance of test data.

---

## Korea

**KCC / RRA** - Recognized by KCC's RRA as a CAB for the acceptance of test data.

---

## Japan

**VCCI** - Associate Member of the VCCI. Conducted and radiated measurement facilities are registered.

---

## Taiwan

**BSMI** – Recognized by BSMI as a CAB for the acceptance of test data.

**NCC** - Recognized by NCC as a CAB for the acceptance of test data.

---

## Singapore

**IDA** – Recognized by IDA as a CAB for the acceptance of test data.

---

## Hong Kong

**OFTA** – Recognized by OFTA as a CAB for the acceptance of test data.

---

## Vietnam

**MIC** – Recognized by MIC as a CAB for the acceptance of test data.

---

## Russia

**GOST** – Accredited by Certinform VNIINMASH, CERTINFO, SAMTES, and Federal CHEC to perform EMC and Hygienic testing for Information Technology products to GOST standards.

---

## SCOPE

For details on the Scopes of our Accreditations, please visit:

<http://www.nwemc.com/accreditations/>

## Measurement Uncertainty

When a measurement is made, the result will be different from the true or theoretically correct value. The difference is the result of tolerances in the measurement system that cannot be completely eliminated. To the extent that technology allows us, it has been our aim to minimize this error. Measurement uncertainty is a statistical expression of measurement error qualified by a probability distribution.


A measurement uncertainty estimation has been performed for each test per our internal quality document WP 342. The estimation is used to compare the measured result with its "true" or theoretically correct value. The expanded measurement uncertainty (K=2) for each test is listed below. Our measurement data meets or exceeds the measurement uncertainty requirements of the applicable specification; therefore, the test data can be compared directly to the specification limit to determine compliance. The calculations for estimating measurement uncertainty are based upon ETSI TR 100 028 (or CISPR 16-4-1 as applicable), and are available upon request.

The following table represents the Measurement Uncertainty (MU) budgets for each of the tests that may be contained in this report.

<b>Test</b>	<b>+ MU</b>	<b>- MU</b>
Frequency Accuracy (Hz)	0.12	-0.01
Amplitude Accuracy (dB)	0.49	-0.49
Conducted Power (dB)	0.41	-0.41
Radiated Power via Substitution (dB)	0.69	-0.68
Temperature (degrees C)	0.81	-0.81
Humidity (% RH)	2.89	-2.89
Field Strength (dB)	3.80	-3.80
AC Powerline Conducted Emissions (dB)	2.94	-2.94



<b>Oregon</b> Labs EV01-12 22975 NW Evergreen Pkwy Hillsboro, OR 97124 (503) 844-4066	<b>California</b> Labs OC01-13 41 Tesla Irvine, CA 92618 (949) 861-8918	<b>New York</b> Labs NY01-04 4939 Jordan Rd. Elbridge, NY 13060 (315) 685-0796	<b>Minnesota</b> Labs MN01-08 9349 W Broadway Ave. Brooklyn Park, MN 55445 (763) 425-2281	<b>Washington</b> Labs NC01-05, SU02, SU07 19201 120 <sup>th</sup> Ave. NE Bothell, WA 98011 (425) 984-6600
<b>VCCI</b>				
A-0108	A-0029		A-0109	A-0110
<b>Industry Canada</b>				
2834D-1, 2834D-2	2834B-1, 2834B-2, 2834B-3		2834E-1	2834C-1
<b>NVLAP</b>				
NVLAP Lab Code: 200630-0	NVLAP Lab Code: 200676-0	NVLAP Lab Code: 200761-0	NVLAP Lab Code: 200881-0	NVLAP Lab Code: 200629-0







# PRODUCT DESCRIPTION

## Client and Equipment Under Test (EUT) Information

<b>Company Name:</b>	Medtronic, Inc.
<b>Address:</b>	8200 Coral Sea St. NE
<b>City, State, Zip:</b>	Mounds View, MN 55112
<b>Test Requested By:</b>	Girad Guillaume
<b>Model:</b>	9538/9539 Patient Assistant
<b>First Date of Test:</b>	January 13, 2014
<b>Last Date of Test:</b>	January 13, 2014
<b>Receipt Date of Samples:</b>	January 13, 2014
<b>Equipment Design Stage:</b>	Prototype
<b>Equipment Condition:</b>	No Damage

## Information Provided by the Party Requesting the Test

<b>Functional Description of the EUT (Equipment Under Test):</b>
Hand-held, battery-operated telemetry device that enables the patient to record cardiac information via ultra low power (ULP) wireless radio telemetry.
<b>Testing Objective:</b>
To demonstrate compliance of the inductive portion of the device to FCC Part 15.209 specifications.



# CONFIGURATIONS

## Configuration MDTR0304- 1

EUT			
Description	Manufacturer	Model/Part Number	Serial Number
Patient Assistant	Medtronic, Inc.	9538/9539	LJP125207P



## Equipment Modifications

Item	Date	Test	Modification	Note	Disposition of EUT
1	1/13/2014	Spurious Radiated Emissions	Tested as delivered to Test Station.	No EMI suppression devices were added or modified during this test.	EUT remained at Northwest EMC following the test.
2	1/13/2014	Field Strength of Fundamental	Tested as delivered to Test Station.	No EMI suppression devices were added or modified during this test.	Scheduled testing was completed.

Testing was performed using the mode(s) of operation and configuration(s) noted within the report. The individuals and/or the organization requesting the test provided the modes, configurations and settings used to complete the evaluation. The actual test parameters are specified in the test data, this includes items such as investigated frequency range (scanned) and test levels. The testing methods and performance specifications, as well as the test site used for the evaluation are indicated in the test data. The test data represents the configuration / operating mode/ model that produced the highest emission levels as compared to the specification limit.

## MODES OF OPERATION

Continuous transmit, modulated at 175 kHz

## POWER SETTINGS INVESTIGATED

Battery

## CONFIGURATIONS INVESTIGATED

MDTR0304 - 1

## FREQUENCY RANGE INVESTIGATED

Start Frequency	9 kHz	Stop Frequency	490 kHz
-----------------	-------	----------------	---------

## SAMPLE CALCULATIONS

Radiated Emissions: Field Strength = Measured Level + Antenna Factor + Cable Factor - Amplifier Gain + Distance Adjustment Factor + External Attenuation

## TEST EQUIPMENT

Description	Manufacturer	Model	ID	Last Cal.	Interval
MN05 Cables	ESM Cable Corp.	Bilog Cables	MNH	5/20/2013	12 mo
Antenna, Loop	ETS Lindgren	6502	AOB	2/20/2013	24 mo
Spectrum Analyzer	Agilent	N9010A	AFI	1/27/2013	24 mo

## MEASUREMENT BANDWIDTHS

Frequency Range (MHz)	Peak Data (kHz)	Quasi-Peak Data (kHz)	Average Data (kHz)
0.01 - 0.15	1.0	0.2	0.2
0.15 - 30.0	10.0	9.0	9.0
30.0 - 1000	100.0	120.0	120.0
Above 1000	1000.0	N/A	1000.0

## TEST DESCRIPTION

The antennas to be used with the EUT were tested. The EUT was continuously transmitting while set to the channel specified. While scanning, emissions from the EUT were maximized by rotating the EUT, adjusting the measurement antenna height and orientation in 3 orthogonal planes, the EUT and/or associated antenna is positioned in 3 orthogonal planes (per ANSI C63.10). An active loop antenna was used for this test in order to provide sufficient measurement sensitivity.


As outlined in 15.209(e) and 15.31(f)(2), measurements may be performed at a distance closer than what is specified with the limit. The limit at the specified distance is shown on the data sheet. Measurements are made at a closer distance and the data is adjusted using a distance correction factor of 40dB/decade for comparison to the limit.

If there are no detectable emissions above the noise floor, the data included will show noise floor measurements for reference only.

Work Order:	MDTR0304	Date:	01/13/14	
Project:	None	Temperature:	24.5 °C	
Job Site:	MN05	Humidity:	17.3% RH	
Serial Number:	LJP125207P	Barometric Pres.:	1003.2 mbar	Tested by: Trevor Buls
EUT:	9538/9539 Patient Assistant			
Configuration:	1			
Customer:	Medtronic, Inc.			
Attendees:	Girard Guillaume			
EUT Power:	Battery			
Operating Mode:	Continuous transmit, modulated at 175 kHz			
Deviations:	None			
Comments:	Device operates between 150-200 kHz, FSK modulated at 175 kHz			

Test Specifications	Test Method
FCC 15.209:2014	ANSI C63.10:2009

Run #	5	Test Distance (m)	3	Antenna Height(s)	1 (m)	Results	Evaluation
-------	---	-------------------	---	-------------------	-------	---------	------------




Freq (MHz)	Amplitude (dBuV)	Preamp (dB)	Antenna Height (meters)	Transducer (dB)	Cable (dB)	External Attenuation (dB)	Polarity/ Transducer Type	Detector	Distance Adjustment (dB)	Adjusted (dBuV/m)	Spec. Limit (dBuV/m)	Compared to Spec. (dB)
------------	------------------	-------------	-------------------------	-----------------	------------	---------------------------	---------------------------	----------	--------------------------	-------------------	----------------------	------------------------

<b>Work Order:</b>	MDTR0304	<b>Date:</b>	01/13/14	<i>Trevor Buls</i>
<b>Project:</b>	None	<b>Temperature:</b>	24.5 °C	
<b>Job Site:</b>	MN05	<b>Humidity:</b>	17.3% RH	
<b>Serial Number:</b>	LJP125207P	<b>Barometric Pres.:</b>	1003.2 mbar	
<b>EUT:</b>	9538/9539 Patient Assistant			
<b>Configuration:</b>	1			
<b>Customer:</b>	Medtronic, Inc.			
<b>Attendees:</b>	Girard Guillaume			
<b>EUT Power:</b>	Battery			
<b>Operating Mode:</b>	Continuous transmit, modulated at 175 kHz			
<b>Deviations:</b>	None			
<b>Comments:</b>	Span set wide enough to encompass the entire emissions envelope. Device operates between 150-200 kHz, FSK modulated at 175 kHz			

Test Specifications	Test Method
FCC 15.209:2014	ANSI C63.10:2009

Run #	5	Test Distance (m)	3	Antenna Height(s)	1m	Results	Pass
-------	---	-------------------	---	-------------------	----	---------	------



Freq (MHz)	Amplitude (dBuV)	Factor (dB)	Antenna Height (meters)	Azimuth (degrees)	Test Distance (meters)	External Attenuation (dB)	Polarity/ Transducer Type	Detector	Distance Adjustment (dB)	Adjusted (dBuV/m)	Spec. Limit (dBuV/m)	Compared to Spec. (dB)	Comments
0.199	52.4	11.4	1.0	159.0	3.0	0.0	Par to EUT	AV	-80.0	-16.2	21.6	-37.8	EUT Vertical
0.199	52.4	11.4	1.0	164.0	3.0	0.0	Par to EUT	AV	-80.0	-16.2	21.6	-37.8	EUT on Side
0.199	49.5	11.4	1.0	248.0	3.0	0.0	Perp to GND	AV	-80.0	-19.1	21.6	-40.7	EUT on Side
0.199	48.6	11.4	1.0	242.0	3.0	0.0	Perp to GND	AV	-80.0	-20.0	21.6	-41.6	EUT Vertical
0.198	46.2	11.4	1.0	338.0	3.0	0.0	Par to GND	AV	-80.0	-22.4	21.7	-44.1	EUT Vertical
0.151	44.8	11.4	1.0	186.0	3.0	0.0	Par to GND	AV	-80.0	-23.8	24.0	-47.8	EUT on Side
0.151	44.8	11.4	1.0	161.0	3.0	0.0	Par to GND	AV	-80.0	-23.8	24.1	-47.8	EUT Horizontal
0.151	41.7	11.4	1.0	31.0	3.0	0.0	Par to EUT	AV	-80.0	-26.9	24.1	-50.9	EUT Horizontal
0.151	40.7	11.4	1.0	338.0	3.0	0.0	Perp to GND	AV	-80.0	-27.9	24.0	-51.9	EUT Horizontal
0.199	54.9	11.4	1.0	159.0	3.0	0.0	Par to EUT	PK	-80.0	-13.7	41.6	-55.3	EUT Vertical
0.199	54.6	11.4	1.0	164.0	3.0	0.0	Par to EUT	PK	-80.0	-14.0	41.6	-55.6	EUT on Side
0.200	52.7	11.4	1.0	242.0	3.0	0.0	Perp to GND	PK	-80.0	-15.9	41.6	-57.5	EUT Vertical
0.200	52.5	11.4	1.0	248.0	3.0	0.0	Perp to GND	PK	-80.0	-16.1	41.6	-57.7	EUT on Side
0.199	50.0	11.4	1.0	161.0	3.0	0.0	Par to GND	PK	-80.0	-18.6	41.6	-60.2	EUT Horizontal
0.150	50.4	11.5	1.0	338.0	3.0	0.0	Par to GND	PK	-80.0	-18.2	44.1	-62.3	EUT Vertical
0.150	49.8	11.5	1.0	186.0	3.0	0.0	Par to GND	PK	-80.0	-18.8	44.1	-62.9	EUT on Side
0.153	47.3	11.4	1.0	31.0	3.0	0.0	Par to EUT	PK	-80.0	-21.3	44.0	-65.2	EUT Horizontal
0.150	46.4	11.4	1.0	338.0	3.0	0.0	Perp to GND	PK	-80.0	-22.2	44.1	-66.2	EUT Horizontal

Testing was performed using the mode(s) of operation and configuration(s) noted within the report. The individuals and/or the organization requesting the test provided the modes, configurations and settings used to complete the evaluation. The actual test parameters are specified in the test data, this includes items such as investigated frequency range (scanned) and test levels. The testing methods and performance specifications, as well as the test site used for the evaluation are indicated in the test data. The test data represents the configuration / operating mode/ model that produced the highest emission levels as compared to the specification limit.

## MODES OF OPERATION

Continuous transmit, modulated at 175 kHz

## POWER SETTINGS INVESTIGATED

Battery

## CONFIGURATIONS INVESTIGATED

MDTR0304 - 1

## FREQUENCY RANGE INVESTIGATED

Start Frequency	9 kHz	Stop Frequency	1000 MHz
-----------------	-------	----------------	----------

## SAMPLE CALCULATIONS

Radiated Emissions: Field Strength = Measured Level + Antenna Factor + Cable Factor - Amplifier Gain + Distance Adjustment Factor + External Attenuation

## TEST EQUIPMENT

Description	Manufacturer	Model	ID	Last Cal.	Interval
Pre-Amplifier	Miteq	AM-1616-1000	PAD	5/20/2013	12 mo
Antenna, Bilog	Teseq	CBL 6141B	AYD	12/17/2013	12 mo
MN05 Cables	ESM Cable Corp.	Bilog Cables	MNH	5/20/2013	12 mo
Antenna, Loop	ETS Lindgren	6502	AOB	2/20/2013	24 mo
Spectrum Analyzer	Agilent	N9010A	AFI	1/27/2013	24 mo

## MEASUREMENT BANDWIDTHS

Frequency Range (MHz)	Peak Data (kHz)	Quasi-Peak Data (kHz)	Average Data (kHz)
0.01 - 0.15	1.0	0.2	0.2
0.15 - 30.0	10.0	9.0	9.0
30.0 - 1000	100.0	120.0	120.0
Above 1000	1000.0	N/A	1000.0

## TEST DESCRIPTION

The antennas to be used with the EUT were tested. The EUT was continuously transmitting while set to the channel specified. While scanning, emissions from the EUT were maximized by rotating the EUT, adjusting the measurement antenna height and orientation in 3 orthogonal planes, the EUT and/or associated antenna is positioned in 3 orthogonal planes (per ANSI C63.10). An active loop antenna was used for this test in order to provide sufficient measurement sensitivity.

For measurements below 30 MHz, as outlined in 15.209(e) and 15.31(f)(2), measurements may be performed at a distance closer than what is specified with the limit. The limit at the specified distance is shown on the data sheet. Measurements are made at a closer distance and the data is adjusted using a distance correction factor of 40dB/decade for comparison to the limit.


If there are no detectable emissions above the noise floor, the data included will show noise floor measurements for reference only.

## SPURIOUS RADIATED EMISSIONS

Work Order:	MDTR0304	Date:	01/13/14	
Project:	None	Temperature:	24.5 °C	
Job Site:	MN05	Humidity:	17.3% RH	
Serial Number:	LJP125207P	Barometric Pres.:	1003.2 mbar	Tested by: Trevor Buls
EUT:	9538/9539 Patient Assistant			
Configuration:	1			
Customer:	Medtronic, Inc.			
Attendees:	Girard Guillaume			
EUT Power:	Battery			
Operating Mode:	Continuous transmit, modulated at 175 kHz			
Deviations:	None			
Comments:	Span set wide enough to encompass the entire emissions envelope. EUT Vertical. Device operates between 150-200 kHz, FSK modulated at 175 kHz.			

Test Specifications	Test Method
FCC 15.209:2014	ANSI C63.10:2009

Run #	6	Test Distance (m)	3	Antenna Height(s)	1 (m)	Results	Evaluation
-------	---	-------------------	---	-------------------	-------	---------	------------




Freq (MHz)	Amplitude (dBuV)	Preamp (dB)	Antenna Height (meters)	Transducer (dB)	Cable (dB)	External Attenuation (dB)	Polarity/ Transducer Type	Detector	Distance Adjustment (dB)	Adjusted (dBuV/m)	Spec. Limit (dBuV/m)	Compared to Spec. (dB)
------------	------------------	-------------	-------------------------	-----------------	------------	---------------------------	---------------------------	----------	--------------------------	-------------------	----------------------	------------------------

## SPURIOUS RADIATED EMISSIONS

Work Order:	MDTR0304	Date:	01/13/14	<i>Trevor Buls</i>
Project:	None	Temperature:	24.5 °C	
Job Site:	MN05	Humidity:	17.3% RH	
Serial Number:	LJP125207P	Barometric Pres.:	1003.2 mbar	
EUT:		9538/9539 Patient Assistant		
Configuration:	1			
Customer:	Medtronic, Inc.			
Attendees:	Girad Guillaume			
EUT Power:	Battery			
Operating Mode:	Continuous transmit, modulated at 175 kHz			
Deviations:	None			
Comments:	Span set wide enough to encompass the entire emissions envelope. EUT Vertical. Device operates between 150-200 kHz, FSK modulated at 175 kHz.			

Test Specifications	Test Method
FCC 15.209:2014	ANSI C63.10:2009

Run #	6	Test Distance (m)	3	Antenna Height(s)	1m	Results	Pass
-------	---	-------------------	---	-------------------	----	---------	------



Freq (MHz)	Amplitude (dBuV)	Factor (dB)	Antenna Height (meters)	Azimuth (degrees)	Test Distance (meters)	External Attenuation (dB)	Polarity/ Transducer Type	Detector	Distance Adjustment (dB)	Adjusted (dBuV/m)	Spec. Limit (dBuV/m)	Compared to Spec. (dB)
0.323	37.3	11.4	1.0	114.0	3.0	0.0	Par to EUT	AV	-80.0	-31.3	17.4	-48.7
0.325	43.4	11.4	1.0	114.0	3.0	0.0	Par to EUT	PK	-80.0	-25.2	37.4	-62.6




## SPURIOUS RADIATED EMISSIONS

Work Order:	MDTR0304	Date:	01/13/14	
Project:	None	Temperature:	24.5 °C	
Job Site:	MN05	Humidity:	17.3% RH	
Serial Number:	LJP125207P	Barometric Pres.:	1003.2 mbar	Tested by: Trevor Buls
EUT:	9538/9539 Patient Assistant			
Configuration:	1			
Customer:	Medtronic, Inc.			
Attendees:	Girard Guillaume			
EUT Power:	Battery			
Operating Mode:	Continuous transmit, modulated at 175 kHz			
Deviations:	None			
Comments:	Span set wide enough to encompass the entire emissions envelope. EUT Vertical. Device operates between 150-200 kHz, FSK modulated at 175 kHz.			

Test Specifications	Test Method
FCC 15.209:2014	ANSI C63.10:2009

Run #	7	Test Distance (m)	3	Antenna Height(s)	1 (m)	Results	Evaluation
-------	---	-------------------	---	-------------------	-------	---------	------------




Freq (MHz)	Amplitude (dBuV)	Preamp (dB)	Antenna Height (meters)	Transducer (dB)	Cable (dB)	External Attenuation (dB)	Polarity/Transducer Type	Detector	Distance Adjustment (dB)	Adjusted (dBuV/m)	Spec. Limit (dBuV/m)	Compared to Spec. (dB)
------------	------------------	-------------	-------------------------	-----------------	------------	---------------------------	--------------------------	----------	--------------------------	-------------------	----------------------	------------------------

## SPURIOUS RADIATED EMISSIONS

Work Order:	MDTR0304	Date:	01/13/14	<i>Trevor Buls</i>
Project:	None	Temperature:	24.5 °C	
Job Site:	MN05	Humidity:	17.3% RH	
Serial Number:	LJP125207P	Barometric Pres.:	1003.2 mbar	
EUT:		9538/9539 Patient Assistant		
Configuration:	1			
Customer:	Medtronic, Inc.			
Attendees:	Girad Guillaume			
EUT Power:	Battery			
Operating Mode:	Continuous transmit, modulated at 175 kHz			
Deviations:	None			
Comments:	Span set wide enough to encompass the entire emissions envelope. EUT Vertical. Device operates between 150-200 kHz, FSK modulated at 175 kHz.			

Test Specifications	Test Method
FCC 15.209:2014	ANSI C63.10:2009

Run #	7	Test Distance (m)	3	Antenna Height(s)	1m	Results	Pass
-------	---	-------------------	---	-------------------	----	---------	------



Freq (MHz)	Amplitude (dBuV)	Factor (dB)	Antenna Height (meters)	Azimuth (degrees)	Test Distance (meters)	External Attenuation (dB)	Polarity/ Transducer Type	Detector	Distance Adjustment (dB)	Adjusted (dBuV/m)	Spec. Limit (dBuV/m)	Compared to Spec. (dB)
0.830	29.4	11.6	1.0	78.0	3.0	0.0	Par to EUT	QP	-40.0	1.0	29.2	-28.2
1.001	24.5	11.9	1.0	346.0	3.0	0.0	Par to EUT	QP	-40.0	-3.6	27.6	-31.2
0.506	30.5	11.6	1.0	115.0	3.0	0.0	Par to EUT	QP	-40.0	2.1	33.5	-31.4
0.651	28.1	11.5	1.0	349.0	3.0	0.0	Par to EUT	QP	-40.0	-0.4	31.3	-31.7
1.401	20.8	11.7	1.0	311.0	3.0	0.0	Par to EUT	QP	-40.0	-7.5	24.7	-32.2
1.183	22.0	11.8	1.0	321.0	3.0	0.0	Par to EUT	QP	-40.0	-6.2	26.2	-32.3
1.532	19.5	11.7	1.0	0.0	3.0	0.0	Par to EUT	QP	-40.0	-8.8	23.9	-32.7
1.717	18.3	11.6	1.0	216.0	3.0	0.0	Par to EUT	QP	-40.0	-10.1	29.5	-39.6