







Figure 109: 16QAM 5MHz B.W.; 1962.5MHz, 30kHz




Figure 110: 16QAM 5MHz B.W.; 1992.5MHz, 15kHz




Figure 111: 16QAM 5MHz B.W.; 1992.5MHz, 30kHz



Figure 112: 16QAM 10MHz B.W.; 1935.0MHz, 15kHz



Figure 113: 16QAM 10MHz B.W.; 1935.0MHz, 30kHz




Figure 114: 16QAM 10MHz B.W.; 1935.0MHz, 60kHz




Figure 115: 16QAM 10MHz B.W.; 1962.5MHz, 15kHz



Figure 116: 16QAM 10MHz B.W.; 1962.5MHz, 30kHz




Figure 117: 16QAM 10MHz B.W.; 1962.5MHz, 60kHz



Figure 118: 16QAM 10MHz B.W.; 1990.0MHz, 15kHz



Figure 119: 16QAM 10MHz B.W.; 1990.0MHz, 30kHz






Figure 120: 16QAM 10MHz B.W.; 1990.0MHz, 60kHz










Figure 139: 64QAM 5MHz B.W.; 1932.5MHz, 15kHz



Figure 140: 64QAM 5MHz B.W.; 1932.5MHz, 30kHz



Figure 141: 64QAM 5MHz B.W.; 1962.5MHz, 15kHz




Figure 142: 64QAM 5MHz B.W.; 1962.5MHz, 30kHz



Figure 143: 64QAM 5MHz B.W.; 1992.5MHz, 15kHz












Figure 144: 64QAM 5MHz B.W.; 1992.5MHz, 30kHz












Figure 169: 64QAM 20MHz B.W.; 1985.0MHz, 15kHz



Figure 170: 64QAM 20MHz B.W.; 1985.0MHz, 30kHz




Figure 171: 64QAM 20MHz B.W.; 1985.0MHz, 60kHz




Figure 172: 256QAM 5MHz B.W.; 1932.5MHz, 15kHz




Figure 173: 256QAM 5MHz B.W.; 1932.5MHz, 30kHz











Figure 174: 256QAM 5MHz B.W.; 1962.5MHz, 15Hz













4.5 Test Equipment Used; RF Power Output

Instrument	Manufacturer	Model	Serial Number	Calibration	
				Last Calibration Date	Next Calibration Due
EXA signal Analyzer	Agilent Technologies	N9010A	MY52220686	28 November 2018	28 November 2020
Sarokal Signal Generator	Mentor® (A Siemens Business)	X-Step-V	1904008	*	*
30 dB Attenuator	MCL	BW-S30W5	533	24 December 2019	24 December 2020

Table 7 Test Equipment Used

* New test equipment, purchased during January 2020.