

RF Exposure Evaluation declaration

Product Name : Automatic Upper Arm Blood Pressure Monitor

Model No. : HL858CB

FCC ID : 2ABTAHNL85CBA

Applicant : HEALTH & LIFE CO., LTD.

Address : 9F No.186, Jian Yi Road, Zhonghe District, New Taipei City, Taiwan

Date of Receipt : Aug. 06, 2015

Date of Declaration : Aug. 21, 2015

Report No. : 1580266R-RFUSP01V00

The test results relate only to the samples tested.

The test results shown in the test report are traceable to the national/international standard through the calibration report of the equipment and evaluated measurement uncertainty herein.

This report must not be used to claim product endorsement by TAF or any agency of the government.

The test report shall not be reproduced without the written approval of Quietek Corporation.

1. RF Exposure Evaluation

1.1. Limits

According to FCC 1.1310: The criteria listed in the following table shall be used to evaluate the environment impact of human exposure to radio frequency (RF) radiation as specified in 1.1307(b)

LIMITS FOR MAXIMUM PERMISSIBLE EXPOSURE (MPE)

Frequency Range (MHz)	Electric Field Strength (V/m)	Magnetic Field Strength (A/m)	Power Density (mW/cm ²)	Average Time (Minutes)
(A) Limits for Occupational/ Control Exposures				
300-1500	--	--	F/300	6
1500-100,000	--	--	5	6
(B) Limits for General Population/ Uncontrolled Exposures				
300-1500	--	--	F/1500	6
1500-100,000	--	--	1	30

F= Frequency in MHz

Friis Formula

Friis transmission formula: $P_d = (P_{out} * G) / (4 * \pi * r^2)$

Where

P_d = power density in mW/cm²

P_{out} = output power to antenna in mW

G = gain of antenna in linear scale

π = 3.1416

R = distance between observation point and center of the radiator in cm

P_d is the limit of MPE, 1 mW/cm². If we know the maximum gain of the antenna and the total power input to the antenna, through the calculation, we will know the distance r where the MPE limit is reached.

1.2. Test Procedure

Software provided by client enabled the EUT to transmit and receive data at lowest, middle and highest channel individually.

The temperature and related humidity: 18°C and 78% RH.

1.3. Test Result of RF Exposure Evaluation

Product : Automatic Upper Arm Blood Pressure Monitor
Test Item : RF Exposure Evaluation
Test Site : No.3 OATS

Operation Frequency	2402 – 2480MHz
Maximum Conducted output power	5.01dBm
Antenna gain	-2.39556dBi

Output Power Into Antenna & RF Exposure Evaluation Distance:

Output Power to Antenna (mW)	Power Density at R = 20 cm (mW/cm ²)
3.169567463	0.0004

Power density is lower than the limit (1 mW/cm²).