

## **APPENDIX**

### **Exhibit 1**

#### **System Validation Plots**

Test Laboratory: JAPAN QUALITY ASSURANCE ORGANIZATION

File Name: [Validation\\_HSL1800\\_040227.da4](#)

## System Validation

**DUT: Dipole 1800 MHz; Type: D1800V2; Serial: 2d038**

**Program: Validation**

Communication System: CW; Frequency: 1800 MHz; Duty Cycle: 1:1

Medium: HSL1800 ( $\sigma = 1.454 \text{ mho/m}$ ,  $\epsilon_r = 38.39$ ,  $\rho = 1000 \text{ kg/m}^3$ )

Phantom section: Flat Section

Measurement Standard: DASY4 (High Precision Assessment)

DASY4 Configuration:

- Probe: ET3DV6 - SN1678; ConvF(5.15, 5.15, 5.15); Calibrated: 2004/02/15
- Sensor-Surface: 4mm (Mechanical And Optical Surface Detection)
- Electronics: DAE3 Sn508; Calibrated: 2004/02/06
- Phantom: SAM 1194; Type: QD 000 P40 CA; Serial: 1194
- Measurement SW: DASY4, V4.1 Build 47; Postprocessing SW: SEMCAD, V1.6 Build 115

**Antenna Input Power 250 mW/Area Scan (5x5x1):** Measurement grid: dx=20mm, dy=20mm

Reference Value = 91.5 V/m

Power Drift = -0.007 dB

Maximum value of SAR = 10.9 mW/g

**Antenna Input Power 250 mW/Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm


Peak SAR (extrapolated) = 18 W/kg

SAR(1 g) = 10.2 mW/g; SAR(10 g) = 5.26 mW/g

Reference Value = 91.5 V/m

Power Drift = -0.007 dB

Maximum value of SAR = 11.3 mW/g



0 dB = 11.3mW/g

Test Laboratory: JAPAN QUALITY ASSURANCE ORGANIZATION

File Name: [Validation\\_040301.da4](#)

## System Validation

**DUT: Dipole 1800 MHz; Type: D1800V2; Serial: 2d038**

**Program: Validation**

Communication System: CW; Frequency: 1800 MHz; Duty Cycle: 1:1

Medium: M1800 ( $\sigma = 1.555 \text{ mho/m}$ ,  $\epsilon_r = 53.92$ ,  $\rho = 1000 \text{ kg/m}^3$ )

Phantom section: Flat Section

Measurement Standard: DASY4 (High Precision Assessment)

DASY4 Configuration:

- Probe: ET3DV6 - SN1678; ConvF(4.65, 4.65, 4.65); Calibrated: 2004/02/15
- Sensor-Surface: 4mm (Mechanical And Optical Surface Detection)
- Electronics: DAE3 Sn508; Calibrated: 2004/02/06
- Phantom: SAM 1194; Type: QD 000 P40 CA; Serial: 1194
- Measurement SW: DASY4, V4.1 Build 47; Postprocessing SW: SEMCAD, V1.6 Build 115

**Antenna Input Power 250 mW/Area Scan (5x5x1):** Measurement grid: dx=20mm, dy=20mm

Reference Value = 89.2 V/m

Power Drift = -0.09 dB

Maximum value of SAR = 10.8 mW/g

**Antenna Input Power 250 mW/Zoom Scan (5x5x7)/Cube 0:** Measurement grid: dx=8mm, dy=8mm, dz=5mm


Peak SAR (extrapolated) = 16.1 W/kg

SAR(1 g) = 9.66 mW/g; SAR(10 g) = 5.11 mW/g

Reference Value = 89.2 V/m

Power Drift = -0.09 dB

Maximum value of SAR = 10.8 mW/g



0 dB = 10.8mW/g