

FCC TEST REPORT FCC 47 CFR Part 95I Medical Device Radiocommunication Service (MedRadio) Industry Canada RSS-243 Medical Devices Operating in the 401 – 406 MHz Frequency Band	
Report Reference No.	G0M-1612-6098-TFC95IM-V02
Testing Laboratory	Eurofins Product Service GmbH
Address	Storkower Str. 38c 15526 Reichenwalde Germany
Accreditation	 A2LA Accredited Testing Laboratory, Certificate No.: 1983.01 FCC Filed Test Laboratory, Reg.-No.: 96970 IC OATS Filing assigned code: 3470A
Applicant's name	Biotronik SE & Co. KG
Address	Woermannkehe 1 12359 Berlin GERMANY
Test specification:	
Standard	47 CFR Part 95I RSS-243, Issue 3, 2010-02
Test scope	complete Radio compliance test (C2PC)
Equipment under test (EUT):	
Product description	CardioMessenger Smart
Model No.	CardioMessenger Smart 3G
Additional Model(s)	None
Brand Name(s)	BIOTRONIK
Hardware version	Cardiomessenger Smart 3G mit LP, Best. LP1//TelexSmart3G,Rev. Fx
Firmware / Software version	SMARTAPP 1.xx
	FCC-ID: QRICMSMART IC: 4708A-CMSMART
Test result	Passed

Possible test case verdicts:

- neither assessed nor tested : N/N
- required by standard but not appl. to test object : N/A
- required by standard but not tested : N/T
- not required by standard for the test object : N/R
- test object does meet the requirement : P (Pass)
- test object does not meet the requirement : F (Fail)

Testing:

Test Lab Temperature : 20 – 23 °C

Test Lab Humidity : 32 – 38 %

Date of receipt of test item : 2016-12-19

Date (s) of performance of tests : 2016-12-21

Compiled by : Wilfried Treffke

Tested by (+ signature) : Wilfried Treffke

(Responsible for Test)

Approved by (+ signature) : Christian Weber

(Head of Lab)

Date of issue : 2017-03-16

Total number of pages : 100

W. Treffke

C. Weber

General remarks:

The test results presented in this report relate only to the object tested.

The results contained in this report reflect the results for this particular model and serial number. It is the responsibility of the manufacturer to ensure that all production models meet the intent of the requirements detailed within this report.

This report shall not be reproduced, except in full, without the written approval of the Issuing testing laboratory.

Additional comments:

The EUT can operate with different data rates (4.106kbit/s / 16.425kbit/s / 32.849kbit/s / 197.095kbit/s). Evaluation measurements were performed for worst case selection. For testing the EUT is configured to operate with 197.095 kbit/s as worst case situation.

Version History

Version	Issue Date	Remarks	Revised by
01	2017-02-17	Initial Release	
02	2017-03-16	Page 36, Frequency stability results corrected	W. Treffke

REPORT INDEX


1	EQUIPMENT (TEST ITEM) DESCRIPTION	5
1.1	Photos - Equipment external	7
1.2	Photos - Equipment internal	9
1.3	Photos – Test setup	12
1.4	Supporting Equipment Used During Testing	13
1.5	Test Modes:	14
1.6	Test Equipment Used During Testing	15
1.7	Sample emission level calculation	17
2	RESULT SUMMARY	18
3	TEST CONDITIONS AND RESULTS	19
3.1	Test Conditions and Results – Occupied Bandwidth	19
3.2	Test Conditions and Results – Emission Bandwidth	32
3.3	Test Conditions and Results – Frequency stability	36
3.4	Test Conditions and Results – Transmitter output power	38
3.5	Test Conditions and Results – Band-edge and In-band Emissions	40
3.6	Test Conditions and Results – Transmitter unwanted emissions	42
3.7	Test Conditions and Results – Receiver spurious emissions	44
3.8	Test Conditions and Results – AC power line conducted emissions	46
3.9	Test Conditions and Results – System threshold power levels	49
3.10	Test Conditions and Results – Monitoring system bandwidth	50
3.11	Test Conditions and Results – Scan cycle time	52
3.12	Test Conditions and Results – Minimum channel monitoring period	55
3.13	Test Conditions and Results – Channel access	57
3.14	Test Conditions and Results – Discontinuation of MICS or MEDS session	59
ANNEX A	Transmitter output power	63
ANNEX B	Transmitter Band-edge and In-band emissions	71
ANNEX C	Transmitter radiated spurious emissions	79
ANNEX D	Receiver radiated spurious emissions	95


1 Equipment (Test item) Description

Description	CardioMessenger Smart	
Model	CardioMessenger Smart 3G	
Additional Model(s)	None	
Brand Name(s)	BIOTRONIK	
Serial number	64740589	
Hardware version	Cardiomessenger Smart 3G mit LP, Best. LP1//TelexSmart3G,Rev. Fx	
Software / Firmware version	SMARTAPP 1.xx	
PMN	N/A	
HVIN	CardioMessenger Smart 3G	
FVIN	N/A	
HMN	N/A	
FCC-ID	QRICMSMART	
IC	4708A-CMSMART	
Equipment type	End product	
Radio type	Transceiver	
Number of Radios	1 Transceivers are built into the device	
Radio technology	MedRadio (MICS) programmer / control transmitter	
Operating frequency range	402 - 405 MHz	
Assigned frequency band	402 - 405 MHz	
Main test frequencies	F _{LOW}	402.45 MHz
	F _{MID}	403.65 MHz
	F _{HIGH}	404.85 MHz
Modulations	2-FSK	
Emission designator	F1D	
Number of channels	9	
Channel spacing	300 kHz	
Spectrum access	Listen before transmit	
Number of antennas	2	
Antenna 1	Type	integrated
	Model	loop antenna
	Manufacturer	see Manufacturer
	Gain	-1.37 dBi (Determined by measurements)
Manufacturer	Biotronik SE & Co. KG Woermannkehre 1 12359 Berlin GERMANY	

Power supply	V _{NOM}	3.7 VDC
	V _{MIN}	3.1 VDC
	V _{MAX}	4.16 VDC
Temperature	T _{NOM}	20°C
	T _{MIN}	-20 °C
	T _{MAX}	40 °C
AC/DC-Adaptor	Model	N/A
	Vendor	N/A
	Input	N/A
	Output	N/A

1.1 Photos - Equipment external







1.2 Photos - Equipment internal




PCB BOTTOM




PCB BOTTOM WITHOUT SHIELDING





SIM: COMPANION DEVICE IMPLANT SIMULATOR TOP



SIM: COMPANION DEVICE IMPLANT SIMULATOR BOTTOM



1.3 Photos – Test setup



Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

1.4 Supporting Equipment Used During Testing

Product Type*	Device	Manufacturer	Model No.	Comments
SIM	Test board Implant Simulator	Biotronik SE & Co. KG	None	Companion device for monitoring test
*Note: Use the following abbreviations: AE : Auxiliary/Associated Equipment, or SIM : Simulator (Not Subjected to Test) CABL : Connecting cables				

1.5 Test Modes:

Mode #	Description	
Unmodulated	General conditions:	EUT powered by laboratory power supply.
	Radio conditions:	Mode = standalone transmit Spreading = None Modulation = None Duty cycle = 100 % Power level = Maximum
Modulated	General conditions:	EUT powered by laboratory power supply.
	Radio conditions:	Mode = standalone transmit Modulation = FSK Duty cycle = 100 % Power level = Maximum
Monitoring A	General conditions:	EUT powered by laboratory power supply. EUT channels adjusted to monitoring conditions by administrative commands without companion device.
	Radio conditions:	Mode = standalone transmit Modulation = FSK Duty cycle = normal
Monitoring B	General conditions:	EUT powered by laboratory power supply. EUT with communication session to companion device.
	Radio conditions:	Mode = standalone transmit Modulation = FSK Duty cycle = normal
Receive	General conditions:	EUT powered by laboratory power supply.
	Radio conditions:	Mode = standalone receive Modulation = FSK
AC-Powerline	General conditions:	EUT connected to and powered by base unit via USB. Active data connection between EUT and base unit. AC connection to base unit.
	Radio conditions:	Mode = transmit Modulation = FSK Duty cycle = normal Power level = Maximum

1.6 Test Equipment Used During Testing

Measurement Software			
Description	Manufacturer	Name	Version
EMC Test Software	Dare Instruments	Radimation	2015.2.4

Occupied Bandwidth					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum analyzer	R&S	FSU 26	EF01003	2016-03	2017-03

Emission Bandwidth					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum analyzer	R&S	FSU 26	EF01003	2016-03	2017-03

Frequency Stability					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum analyzer	R&S	FSU 26	EF01003	2016-03	2017-03

Effective radiated power					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Anechoic chamber	Frankonia	AC 2	EF00196	-	-
Spectrum Analyzer	R&S	FSEK30	EF00168	2016-12	2017-12
LPD Antenna	R&S	HL 223	EF00212	2016-04	2019-04

Radiated spurious emissions					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Anechoic chamber	Frankonia	AC 2	EF00196	-	-
Spectrum Analyzer	R&S	FSEK30	EF00168	2016-12	2017-12
Biconical Antenna	R&S	HK 116	EF00012	2016-05	2019-05
LPD Antenna	R&S	HL 223	EF00187	2016-05	2019-05
LPD Antenna	R&S	HL 025	EF00327	2015-10	2018-10

AC powerline conducted emissions					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
AMN	R&S	ESH3-Z5	EF00036	2014-12	2016-12
EMI Test Receiver	R&S	ESCS 30	EF00295	2016-11	2017-11

Monitoring system scan cycle time					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum Analyzer	R&S	FSIQ26	EF00242	2016-04	2017-04
Signal Generator	R&S	SMP 02	EF00165	2015-05	2017-05

Minimum channel monitoring period					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum Analyzer	R&S	FSIQ26	EF00242	2016-04	2017-04
Signal Generator	R&S	SMP 02	EF00165	2015-05	2017-05

Channel access					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum Analyzer	R&S	FSIQ26	EF00242	2016-04	2017-04
Signal Generator	R&S	SMP 02	EF00165	2015-05	2017-05

Discontinuation of MICS session					
Description	Manufacturer	Model	Identifier	Cal. Date	Cal. Due
Spectrum Analyzer	R&S	FSIQ26	EF00242	2016-04	2017-04
Signal Generator	R&S	SMP 02	EF00165	2015-05	2017-05

1.7 Sample emission level calculation

The following is a description of terms and a sample calculation, as appears in the radiated emissions data table. The numbers used in the calculation are for example only. There is no direct correlation to the specific data taken for the product described in this document:

Reading:

This is the reading obtained on the spectrum analyzer in dBμV. Any external preamplifiers used are taken into account through internal analyzer settings.

A.F.:

This is the antenna factor for the receiving antenna. It is a conversion factor, which converts electric fields strengths to voltages, which can be measured directly on the spectrum analyzer. It is treated as a loss in dB. Cable losses have been included with the A.F. to simplify the calculations. The antenna factor is used in calculations as follows:

$$\text{Reading on Analyzer (dB}\mu\text{V)} + \text{A.F. (dB)} = \text{Net field strength (dB}\mu\text{V/m)}$$

Net:

This is the net field strength measurement (as shown above).

Limit:

This is the FCC Class B radiated emission limit (in units of dBμV/m). The FCC limits are given in units of μV/m. The following formula is used to convert the units of μV/m to dBμV/m:

$$\text{Limit (dB}\mu\text{V/m)} = 20 * \log (\mu\text{V/m})$$

Margin:

This is the margin of compliance below the FCC limit. The units are given in dB. A negative margin indicates the emission was below the limit. A positive margin indicates that the emission exceeds the limit.

Example only:

$$\begin{array}{rclcl} \text{Reading} & + & \text{AF} & = & \text{Net Reading} & : & \text{Net reading - FCC limit} & = & \text{Margin} \\ 21.5 \text{ dB}\mu\text{V} & + & 26 \text{ dB} & = & 47.5 \text{ dB}\mu\text{V/m} & : & 47.5 \text{ dB}\mu\text{V/m} - 57.0 \text{ dB}\mu\text{V/m} & = & -9.5 \text{ dB} \end{array}$$

2 Result Summary

FCC 47 CFR Part 95E, 95I, 15C, IC RSS-243, IC RSS-Gen				
Product Specific Standard Section	Requirement – Test	Reference Method	Result	Remarks
IC RSS-243 3.2 IC RSS-Gen 6.6	Occupied bandwidth	RSS-Gen 6.6	N/A	Informational only
FCC 95.628(d) FCC § 95.633(e) IC RSS-243 3.6, 5.1	Emission bandwidth	FCC § 95.628(a)(6)(i) FCC § 95.633(e)(3)	PASS	
FCC 95.628(e) IC RSS-243 3.3, 5.3 RSS-Gen 8.11	Frequency stability	EN 301 839-1 8.1	PASS	
FCC § 95.6369(f) IC RSS-243 § 5.4	Transmitter output power	EN 301 839-1 8.3	PASS	
FCC § 95.635(d) IC RSS-243 § 3.4, 5.5	Band edge compliance	FCC § 95.635(d) ANSI C63.4	PASS	
FCC § 95.635(d) IC RSS-243 § 3.4, 5.5 RSS-Gen 6.13	Transmitter unwanted emissions	FCC § 95.635(d) ANSI C63.4	PASS	
IC RSS-243 3.5, 5.6 IC RSS-Gen 7.1	Receiver spurious emissions	ANSI C63.4	PASS	
FCC § 15.207 IC RSS-Gen 8.8	AC power line conducted emissions	ANSI C63.4	PASS	
FCC § 95.628(a)(3) IC RSS-243 3.6, 5.7.1	System threshold power levels	EN 301 839-1 10.1	PASS	
FCC § 95.628(a)(1) IC RSS-243 3.6, 5.7.2	Monitoring system bandwidth	EN 301 839-1 10.2	PASS	
FCC § 95.628(a)(2) IC RSS-243 3.6, 5.7.3	Scan cycle time	EN 301 839-1 10.3	PASS	
FCC § 95.628(a)(2) IC RSS-243 3.6, 5.7.4	Minimum channel monitoring period	EN 301 839-1 10.3	PASS	
FCC § 95.628(a)(4) IC RSS-243 3.6, 5.7.5	Channel Access	EN 301 839-1 10.4	PASS	
FCC § 95.628(a)(4) IC RSS-243 3.6, 5.7.6	Discontinuation of MICS or MEDS session	EN 301 839-1 10.5	PASS	
FCC § 95.628(a)(5) IC RSS-243 3.6, 5.7.7	Use of the pre-scanned alternate channel	EN 301 839-1 10.6	N/A	
Remarks:				

3 Test Conditions and Results


3.1 Test Conditions and Results – Occupied Bandwidth

Occupied Bandwidth acc. to IC RSS-243			Verdict: PASS
Test according to measurement reference	Reference Method		
	RSS-Gen 6.6		
Test frequency range	Tested frequencies		
	F _{LOW} / F _{MID} / F _{HIGH}		
EUT test mode	Modulated		
Limits			
None (Informational only)			
Test setup			
Spectrum Analyzer EUT			
Test procedure			
1. EUT set to test mode (Communication tester is used if needed) 2. Span set to at least twice the emission spectrum 3. Resolution bandwidth set to 1 % of span 4. Occupied Bandwidth (99 %) measurement with spectrum analyzer built in measurement function			
Test results – Transmitter & Antenna 1			
Channel	Frequency [MHz]	Data rate [kbps]	Occupied Bandwidth [kHz]
F _{LOW}	402.45	4	162.000
F _{MID}	403.65	4	164.700
F _{HIGH}	404.85	4	163.800
F _{LOW}	402.45	16	96.525
F _{MID}	403.65	16	94.275
F _{HIGH}	404.85	16	94.500
F _{LOW}	402.45	32	115.650
F _{MID}	403.65	32	115.875
F _{HIGH}	404.85	32	115.650
F _{LOW}	402.45	197	233.100
F _{MID}	403.65	197	231.750
F _{HIGH}	404.85	197	232.425
Comments:			

Occupied Bandwidth – Transmitter 4kbps F_{LOW}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
Applicant: Biotronik SE & Co.KG
Model Description: Telemonitoring System
Model: CardioMessenger Smart 3G
Test Sample ID: 01 005
Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
Operational Mode: 2FSK, 4 kbps, Channel: 8, 402.45 MHz
Operating Conditions: T_{nom} / V_{nom}
Operator: W. Treffke
Test Site: Eurofins Product Service GmbH
Test Date: 2016-12-20
Occupied Bandwidth [kHz]: 161.775




Date: 20.DEC.2016 15:02:39

Occupied Bandwidth - Transmitter 4kbps F_{MID}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 4 kbps, Channel: 0, 403.65 MHz
 Operating Conditions: Tnom / Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 164.700



Date: 20.DEC.2016 15:07:05


Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Occupied Bandwidth - Transmitter 4kbps F_{HIGH}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 4 kbps, Channel: 7, 404.85 MHz
 Operating Conditions: Tnom / Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 163.800



Date: 20.DEC.2016 15:17:52


Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Occupied Bandwidth - Transmitter 16kbps F_{Low}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 16 kbps, Channel: 8, 402.45 MHz
 Operating Conditions: T_{nom} / V_{nom}
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 94.725




Date: 20.DEC.2016 14:47:18

Occupied Bandwidth - Transmitter 16kbps F_{MID}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 16 kbps, Channel: 0, 403.65 MHz
 Operating Conditions: T_{nom} / V_{nom}
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 94.275




Date: 20.DEC.2016 15:08:35

Occupied Bandwidth - Transmitter 16kbps F_{HIGH}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 16 kbps, Channel: 7, 404.85 MHz
 Operating Conditions: T_{nom} / V_{nom}
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 94.500




Date: 20.DEC.2016 15:20:15

Occupied Bandwidth - Transmitter 32kbps F_{Low}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
Applicant: Biotronik SE & Co.KG
Model Description: Telemonitoring System
Model: CardioMessenger Smart 3G
Test Sample ID: 01 005
Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
Operational Mode: 2FSK, 32 kbps, Channel: 8, 402.45 MHz
Operating Conditions: T_{nom} / V_{nom}
Operator: W. Treffke
Test Site: Eurofins Product Service GmbH
Test Date: 2016-12-20
Occupied Bandwidth [kHz]: 115.650



Date: 20.DEC.2016 14:58:04


Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Occupied Bandwidth - Transmitter 32bps F_{MID}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
Applicant: Biotronik SE & Co.KG
Model Description: Telemonitoring System
Model: CardioMessenger Smart 3G
Test Sample ID: 01 005
Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
Operational Mode: 2FSK, 32 kbps, Channel: 0, 403.65 MHz
Operating Conditions: Tnom / Vnom
Operator: W. Treffke
Test Site: Eurofins Product Service GmbH
Test Date: 2016-12-20
Occupied Bandwidth [kHz]: 115.875




Date: 20.DEC.2016 15:12:28

Occupied Bandwidth - Transmitter 32kbps F_{HIGH}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 32 kbps, Channel: 7, 404.85 MHz
 Operating Conditions: Tnom / Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 115.650




Date: 20.DEC.2016 15:22:26

Occupied Bandwidth - Transmitter 197kbps F_{Low}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
Applicant: Biotronik SE & Co.KG
Model Description: Telemonitoring System
Model: CardioMessenger Smart 3G
Test Sample ID: 01 005
Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
Operational Mode: 2FSK, 197 kbps, Channel: 8, 402.45 MHz
Operating Conditions: Tnom / Vnom
Operator: W. Treffke
Test Site: Eurofins Product Service GmbH
Test Date: 2016-12-20
Occupied Bandwidth [kHz]: 233.100




Date: 20.DEC.2016 15:01:10

Occupied Bandwidth - Transmitter 197kbps F_{MID}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 197 kbps, Channel: 0, 403.65 MHz
 Operating Conditions: Tnom / Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 231.750



Date: 20.DEC.2016 15:15:02


Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Occupied Bandwidth - Transmitter 197kbps F_{HIGH}

Occupied Bandwidth RSS-243

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Method: RSS-Gen Issue 4 6.6 (Occupied Bandwidth)
 Operational Mode: 2FSK, 197 kbps, Channel: 7, 404.85 MHz
 Operating Conditions: Tnom / Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Occupied Bandwidth [kHz]: 232.425



Date: 20.DEC.2016 15:27:01


3.2 Test Conditions and Results – Emission Bandwidth

Emission Bandwidth acc. to FCC Part 95 / IC RSS-243				Verdict: PASS
EUT requirement rule parts and clause	Reference			
	FCC 95.628(d) / FCC 95.633(e) / IC RSS-243 3.3 5.1			
Test according to measurement reference	Reference Method			
	FCC 95.628(a)(6)(i) / FCC 95.633(e)(3)			
Test frequency range	Tested frequencies			
	F _{LOW} / F _{MID} / F _{HIGH}			
EUT test mode	Modulated			
Limits				
≤ 300 kHz				
Test setup				
Spectrum Analyzer EUT				
Test procedure				
1. EUT set to test mode 2. Span set to at least twice the emission spectrum 3. Detector set to peak and max hold 4. Envelope peak value of emission spectrum is selected 5. Marker on envelope of spectrum is set to level of -20 dB to the left of the peak 6. Marker on envelope of spectrum is set to level of -20 dB to the right of the peak 7. 20 dB Emission Bandwidth is determined by marker frequency separation				
Test results – Transmitter				
Channel	Frequency [MHz]	Emission Bandwidth [kHz]	Limit [kHz]	Result
F _{LOW}	402.45	254.250	≤ 300	PASS
F _{MID}	403.65	256.050	≤ 300	PASS
F _{HIGH}	404.85	255.600	≤ 300	PASS
Comments:				

Emission Bandwidth – Transmitter 197kbps F_{LOW}

20 dB Bandwidth FCC

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Standards: FCC 95.627
 Reference Method: 47 CFR § 95.627(a)(6)(i)
 Operational Mode: 2FSK, 197 kbps, Channel: 8, 402.45 MHz
 Operating Conditions: Tnom/Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Lower Frequency [MHz]: 402.322
 Upper Frequency [MHz]: 402.576
 20 dB Bandwidth [kHz]: 254.250




Date: 20.DEC.2016 15:36:17

Emission Bandwidth – Transmitter 197kbps F_{MID}

20 dB Bandwidth FCC

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Standards: FCC 95.627
 Reference Method: 47 CFR § 95.627(a)(6)(i)
 Operational Mode: 2FSK, 16 kbps, Channel: 0, 403.65 MHz
 Operating Conditions: Tnom/Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Lower Frequency [MHz]: 403.522
 Upper Frequency [MHz]: 403.778
 20 dB Bandwidth [kHz]: 256.050




Date: 20.DEC.2016 15:32:55

Emission Bandwidth – Transmitter 197kbps F_{HIGH}


20 dB Bandwidth FCC

Project Number: G0M-1612-6098
 Applicant: Biotronik SE & Co.KG
 Model Description: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Sample ID: 01 005
 Reference Standards: FCC 95.627
 Reference Method: 47 CFR § 95.627(a)(6)(i)
 Operational Mode: 2FSK, 16 kbps, Channel: 7, 404.85 MHz
 Operating Conditions: Tnom/Vnom
 Operator: W. Treffke
 Test Site: Eurofins Product Service GmbH
 Test Date: 2016-12-20
 Lower Frequency [MHz]: 404.721
 Upper Frequency [MHz]: 404.977
 20 dB Bandwidth [kHz]: 255.600




Date: 20.DEC.2016 15:40:24

3.3 Test Conditions and Results – Frequency stability

Frequency stability acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
EUT requirement rule parts and clause	Reference	
	FCC 95.628(e) / IC RSS-243 3.3 5.3 / RSS-Gen 4.7	
Test according to measurement reference	Reference Method	
	EN 301 839-1 8.1	
Test frequency range	Tested frequencies	
	$F_{\text{LOW}} / F_{\text{HIGH}}$	
EUT test mode	Unmodulated	
Limits		
$\leq \pm 100$ ppm		
Test setup		
 <pre> graph LR Power[Power] --- EUT[EUT (Test fixture)] subgraph Climatic Chamber EUT end EUT --- SA[Spectrum Analyzer] SA --- RR[Rubidium Reference] </pre>		
Test procedure		
1. EUT set to test mode with supply voltage and temperature set to nominal conditions 2. EUT transmits without modulation 3. Detector set to peak and max hold 4. Peak of emission is measured using a frequency counter 5. The frequency error is determined as the deviation of the emission frequency from the nominal frequency stated by the customer.		


Test results					
Channel	Nominal Frequency [MHz]	Temperature [°C]	Supply voltage	Frequency [MHz]	Drift [ppm]
F _{LOW}	402.45	-20	V _{NOM} = 3.7 VDC	402.448958	-02.59
F _{HIGH}	404.85	-20	V _{NOM} = 3.7 VDC	404.849141	-02.12
F _{LOW}	402.45	-10	V _{NOM} = 3.7 VDC	402.449354	-01.61
F _{HIGH}	404.85	-10	V _{NOM} = 3.7 VDC	404.849489	-01.26
F _{LOW}	402.45	0	V _{NOM} = 3.7 VDC	402.450846	02.10
F _{HIGH}	404.85	0	V _{NOM} = 3.7 VDC	404.851015	02.51
F _{LOW}	402.45	10	V _{NOM} = 3.7 VDC	402.450636	01.58
F _{HIGH}	404.85	10	V _{NOM} = 3.7 VDC	404.850835	02.06
F _{LOW}	402.45	20	V _{NOM} = 3.7 VDC	402.449881	-00.30
F _{HIGH}	404.85	20	V _{NOM} = 3.7 VDC	404.850038	00.09
F _{LOW}	402.45	20	V _{MIN} = 3.1 VDC	402.449845	-00.39
F _{HIGH}	404.85	20	V _{MIN} = 3.1 VDC	404.850052	00.13
F _{LOW}	402.45	20	V _{MAX} = 4.16 VDC	402.449874	-00.31
F _{HIGH}	404.85	20	V _{MAX} = 4.16 VDC	404.850043	00.11
F _{LOW}	402.45	30	V _{NOM} = 3.7 VDC	402.449319	-01.69
F _{HIGH}	404.85	30	V _{NOM} = 3.7 VDC	404.849430	-01.41
F _{LOW}	402.45	40	V _{NOM} = 3.7 VDC	402.448446	-03.86
F _{HIGH}	404.85	40	V _{NOM} = 3.7 VDC	404.848634	-03.37
Comments:					

3.4 Test Conditions and Results – Transmitter output power

Transmitter output power acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
EUT requirement rule parts and clause	Reference	
	FCC 95.639(f) / IC RSS-243 5.4	
Test according to measurement reference	Reference Method	
	EN 301 839-1 8.3	
Test frequency range	Tested frequencies	
	$F_{\text{LOW}} / F_{\text{MID}} / F_{\text{HIGH}}$	
EUT test mode	Modulated	
Limits		
$\leq 25 \mu\text{W}$ (-16 dBm) e.i.r.p.		
Test setup		
		
Test procedure		
1. EUT set to test frequency with modulation 2. Measurement polarization is set to vertical 3. Span it set according to measurement range and detector is set to peak and max hold 4. Resolution bandwidth is set to be at least twice the emission bandwidth 5. During the sweep the EUT is rotated to obtain maximum emission level 6. Measurement is repeated with horizontal measurement polarization		

Test results – Transmitter						
Channel	Frequency [MHz]	Emission Level [dBm e.i.r.p.]	Pol	Detector	Limit [dBm e.i.r.p.]	Margin [dB]
F _{LOW}	402.45	-18.1	Hor	pk	-16	-02.10
F _{LOW}	402.45	-42.7	Ver	pk	-16	-26.70
F _{HIGH}	404.85	-16.5	Hor	pk	-16	-00.50
F _{HIGH}	404.85	-42.9	Ver	pk	-16	-26.90
Comments:						

3.5 Test Conditions and Results – Band-edge and In-band Emissions

Band-edge and in-band emission compliance acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
EUT requirement rule parts and clause	Reference	
	FCC 95.635(d) / IC RSS-243 3.5 5.5 / RSS-Gen 4.9	
Test according to measurement reference	Reference Method	
	FCC 95.635(d) / ANSI C 63.4	
Test frequency range	Tested frequencies	
	F _{LOW} / F _{HIGH}	
EUT test mode	Modulated	
Limits - FCC		
Frequency range	Limit	
402 MHz – 250 kHz ≤ f ≤ 402 MHz	20 dB below maximum permitted output power	
402 MHz < f < 150 kHz - f _C	20 dB below transmitter output power	
150 kHz + f _C < f < 405 Mhz	20 dB below transmitter output power	
405 MHz ≤ f ≤ 405 MHz + 250 kHz	20 dB below maximum permitted output power	
Limits - IC		
Frequency range	Limit	
402 MHz – 250 kHz < f < 150 kHz-f _C	20 dB below maximum permitted output power	
150 kHz+f _C < f < 405 MHz + 250 kHz	20 dB below maximum permitted output power	
Because the FCC limits are more stringent than the Industry Canada limits, the FCC limits are used to show compliance with the band-edge emission requirements.		
Test setup		
		


Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Test procedure						
1. EUT set to test frequency with modulation 2. Measurement polarization is set to vertical 3. Span it set according to measurement range 4. Resolution bandwidth is set to 1% of the emission bandwidth and detector is set to peak 5. During the sweep the EUT is rotated to obtain maximum emission level 6. Measurement is repeated with horizontal measurement polarization						
Test results – Transmitter						
Channel	Frequency [MHz]	Emission [MHz]	Level [dBμV/m]	Pol.	Limit [dBμV/m]	Margin [dB]
F _{LOW}	402.45	401.991	25.08	hor	59.40	-34.32
F _{LOW}	402.45	402.293	35.58	hor	54.00	-18.42
F _{LOW}	402.45	402.293	10.73	ver	54.00	-43.27
F _{LOW}	402.45	402.605	35.43	hor	54.00	-18.57
F _{LOW}	402.45	402.605	11.53	ver	54.00	-42.47
F _{HIGH}	404.85	404.678	36.25	hor	54.00	-17.75
F _{HIGH}	404.85	404.695	11.15	ver	54.00	-42.85
F _{HIGH}	404.85	405.000	38.13	hor	54.00	-15.87
F _{HIGH}	404.85	405.000	12.14	ver	54.00	-41.86
F _{HIGH}	404.85	405.006	36.74	hor	59.40	-22.66
F _{HIGH}	404.85	405.006	13.84	ver	59.40	-45.56

Test procedure								
1. EUT set to test mode 2. Span it set according to measurement range 3. Resolution bandwidth below 1 GHz is set according to CISPR 16 with peak/quasi-peak detector and RBW of 1 MHz with peak/average detector is used above 1 GHz 4. Markers are set to peak emission levels within restricted bands								
Test results – Transmitter								
Channel	Frequency [MHz]	Mode	Emission [MHz]	Level [dBμV/m]	Det.	Pol.	Limit [dBμV/m]	Margin [dB]
F _{LOW}	402.45	Modulated	401.347	27.87	pk	hor	46.00	-18.13
F _{LOW}	402.45	Modulated	406.44	19.88	pk	hor	46.00	-26.12
F _{LOW}	402.45	Modulated	804.922	33.14	pk	hor	46.00	-12.86
F _{HIGH}	404.85	Modulated	400.943	29.36	pk	hor	46.00	-16.64
F _{HIGH}	404.85	Modulated	405.25	37.93	pk	hor	46.00	-08.07
F _{HIGH}	404.85	Modulated	808.49	34.90	pk	hor	46.00	-11.10
F _{HIGH}	404.85	Modulated	850.123	32.64	pk	ver	46.00	-13.36
F _{HIGH}	404.85	Modulated	854.881	29.34	pk	hor	46.00	-16.66
Comments:								

3.7 Test Conditions and Results – Receiver spurious emissions

Receiver spurious emissions acc. to IC RSS-243				Verdict: PASS
Test according referenced standards	Reference Method			
	IC RSS-243 3.5 5.6 / IC RSS-Gen 4.10 6.1			
Test according to measurement reference	Reference Method			
	ANSI C 63.4			
Test frequency range	Tested frequencies			
	30 MHz – 5 th Harmonic			
EUT test mode	Receive			
Limits				
Frequency range [MHz]	Detector	Limit [μV/m]	Limit [dBμV/m]	Limit Distance [m]
30 – 88	Quasi-Peak	100	40	3
88 – 216	Quasi-Peak	150	43.5	3
216 – 960	Quasi-Peak	200	46	3
960 – 1000	Quasi-Peak	500	54	3
> 1000	Average	500	54	3
Test setup				
				

Test procedure							
1. EUT set to receive mode (Communication tester is used if needed) 2. Span it set according to measurement range 3. Resolution bandwidth below 1 GHz is set according to CISPR 16 with peak/quasi-peak detector and RBW of 1 MHz with peak/average detector is used above 1 GHz 4. Markers are set to peak emission levels							
Test results							
Channel	Frequency [MHz]	Emission [MHz]	Emission Level [dBμV/m]	Det.	Pol.	Limit [dBμV/m]	Margin [μV/m]
F _{MID}	403.65	3772	39.84	pk	hor	53.9	-14.06 dB
Comments:							

3.8 Test Conditions and Results – AC power line conducted emissions

Power line conducted emissions acc. to FCC 47 CFR 15.207 / IC RSS-Gen				Verdict: PASS	
Test according referenced standards		Reference Method			
		ANSI C 63.4			
Fully configured sample scanned over the following frequency range		Frequency range			
		0.15 MHz to 30 MHz			
Points of Application		Application Interface			
AC Mains		LISN			
EUT test mode		AC-Powerline			
Limits and results					
Frequency [MHz]	Quasi-Peak [dBµV]	Result	Average [dBµV]	Result	
0.15 to 5	66 to 56*	PASS	56 to 46*	PASS	
0.5 to 5	56	PASS	46	PASS	
5 to 30	60	PASS	50	PASS	
Comments:					
* Limit decreases linearly with the logarithm of the frequency.					


Conducted Emissions

EMI voltage test in the ac-mains according to FCC 15B

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: CardioMessenger Smart 3G
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Meili
 Test Conditions: Tnom: 23°C, Unom: 120 VAC 50 Hz
 LISN: ESH3-Z5 (L)
 Mode: Mode 1
 Test Date: 2016-12-19
 Note:

Index 65




Conducted Emissions

EMI voltage test in the ac-mains according to FCC 15B

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: CardioMessenger Smart 3G
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Meili
 Test Conditions: Tnom: 23°C, Unom: 120 VAC 50 Hz
 LISN: ESH3-Z5 (N)
 Mode: Mode 1
 Test Date: 2016-12-19
 Note:



Index 72



3.9 Test Conditions and Results – System threshold power levels

System threshold power levels acc. to FCC Part 95 / IC RSS-243			Verdict: PASS
Test according referenced standards	Reference Method		
	FCC 95.628(a)(3) / IC RSS-243 3.6 5.7.1		
Test according to measurement reference	Reference Method		
	EN 301 839-1 10.1		
Limits			
$P_{TH} [dBm] = 10 \cdot \text{Log}_{10}(EB[Hz]) - 150 + G[dBi]$ P_{TH} = LBT threshold level in dBm EB = Emission bandwidth in Hz G = Monitoring system antenna gain in dBi			
If an ULP-AMI device is used to select the frequency of operation for a MICS system, the above LBT threshold level requirement may be adjusted higher by 1 dB for every 1 dB the e.r.p. of the device performing the LBT and AFA function is below the maximum permitted level of -16 dBm e.r.p..			
Test procedure			
It is not necessary to measure the actual threshold power level of a MICS system; however, it shall be determined that the system uses the LIC selection process if no channel is available with an ambient power level at or below the calculated threshold power level.			
Test results			
Emission bandwidth of companion device [Hz]	Antenna gain [dBi]	Calculated threshold level [dBm]	Measured threshold level [dBm]
256000	-1.37	-97.3	-97.3
Comments: The EUT changed the channel from f_c (channel 0) to channel1 at a CW level of -93.3 dBm			

3.10 Test Conditions and Results – Monitoring system bandwidth



Monitoring system bandwidth acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
Test according referenced standards	Reference Method	
	FCC 95.628(a)(1) / IC RSS-243 3.6 5.7.2	
Test according to measurement reference	Reference Method	
	EN 301 839-1 10.2	
Test frequency range	Tested frequencies	
	F _{MID}	
EUT test mode	Monitoring A	
Limits		
≥ Emission bandwidth (equals to measured power level differences ≤ 20 dB)		
Test setup		
		
Test procedure		
1. By administration commands the following channel occupation is simulated to the device so that the EUT can only send on frequency f_c.  2. A CW signal is generated by the signal generator on frequency f_c with a level sufficient to block transmission of the EUT on channel f_c. It is verified that the EUT stops transmission. 3. A new communication session is established and the level of the signal generator is reduced until the EUT starts to transmit on channel f_c. 4. Then the frequency of the generator is set to the measured lower edge frequency of the emission bandwidth and the level of the signal generator is increased until the EUT starts to transmit in the out-of-band region again. The signal level is recorded. 5. The procedure is repeated at the upper edge frequency of the emission bandwidth measurement. The power level difference between the center and the edge frequency is recorded.		

Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Test results						
Channel	Frequency [MHz]	Center Interferer Level [dBm]	Edge $\pm$ EBW/2 [kHz]	Edge Interferer Level [dBm]	Level Difference [dB]	Limit [dB]
F _{MID}	403.65	-94.3	-128	-92.3	2	≤ 20
F _{MID}	403.65	-94.3	+128	-86.3	8	≤ 20
Comments:						

3.11 Test Conditions and Results – Scan cycle time

Scan cycle time acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
Test according referenced standards	Reference Method	
	FCC 95.628(a)(2) / IC RSS-243 3.6 5.7.3	
Test according to measurement reference	Reference Method	
	EN 301 839-1 10.3	
Test frequency range	Tested frequencies	
	F _{MID}	
EUT test mode	Monitoring A	
Limits		
≤ 5 s		
Test setup		
		
Test procedure		
1. By administration commands the following channel occupation is simulated to the device so that the EUT can only send on frequency f_c.  2. A CW signal is generated by the signal generator on frequency f_c with a level 3 dB above the out-of-band region level to block transmission of the EUT on channel f_c. It is verified that the EUT does not transmit on f_c. 3. The CW interferer is removed, a new communication session is established and the time until the EUT starts to transmit is measured. 4. If the EUT does not transmit on f_c a 1 second delay is added between the removal of the interferer and the establishment of the communication session. The addition of delay is repeated until the EUT always starts transmission on f_c. The delay time measurement is repeated several times. At the end 1 second is subtracted from all delays measured.		


Test results			
Channel	Frequency [MHz]	Scan cycle time [s]	Limit [s]
F _{MID}	403.65	0.3606	≤ 5
Comments:			

Spectrum Access – Monitoring system scan cycle time

Monitoring system scan cycle time

Project Number: G0M-1309-3225

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Wilfried Treffke
 Test Conditions: Tnom / Vnom
 Mode: EN 301 839
 Test Date: 2016-12-21
 Verdict: PASS
 Note 1: Comm. Channel = Ch1, changing to ch.0 after release of interferer @ ch0
 Note 2: Result 360.6 ms; Limit < 5 sec PASS



Date: 21.DEC.2016 11:21:24

Test Report No.: G0M-1612-6098-TFC95IM-V02



Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

3.12 Test Conditions and Results – Minimum channel monitoring period

Minimum channel monitoring period acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
Test according referenced standards	Reference Method	
	FCC 95.628(a)(2) / IC RSS-243 3.6 5.7.4	
Test according to measurement reference	Reference Method	
	EN 301 839-1 10.3	
Test frequency range	Tested frequencies	
	F _{MID}	
EUT test mode	Monitoring A	
Limits		
≥ 10 ms		
Test setup		
Signal Generator Splitter Spectrum Analyzer EUT PC		
Test procedure		
1. By administration commands the following channel occupation is simulated to the device so that the EUT can only send on frequency f_c. ULP-AMI Band 3 dB Calculated Access Threshold 402 MHz f_c 405 MHz Amplitude Frequency Out-of-Operating Region Disturbance EUT Operating Region 2. A CW signal is generated by the signal generator on frequency f_c with a level equal to the out-of-band region level to block transmission of the EUT on channel f_c and the out-of-band interference is removed. It is verified that the EUT does not transmit on f_c. 3. Then the out-of-band interference level is set to 3 dB higher and it is verified that the EUT transmits on f_c. 4. The out-of-band interferer are pulsed with a pulse width of 0.1 ms and a repetition frequency of 100Hz. The EUT is placed in a state where it is seeking to initiate a communication session with the ULP-AMI companion device. 5. The EUT shall not initiate a communication session on a channel different from f_c. This condition is checked more than 10 times.		



Test results					
Channel	Frequency [MHz]	Interferer Channel	Interferer level [dBm]	Carrier transmits on Channel	Result
F _{MID}	403.65	0	OFF	0	Pass
F _{MID}	403.65	0	-91.3	1	Pass
Comments: For practical reasons the test has been performed with a fixed interferer level in the out-of-band region and a pulsed interferer level on center channel. To make sure that the monitoring period requirement was met, it was verified that no communication on center channel had been initiated.					

3.13 Test Conditions and Results – Channel access

Channel access acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
Test according referenced standards	Reference Method	
	FCC 95.628(a)(4) / IC RSS-243 3.6 5.7.1	
Test according to measurement reference	Reference Method	
	EN 301 839-1 10.4	
Test frequency range	Tested frequencies	
	F _{MID}	
EUT test mode	Monitoring A	
Limits		
EUT has to select and transmit on least interfered channel (LIC)		
Test setup		
		
Test procedure		
1. By administration commands the following channel occupation is simulated to the device so that the EUT can only send on frequency f_c.  2. A CW signal is generated by the signal generator on frequency f_c with a level 3 dB lower than the calculated LBT threshold level. It is determined that the EUT communicates on f_c. 3. The CW interferer level is increased by 9dB and a new communication session is initiated. Now it is checked that the EUT communicates on the LIC center frequency.		

Test results						
Step	Frequency [MHz]	LIC channel	Frequency [MHz]	Interferer level channel 0 [dBm]	Communication channel	Result
1	403.65	N/A	N/A	N/A	0	Pass
2	403.65	4	403.04	-100.3	0	Pass
3	403.65	4	403.04	-91.3	4	Pass
Comments:						

3.14 Test Conditions and Results – Discontinuation of MICS or MEDS session

Discontinuation of MICS or MEDS session acc. to FCC Part 95 / IC RSS-243		Verdict: PASS
Test according referenced standards	Reference Method	
	FCC 95.628(a)(4) / IC RSS-243 3.6 5.7.7	
Test according to measurement reference	Reference Method	
	EN 301 839-1 10.5	
Test frequency range	Tested frequencies	
	F _{MID}	
EUT test mode	Monitoring B	
Limits		
Cease transmission for silent period ≥ 5 s		
Test setup		
		
Test procedure		
1. By administration commands the following channel occupation is simulated to the device so that the EUT can only send on frequency f_c.  2. A CW signal is generated by the signal generator on frequency f_c with a level 9 dB higher than the calculated LBT threshold level. It is determined that the EUT communicates on LIC channel. 3. The CW interferer level is reduced to a level 3 dB below the threshold level and the ULP-AMI is switched off. The transmission of the EUT (ULP-AMI-P) is captured until the transmission is finished and the time is recorded. 4. The ULP-AMI is enabled again and the communication session should not restart on previous LIC channel.		

Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany


Test results							
Step	Frequency [MHz]	LIC Channel	Frequency [MHz]	Interferer channel	Interferer Level [dBm]	Communication channel	Result
1	403.65	N/A	N/A	N/A	N/A	0	Pass
2	403.65	4	403.04	0	-88.3	4	Pass
3	403.65	4	403.04	0	-100.3	4, Communication ends 0.2 ms after ULP-AMI switched off	Pass
4	403.65	4	403.04	0	-100.3	0, After restart	Pass
Comments:							

Spectrum Access – Discontinuation of MICS session - regular traffic

Discontinuation of MICS session if a silent period greater than or equal 5 s

Project Number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Wilfried Treffke
 Test Conditions: Tnom / Vnom
 Mode: Tx 403.65 MHz
 Test Date: 2016-12-21
 Verdict: PASS
 Note 1: communication channel
 Note 2: Mode: communication link, fully message



Date: 21.DEC.2016 13:32:06

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spectrum Access – Discontinuation of MICS session – traffic after ULP-AMI switched off

Discontinuation of MICS session if a silent period greater than or equal 5 s

Project Number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Wilfried Treffke
 Test Conditions: Tnom / Vnom
 Mode: Tx 403.65 MHz
 Test Date: 2016-12-21
 Verdict: PASS
 Note 1: No communication after 0.2 ms silent period @ communication channel



Date: 21.DEC.2016 13:23:05


ANNEX A Transmitter output power

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Horizontal
Measurement distance:	3 m
Mode:	Tx; 402.45 MHz, CW
Test Date:	2016-12-19
Note:	Tx Power EIRP

Index 12



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
402.419 MHz	-18.1 dBm	-16 dBm	-2.1 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	Tx; 402.45 MHz, CW
Test Date:	2016-12-19
Note:	Tx Power EIRP

Index 15



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
402.409 MHz	-42.7 dBm	-16 dBm	-26.71 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: Tx; 404.85 MHz, CW
 Test Date: 2016-12-19
 Note: Tx Power EIRP

Index 19



Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Vertical
 Measurement distance: 3 m
 Mode: Tx; 404.85 MHz, CW
 Test Date: 2016-12-19
 Note: Tx Power EIRP

Index 21



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
404.806 MHz	-42.9 dBm	-16 dBm	-26.92 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Horizontal
Measurement distance:	3 m
Mode:	Tx; 402.45 MHz, CW
Test Date:	2016-12-19
Note:	Power dBμV/m ERP

Index 13



Frequency
402.41 MHz


Peak
74.07 dBμV/m

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	Tx; 402.45 MHz, CW
Test Date:	2016-12-19
Note:	Power dB μ V/m ERP

Index 14



Frequency
402.43 MHz

Peak
54.23 dB μ V/m

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Horizontal
Measurement distance:	3 m
Mode:	Tx; 404.85 MHz, CW
Test Date:	2016-12-19
Note:	Power dBμV/m ERP

Index 20



Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Radiated power according to FCC part 95 MedRadio (402-405MHz)

Order number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	Tx; 404.85 MHz, CW
Test Date:	2016-12-19
Note:	Power dBμV/m ERP

Index 22



Frequency
404.81 MHz

Peak
54.06 dBμV/m

Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany


ANNEX B Transmitter Band-edge and In-band emissions

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 402.45 MHz, 2FSK
 Test Date: 2016-12-19
 Note: Band-edge

Index 27




Frequency	Peak	Peak Limit	Peak Difference	Peak Status
401.991 MHz	25.08 dBµV/m	59.4 dBµV/m	-34.32 dB	Pass

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	TX; 402.45 MHz, 2FSK
Test Date:	2016-12-19
Note:	Band-edge

Index 26



Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 402.45 MHz, 2FSK
 Test Date: 2016-12-19
 Note: In-band emissions

Index 29



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
402.293 MHz	35.58 dBµV/m	54 dBµV/m	-18.42 dB	Pass
402.605 MHz	35.43 dBµV/m	54 dBµV/m	-18.57 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Vertical
 Measurement distance: 3 m
 Mode: TX; 402.45 MHz, 2FSK
 Test Date: 2016-12-19
 Note: In-band emissions

Index 30



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
402.293 MHz	10.73 dBµV/m	54 dBµV/m	-43.27 dB	Pass
402.605 MHz	11.53 dBµV/m	54 dBµV/m	-42.47 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note: Band-edge

Index 45




Frequency	Peak	Peak Limit	Peak Difference	Peak Status
405.006 MHz	36.74 dBµV/m	59.4 dBµV/m	-22.66 dB	Pass

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Vertical
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note: Band-edge

Index 49




Frequency	Peak	Peak Limit	Peak Difference	Peak Status
405.006 MHz	13.84 dBµV/m	59.4 dBµV/m	-45.56 dB	Pass

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note: In-band emissions

Index 47




Frequency	Peak	Peak Limit	Peak Difference	Peak Status
404.678 MHz	36.25 dBµV/m	54 dBµV/m	-17.75 dB	Pass
405 MHz	38.13 dBµV/m	54 dBµV/m	-15.87 dB	Pass

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Vertical
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note: In-band emissions

Index 51



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
404.695 MHz	11.15 dBµV/m	54 dBµV/m	-42.85 dB	Pass
405 MHz	12.14 dBµV/m	54 dBµV/m	-41.86 dB	Pass


ANNEX C Transmitter radiated spurious emissions

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HK 116, Horizontal
Measurement distance:	3 m
Mode:	TX; 402.45 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 34




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HK 116, Vertical
Measurement distance:	3 m
Mode:	TX; 402.45 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 35




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 402.45 MHz, 2FSK
 Test Date: 2016-12-19
 Note:

Index 24



Frequency	Peak	Peak Limit	Peak Difference	Status
401.347 MHz	27.87 dBµV/m	46 dBµV/m	-18.13 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	TX; 402.45 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 25




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 402.45 MHz, 2FSK
 Test Date: 2016-12-19
 Note:

Index 33



Frequency	Peak	Peak Limit	Peak Difference	Peak Status
406.44 MHz	19.88 dBμV/m	46 dBμV/m	-26.12 dB	Pass
804.922 MHz	33.14 dBμV/m	46 dBμV/m	-12.86 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	TX; 402.45 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 31




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Schwarzbeck BBHA 9120D, Horizontal
 Measurement distance: 3 m
 Mode: TX; 402.45 MHz, 2FSK
 Test Date: 2016-12-19
 Note:

Index 38




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Schwarzbeck BBHA 9120D, Vertical
Measurement distance:	3 m
Mode:	TX; 402.45 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 39




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HK 116, Horizontal
Measurement distance:	3 m
Mode:	TX; 404.85 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 42




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HK 116, Vertical
Measurement distance:	3 m
Mode:	TX; 404.85 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 43



Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note:

Index 44



Frequency	Peak	Peak Limit	Peak Difference	Status
400.943 MHz	29.36 dBµV/m	46 dBµV/m	-16.64 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02


Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	TX; 404.85 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 48




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Vertical
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note:

Index 52




Frequency	Peak	Peak Limit	Peak Difference	Peak Status
850.123 MHz	32.64 dBµV/m	46 dBµV/m	-13.36 dB	Pass

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom:
 Antenna: Rohde & Schwarz HL 223, Horizontal
 Measurement distance: 3 m
 Mode: TX; 404.85 MHz, 2FSK
 Test Date: 2016-12-19
 Note:

Index 53




Frequency	Peak	Peak Limit	Peak Difference	Peak Status
405.25 MHz	37.93 dBµV/m	46 dBµV/m	-8.07 dB	Pass
808.49 MHz	34.9 dBµV/m	46 dBµV/m	-11.1 dB	Pass
854.881 MHz	29.34 dBµV/m	46 dBµV/m	-16.66 dB	Pass

Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Schwarzbeck BBHA 9120D, Horizontal
Measurement distance:	3 m
Mode:	TX; 404.85 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 40




Spurious emissions according to FCC part 95 MedRadio (402-405MHz)

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom:
Antenna:	Schwarzbeck BBHA 9120D, Vertical
Measurement distance:	3 m
Mode:	TX; 404.85 MHz, 2FSK
Test Date:	2016-12-19
Note:	

Index 41




ANNEX D Receiver radiated spurious emissions

Spurious emissions according to RSS-Gen Issue 4

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom: 3.7 V DC
Antenna:	Rohde & Schwarz HK 116, Horizontal
Measurement distance:	3 m
Mode:	RX; 403.65 MHz
Test Date:	2016-12-19
Note:	

Index 59




Spurious emissions according to RSS-Gen Issue 4

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom: 3.7 V DC
Antenna:	Rohde & Schwarz HK 116, Vertical
Measurement distance:	3 m
Mode:	RX; 403.65 MHz
Test Date:	2016-12-19
Note:	

Index 60




Spurious emissions according to RSS-Gen Issue 4

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom: 3.7 V DC
Antenna:	Rohde & Schwarz HL 223, Horizontal
Measurement distance:	3 m
Mode:	RX; 403.65 MHz
Test Date:	2016-12-19
Note:	

Index 54




Spurious emissions according to RSS-Gen Issue 4

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom: 3.7 V DC
Antenna:	Rohde & Schwarz HL 223, Vertical
Measurement distance:	3 m
Mode:	RX; 403.65 MHz
Test Date:	2016-12-19
Note:	

Index 58




Spurious emissions according to RSS-Gen Issue 4

Project number: G0M-1612-6098

Applicant: Biotronik SE & Co. KG
 EUT Name: Telemonitoring System
 Model: CardioMessenger Smart 3G
 Test Site: Eurofins Product Service GmbH
 Operator: Mr. Treffke
 Test Conditions: Tnom: 25°C, Vnom: 3.7 V DC
 Antenna: Schwarzbeck BBHA 9120D, Horizontal
 Measurement distance: 3 m
 Mode: RX; 403.65 MHz
 Test Date: 2016-12-19
 Note:

Index 61



Frequency	Peak	Peak Limit	Peak Difference	Status
3.772 GHz	39.84 dBµV/m	53.9 dBµV/m	-14.06 dB	Pass

Test Report No.: G0M-1612-6098-TFC95IM-V02

Eurofins Product Service GmbH
 Storkower Str. 38c, D-15526 Reichenwalde, Germany

Spurious emissions according to RSS-Gen Issue 4

Project number: G0M-1612-6098

Applicant:	Biotronik SE & Co. KG
EUT Name:	Telemonitoring System
Model:	CardioMessenger Smart 3G
Test Site:	Eurofins Product Service GmbH
Operator:	Mr. Treffke
Test Conditions:	Tnom: 25°C, Vnom: 3.7 V DC
Antenna:	Schwarzbeck BBHA 9120D, Vertical
Measurement distance:	3 m
Mode:	RX; 403.65 MHz
Test Date:	2016-12-19
Note:	

Index 62

