


Impedance Measurement Plot for Head TSL





DASY5 Validation Report for Body TSL

Date: 14.12.2023

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole D5GHzV2; Type: D5GHzV2; Serial: D5GHzV2 - SN:1100

Communication System: UID 0 - CW; Frequency: 5200 MHz, Frequency: 5300 MHz, Frequency: 5500

MHz, Frequency: 5600 MHz, Frequency: 5800 MHz

Medium parameters used: f = 5200 MHz; σ = 5.44 S/m; ϵ_r = 49.2; ρ = 1000 kg/m³ ,

Medium parameters used: f = 5300 MHz; σ = 5.60 S/m; ϵ_r = 49.1; ρ = 1000 kg/m³ ,

Medium parameters used: f = 5500 MHz; $\sigma = 5.88$ S/m; $\varepsilon_r = 48.8$; $\rho = 1000$ kg/m³,

Medium parameters used: f = 5600 MHz; $\sigma = 6.01$ S/m; $\epsilon_r = 48.7$; $\rho = 1000$ kg/m³,

Medium parameters used: f = 5800 MHz; $\sigma = 6.28 \text{ S/m}$; $\epsilon_r = 48.3$; $\rho = 1000 \text{ kg/m}^3$

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

- Probe: EX3DV4 SN3503; ConvF(5.29, 5.29, 5.29) @ 5200 MHz, ConvF(5.23, 5.23, 5.23) @ 5300 MHz, ConvF(4.84, 4.84, 4.84) @ 5500 MHz, ConvF(4.79, 4.79, 4.79) @ 5600 MHz, ConvF(4.62, 4.62, 4.62) @ 5800 MHz; Calibrated: 07.03.2023
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn601; Calibrated: 03.10.2023
- Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002
- DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5200 MHz/Zoom Scan, dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 65.06 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 26.0 W/kg

SAR(1 g) = 7.31 W/kg; SAR(10 g) = 2.07 W/kg

Smallest distance from peaks to all points 3 dB below = 7.2 mm

Ratio of SAR at M2 to SAR at M1 = 69.3%

Maximum value of SAR (measured) = 16.5 W/kg

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5300 MHz/Zoom Scan,

dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 64.35 V/m; Power Drift = -0.08 dB

Peak SAR (extrapolated) = 27.4 W/kg

SAR(1 g) = 7.33 W/kg; SAR(10 g) = 2.06 W/kg

Smallest distance from peaks to all points 3 dB below = 7.2 mm

Ratio of SAR at M2 to SAR at M1 = 67.8%

Maximum value of SAR (measured) = 16.9 W/kg

Certificate No: D5GHzV2-1100_Dec23 Page 14 of 16



Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5500 MHz/Zoom Scan,

dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 66.02 V/m; Power Drift = -0.07 dB

Peak SAR (extrapolated) = 31.2 W/kg

SAR(1 g) = 7.86 W/kg; SAR(10 g) = 2.17 W/kg

Smallest distance from peaks to all points 3 dB below = 7.2 mm

Ratio of SAR at M2 to SAR at M1 = 66%

Maximum value of SAR (measured) = 18.5 W/kg

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5600 MHz/Zoom Scan,

dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx-4mm, dy=4mm, dz=1.4mm

Reference Value = 64.95 V/m; Power Drift = -0.09 dB

Peak SAR (extrapolated) = 32.2 W/kg

SAR(1 g) = 7.86 W/kg; SAR(10 g) = 2.21 W/kg

Smallest distance from peaks to all points 3 dB below = 7.2 mm

Ratio of SAR at M2 to SAR at M1 = 64.7%

Maximum value of SAR (measured) = 18.8 W/kg

Dipole Calibration for Body Tissue/Pin=100mW, dist=10mm, f=5800 MHz/Zoom Scan,

dist=1.4mm (8x8x7)/Cube 0: Measurement grid: dx=4mm, dy=4mm, dz=1.4mm

Reference Value = 63.73 V/m; Power Drift = -0.08 dB


Peak SAR (extrapolated) = 31.2 W/kg

SAR(1 g) = 7.50 W/kg; SAR(10 g) = 2.07 W/kg

Smallest distance from peaks to all points 3 dB below = 7.2 mm


Ratio of SAR at M2 to SAR at M1 = 64.5%

Maximum value of SAR (measured) = 18.0 W/kg





Impedance Measurement Plot for Body TSL



Certificate No: D5GHzV2-1100_Dec23



Calibration Laboratory of Schmid & Partner **Engineering AG** Zeughausstrasse 43, 8004 Zurich, Switzerland



Schweizerlscher Kalibrierdienst S Service suisse d'étalonnage C Servizio svizzero di taratura **Swiss Calibration Service**

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS) The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Client TÜV SÜD

Fareham, United Kingdom

Certificate No. D2450V2-715 Dec23

CALIBRATION CERTIFICATE

Object D2450V2 - SN:715

QA CAL-05.v12 Calibration procedure(s)

Calibration Procedure for SAR Validation Sources between 0.7-3 GHz

Calibration date: December 07, 2023

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%,

Calibration Equipment used (M&TE critical for calibration)

1D #	Cal Date (Certificate No.)	Scheduled Calibration
SN: 104778	30-Mar-23 (No. 217-03804/03805)	Mar-24
SN: 103244	30-Mar-23 (No. 217-03804)	Mar-24
SN: 103245	30-Mar-23 (No. 217-03805)	Mar-24
SN: BH9394 (20k)	30-Mar-23 (No. 217-03809)	Mar-24
SN: 310982 / 06327	30-Mar-23 (No. 217-03810)	Mar-24
SN: 7349	03-Nov-23 (No. EX3-7349_Nov23)	Nov-24
SN: 601	03-Oct-23 (No. DAE4-601_Oct23)	Oct-24
ID#	Check Date (in house)	Scheduled Check
SN: GB39512475	30-Oct-14 (in house check Oct-22)	In house check: Oct-24
SN; US37292783	07-Oct-15 (in house check Oct-22)	In house check: Oct-24
SN; MY41093315	07-Oct-15 (in house check Oct-22)	In house check: Oct-24
SN: 100972	15-Jun-15 (in house check Oct-22)	In house check: Oct-24
SN: US41080477	31-Mar-14 (in house check Oct-22)	in house check: Oct-24
Name	Function	Signature
Paulo Pina	Laboratory Technician	1
Sven Kühn	Technical Manager	(0)
	SN: 104778 SN: 103244 SN: 103245 SN: BH9394 (20k) SN: 310982 / 06327 SN: 7349 SN: 601 ID # SN: GB39512475 SN: US37292783 SN: MY41093315 SN: 100972 SN: US41080477 Name Paulo Pina	SN: 104778 30-Mar-23 (No. 217-03804/03805) SN: 103244 30-Mar-23 (No. 217-03804) SN: 103245 30-Mar-23 (No. 217-03805) SN: BH9394 (20k) 30-Mar-23 (No. 217-03809) SN: 310982 / 06327 30-Mar-23 (No. 217-03810) SN: 7349 03-Nov-23 (No. EX3-7349_Nov23) SN: 601 03-Oct-23 (No. DAE4-601_Oct23) ID # Check Date (in house) SN: GB39512475 30-Oct-14 (in house check Oct-22) SN: US37292783 07-Oct-15 (in house check Oct-22) SN: MY41093315 07-Oct-15 (in house check Oct-22) SN: 100972 15-Jun-15 (in house check Oct-22) SN: US41080477 31-Mar-14 (in house check Oct-22) Name Function Paulo Pina Laboratory Technician

Issued: December 8, 2023

Certificate No: D2450V2-715_Dec23

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.



Calibration Laboratory of Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland





Schweizerlscher Kalibrierdienst
Service suisse d'étalonnage
Servizio svizzero di taratura
Swiss Calibration Service

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS)
The Swiss Accreditation Service is one of the signatories to the EA
Multilateral Agreement for the recognition of calibration certificates

Glossary:

TSL

tissue simulating liquid

ConvF N/A

sensitivity in TSL / NORM x,y,z not applicable or not measured

Calibration is Performed According to the Following Standards:

- a) IEC/IEEE 62209-1528, "Measurement Procedure For The Assessment Of Specific Absorption Rate Of Human Exposure To Radio Frequency Fields From Hand-Held And Body-Worn Wireless Communication Devices - Part 1528: Human Models, Instrumentation And Procedures (Frequency Range of 4 MHz to 10 GHz)", October 2020.
- b) KDB 865664, "SAR Measurement Requirements for 100 MHz to 6 GHz"

Additional Documentation:

c) DASY System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions: Further details are available from the Validation Report at the end
 of the certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL: The source is mounted in a touch configuration below the center marking of the flat phantom.
- Return Loss: This parameter is measured with the source positioned under the liquid filled phantom (as described in the measurement condition clause). The Return Loss ensures low reflected power. No uncertainty required.
- SAR measured: SAR measured at the stated antenna input power.
- SAR normalized: SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters: The measured TSL parameters are used to calculate the nominal SAR result.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Certificate No: D2450V2-715_Dec23

Page 2 of 8



Measurement Conditions

DASY system configuration, as far as not given on page 1

DASY Version	DASY52	V52.10.4
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	10 mm	with Spacer
Zoom Scan Resolution	dx, dy, dz = 5 mm	
Frequency	2450 MHz ± 1 MHz	

Head TSL parameters
The following parameters and calculations were applied

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	39.2	1.80 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	38.3 ± 6 %	1.85 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C		

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	250 mW input power	13.4 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	52.6 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	250 mW input power	6.21 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	24.6 W/kg ± 16.5 % (k=2)

Body TSL parameters
The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Body TSL parameters	22.0 °C	52.7	1.95 mho/m
Measured Body TSL parameters	(22.0 ± 0.2) °C	53.0 ± 6 %	2.01 mho/m ± 6 %
Body TSL temperature change during test	< 0.5 °C	(<u></u>	

SAR result with Body TSL

SAR averaged over 1 cm ³ (1 g) of Body TSL	Condition	
SAR measured	250 mW input power	12.5 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	49.3 W/kg ± 17.0 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Body TSL	condition	
SAR measured	250 mW input power	5.93 W/kg
SAR for nominal Body TSL parameters	normalized to 1W	23.6 W/kg ± 16.5 % (k=2)

Certificate No: D2450V2-715_Dec23



Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	51.7 Ω + 2.1 jΩ
Return Loss	- 31.6 dB

Antenna Parameters with Body TSL

Impedance, transformed to feed point	49.4 Ω + 2.5 jΩ
Return Loss	- 31.8 dB

General Antenna Parameters and Design

Electrical Delay (one direction)	1.157 ns

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

Manufactured by	SPEAG



DASY5 Validation Report for Head TSL

Date: 07.12.2023

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2450 MHz; Type: D2450V2; Serial: D2450V2 - SN:715

Communication System: UID 0 - CW; Frequency: 2450 MHz

Medium parameters used: f = 2450 MHz; $\sigma = 1.85$ S/m; $\varepsilon_r = 38.3$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

Probe: EX3DV4 - SN7349; ConvF(7.96, 7.96, 7.96) @ 2450 MHz; Calibrated: 03.11.2023

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn601; Calibrated: 03.10.2023

Phantom: Flat Phantom 5.0 (front); Type: QD000P50AA; Serial: 1001

DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Dipole Calibration for Head Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:

Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 116.1 V/m; Power Drift = 0.03 dB


Peak SAR (extrapolated) = 26.5 W/kg

SAR(1 g) = 13.4 W/kg; SAR(10 g) = 6.21 W/kg

Smallest distance from peaks to all points 3 dB below = 9 mm

Ratio of SAR at M2 to SAR at M1 = 50.6%

Maximum value of SAR (measured) = 21.9 W/kg




0 dB = 21.9 W/kg = 13.40 dBW/kg

Certificate No: D2450V2-715_Dec23



Impedance Measurement Plot for Head TSL





DASY5 Validation Report for Body TSL

Date: 06.12.2023

Test Laboratory: SPEAG, Zurich, Switzerland

DUT: Dipole 2450 MHz; Type: D2450V2; Serial: D2450V2 - SN:715

Communication System: UID 0 - CW; Frequency: 2450 MHz

Medium parameters used: f = 2450 MHz; $\sigma = 2.01$ S/m; $\epsilon_r = 53$; $\rho = 1000$ kg/m³

Phantom section: Flat Section

Measurement Standard: DASY5 (IEEE/IEC/ANSI C63.19-2011)

DASY52 Configuration:

Probe: EX3DV4 - SN7349; ConvF(8.12, 8.12, 8.12) @ 2450 MHz; Calibrated: 03.11.2023

Sensor-Surface: 1.4mm (Mechanical Surface Detection)

Electronics: DAE4 Sn601; Calibrated: 03.10.2023

Phantom: Flat Phantom 5.0 (back); Type: QD 000 P50 AA; Serial: 1002

DASY52 52.10.4(1535); SEMCAD X 14.6.14(7501)

Dipole Calibration for Body Tissue/Pin=250 mW, d=10mm/Zoom Scan (7x7x7)/Cube 0:

Measurement grid: dx=5mm, dy=5mm, dz=5mm

Reference Value = 107.3 V/m; Power Drift = 0.08 dB


Peak SAR (extrapolated) = 23.3 W/kg

SAR(1 g) = 12.5 W/kg; SAR(10 g) = 5.93 W/kg

Smallest distance from peaks to all points 3 dB below = 8.9 mm

Ratio of SAR at M2 to SAR at M1 = 54.6%


Maximum value of SAR (measured) = 20.0 W/kg



0 dB = 20.0 W/kg = 13.01 dBW/kg



Impedance Measurement Plot for Body TSL



Certificate No: D2450V2-715_Dec23



Calibration Laboratory of Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland





S Schweizerischer Kalibrierdienst
C Service suisse d'étalonnage
Servizio svizzero di taratura
Swiss Calibration Service

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA

Multilateral Agreement for the recognition of calibration certificates

Client TüV SÜD

Certificate No. D6.5GHzV2-1071 Jul24

Fareham, United Kingdom

CALIBRATION CERTIFICATE Object D6.5GHzV2 - SN:1071 Calibration procedure(s) QA CAL-22.v7 Calibration Procedure for SAR Validation Sources between 3-10 GHz Calibration date: July 04, 2024 This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI), The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate. All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3) C and humidity < 70%. Calibration Equipment used (M&TE critical for calibration) Primary Standards 10# Cal Date (Certificate No.) Scheduled Calibration Power sensor R&S NRP33T SN: 100967 28-Mar-24 (No. 217-04038) Mar-25 Reference 20 dB Attenuator SN: BH9394 (20k) 26-Mar-24 (No. 217-04046) Mar-25 Mismatch combination SN: 84224 / 360D 28-Mar-24 (No. 217-04050) Mar-25 Reference Probe EX3DV4 SN: 7405 01-Jul-24 (No. EX3-7405_Jul24) Jul-25 DAE4 SN: 908 27-Mar-24 (No. DAE4-908_Mar24) Mar-25 Secondary Standards ID# Check Date (in house) Scheduled Check RF generator Anapico APSIN20G SN: 827 18-Dec-18 (in house check Jan-24) In house check: Jan-25 Power sensor NRP-Z23 SN: 100169 10-Jan-19 (in house check Jan-24) In house check: Jan-25 Power sensor NRP-18T SN: 100950 28-Sep-22 (in house check Jan-24) In house check: Jan-25 Network Analyzer Keysight E5063A SN:MY54504221 31-Oct-19 (in house check Oct-22) In house check: Oct-25 Name Function Calibrated by: Aldonia Georgiadou Laboratory Technician Approved by: Sven Kühn Technical Manager Issued: July 8, 2024 This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: D6.5GHzV2-1071_Jul24

Page 1 of 6



Calibration Laboratory of Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland





Schweizerischer Kalibrierdienst Service suisse d'étalonnage Servizio svizzero di taratura Swiss Calibration Service

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA

Multilateral Agreement for the recognition of calibration certificates

Glossary:

TSL

tissue simulating liquid

ConvF N/A sensitivity in TSL / NORM x,y,z not applicable or not measured

Calibration is Performed According to the Following Standards:

a) IEC/IEEE 62209-1528, "Measurement Procedure For The Assessment Of Specific Absorption Rate Of Human Exposure To Radio Frequency Fields From Hand-Held And Body-Worn Wireless Communication Devices - Part 1528: Human Models, Instrumentation And Procedures (Frequency Range Of 4 MHz To 10 GHz)", October 2020.

Additional Documentation:

b) DASY System Handbook

Methods Applied and Interpretation of Parameters:

- Measurement Conditions: Further details are available from the Validation Report at the end of the
 certificate. All figures stated in the certificate are valid at the frequency indicated.
- Antenna Parameters with TSL: The dipole is mounted with the spacer to position its feed point
 exactly below the center marking of the flat phantom section, with the arms oriented parallel to the
 body axis.
- Feed Point Impedance and Return Loss: These parameters are measured with the dipole positioned under the liquid filled phantom. The Return Loss ensures low reflected power. No uncertainty required.
- SAR measured: SAR measured at the stated antenna input power.
- SAR normalized: SAR as measured, normalized to an input power of 1 W at the antenna connector.
- SAR for nominal TSL parameters: The measured TSL parameters are used to calculate the nominal SAR result.
- The absorbed power density (APD): The absorbed power density is evaluated according to Samaras T, Christ A, Kuster N, "Compliance assessment of the epithelial or absorbed power density above 6 GHz using SAR measurement systems", Bioelectromagnetics, 2021 (submitted). The additional evaluation uncertainty of 0.55 dB (rectangular distribution) is considered.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Certificate No: D6.5GHzV2-1071_Jul24

Page 2 of 6



Measurement Conditions

DASY system configuration, as far as not given on page 1.

DASY Version	DASY6	V16.2
Extrapolation	Advanced Extrapolation	
Phantom	Modular Flat Phantom	
Distance Dipole Center - TSL	5 mm	with Spacer
Zoom Scan Resolution	dx, dy = 3.4 mm, dz = 1.4 mm	Graded Ratio = 1.4 (Z direction)
Frequency	6500 MHz ± 1 MHz	

Head TSL parameters

The following parameters and calculations were applied.

	Temperature	Permittivity	Conductivity
Nominal Head TSL parameters	22.0 °C	34.5	6.07 mho/m
Measured Head TSL parameters	(22.0 ± 0.2) °C	35.8 ± 6 %	6.26 mho/m ± 6 %
Head TSL temperature change during test	< 0.5 °C		

SAR result with Head TSL

SAR averaged over 1 cm ³ (1 g) of Head TSL	Condition	
SAR measured	100 mW input power	29.5 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	297 W/kg ± 24.7 % (k=2)

SAR averaged over 8 cm ³ (8 g) of Head TSL	Condition	
SAR measured	100 mW input power	6.57 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	66.3 W/kg ± 24.4 % (k=2)

SAR averaged over 10 cm ³ (10 g) of Head TSL	condition	
SAR measured	100 mW input power	5.37 W/kg
SAR for nominal Head TSL parameters	normalized to 1W	54.2 W/kg ± 24.4 % (k=2)



Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters with Head TSL

Impedance, transformed to feed point	49.5 Ω - 1.1 jΩ
Return Loss	- 38.4 dB

APD (Absorbed Power Density)

APD averaged over 1 cm ²	Condition	
APD measured	100 mW Input power	297 W/m²
APD measured	normalized to 1W	2970 W/m² ± 29.2 % (k=2)

APD averaged over 4 cm ²	condition	
APD measured	100 mW input power	131 W/m²
APD measured	normalized to 1W	1310 W/m ² ± 28.9 % (k=2)

^{*}The reported APD values have been derived using the psSAR1g and psSAR8g.

General Antenna Parameters and Design

After long term use with 100W radiated power, only a slight warming of the dipole near the feedpoint can be measured.

The dipole is made of standard semirigid coaxial cable. The center conductor of the feeding line is directly connected to the second arm of the dipole. The antenna is therefore short-circuited for DC-signals. On some of the dipoles, small end caps are added to the dipole arms in order to improve matching when loaded according to the position as explained in the "Measurement Conditions" paragraph. The SAR data are not affected by this change. The overall dipole length is still according to the Standard.

No excessive force must be applied to the dipole arms, because they might bend or the soldered connections near the feedpoint may be damaged.

Additional EUT Data

	1
Manufactured by	SPEAG
	t and the second



Zoom Scan 2024-07-04, 13:30

No correction

29.5 6.57 5.37 0.03 Disabled

54.3

4.8

DASY6 Validation Report for Head TSL

Measurement Report for D6.5GHz-1071, UID 0 -, Channel 6500 (6500.0MHz)

Device under Test Properties

Name, Manufacturer Dimensions [mm] IMEI **DUT Type** D6.5GHz $16.0 \times 6.0 \times 300.0$ SN: 1071

Exposure Conditions

Phantom Position, Test Band Group, Frequency Conversion TSL Cond. T5L Section, TSL Distance UID [MHz] Factor [S/m] Permittivity [mm] Flat, HSL 5.00 Band CW, 6500 5.42 6.26 35.8

Hardware Setup

Phantom TSL **Probe, Calibration Date** DAE, Calibration Date MFP V8.0 Center - 1182 HBBL600-10000V6 EX3DV4 - SN7405, 2024-07-01 DAE4 Sn908, 2024-03-27

Scan Setup		Measurement Results
	Zoom Scan	
Grid Extents [mm]	22.0 x 22.0 x 22.0	Date
Grid Steps [mm]	3.4 x 3.4 x 1.4	psSAR1g [W/Kg]
Sensor Surface [mm]	1.4	psSAR8g [W/Kg]
Graded Grid	Yes	psSAR10g [W/Kg]
Grading Ratio	1.4	Power Drift [dB]
MAIA	N/A	Power Scaling
Surface Detection	VMS + 6p	Scaling Factor [dB]
Scan Method	Measured	TSL Correction
		M2/M1 [%]




Dist 3dB Peak [mm]

Certificate No: D6.5GHzV2-1071_Jul24



Impedance Measurement Plot for Head TSL



Certificate No: D6.5GHzV2-1071_Jul24

Page 6 of 6



Calibration Laboratory of Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland





Schweizerischer Kalibrierdienst S Service suisse d'étalonnage C Servizio svizzero di taratura Swiss Calibration Service

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS) The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Client

TÜV SÜD

Fareham, United Kingdom

Certificate No. 5G-Veri10-1053 Oct24

Scheduled Calibration

In house check: Sep-26

Aug-25

CALIBRATION CERTIFICATE

5G Verification Source 10 GHz - SN: 1053 Object

QA CAL-45.v5 Calibration procedure(s)

Calibration procedure for sources in air above 6 GHz

Calibration date: October 10, 2024

This calibration certificate documents the traceability to national standards, which realize the physical units of measurements (SI). The measurements and the uncertainties with confidence probability are given on the following pages and are part of the certificate.

All calibrations have been conducted in the closed laboratory facility: environment temperature (22 ± 3)°C and humidity < 70%.

Calibration Equipment used (M&TE critical for calibration)

Network Analyzer Keysight E5063A SN: MY54504221

ID#

SN: 9374

DAE4ip	SN: 1602	08-Nov-23 (No. DAE4ip-1602_Nov23)	Nov-24
Secondary Standards	ID#	Check Date (in house)	Scheduled Check
RF generator R&S SMF100A	SN: 100184	29-Nov-23 (in house check Nov-23)	In house check: Nov-24
Power sensor R&S NRP18S-10	SN: 101258	29-Nov-23 (in house check Nov-23)	In house check: Nov-24

Cal Date (Certificate No.)

28-Aug-24 (No. EUmm-9374 Aug24)

31-Oct-19 (in house check Sep-24)

Calibrated by:

Primary Standards

Reference Probe EUmmWV3

Name Joanna Lleshal

Function Laboratory Technician

Approved by:

Sven Kühn

Technical Manager

Issued: October 11, 2024

This calibration certificate shall not be reproduced except in full without written approval of the laboratory.

Certificate No: 5G-Veri10-1053_Oct24



Calibration Laboratory of Schmid & Partner Engineering AG Zeughausstrasse 43, 8004 Zurich, Switzerland





C

Schweizerischer Kalibrierdienst Service suisse d'étalonnage Servizio svizzero di taratura Swiss Calibration Service

Accreditation No.: SCS 0108

Accredited by the Swiss Accreditation Service (SAS)

The Swiss Accreditation Service is one of the signatories to the EA Multilateral Agreement for the recognition of calibration certificates

Glossary

CW

Continuous wave

Calibration is Performed According to the Following Standards

- Internal procedure QA CAL-45, Calibration procedure for sources in air above 6 GHz.
- IEC/IEEE 63195-1, "Assessment of power density of human exposure to radio frequency fields from wireless devices in close proximity to the head and body (frequency range of 6 GHz to 300 GHz)", May 2022

Methods Applied and Interpretation of Parameters

- Coordinate System: z-axis in the waveguide horn boresight, x-axis is in the direction of the E-field, y-axis normal to the others in the field scanning plane parallel to the horn flare and horn flange.
- Measurement Conditions: (1) 10 GHz: The radiated power is the forward power to the horn
 antenna minus ohmic and mismatch loss. The forward power is measured prior and after
 the measurement with a power sensor. During the measurements, the horn is directly
 connected to the cable and the antenna ohmic and mismatch losses are determined by farfield measurements. (2) 30, 45, 60 and 90 GHz: The verification sources are switched on for
 at least 30 minutes. Absorbers are used around the probe cub and at the ceiling to minimize
 reflections.
- Horn Positioning: The waveguide horn is mounted vertically on the flange of the waveguide source to allow vertical positioning of the EUmmW probe during the scan. The plane is parallel to the phantom surface. Probe distance is verified using mechanical gauges positioned on the flare of the horn.
- E- field distribution: E field is measured in two x-y-plane (10mm, 10mm + λ/4) with a vectorial E-field probe. The E-field value stated as calibration value represents the E-fieldmaxima and the averaged (1cm² and 4cm²) power density values at 10mm in front of the horn.
- Field polarization: Above the open horn, linear polarization of the field is expected. This is verified graphically in the field representation.

Calibrated Quantity

 Local peak E-field (V/m) and average of peak spatial components of the poynting vector (W/m²) averaged over the surface area of 1 cm² and 4cm² at the nominal operational frequency of the verification source. Both square and circular averaging results are listed.

The reported uncertainty of measurement is stated as the standard uncertainty of measurement multiplied by the coverage factor k=2, which for a normal distribution corresponds to a coverage probability of approximately 95%.

Certificate No: 5G-Veri10-1053_Oct24

Page 2 of 8



Measurement Conditions

DASY system configuration, as far as not given on page 1

DASY Version	DASY8 Module mmWave	V3.2
Phantom	5G Phantom	
Distance Horn Aperture - plane	10 mm	
Number of measured planes	2 (10mm, 10mm + λ/4)	7.50-7.00
Frequency	10 GHz ± 10 MHz	

Calibration Parameters, 10 GHz

Circular Averaging

Distance Horn Aperture to Measured Plane	Prad¹ (mW)	Max E-field (V/m)	Uncertainty (k = 2)	Avg (psPOn+, ps	er Density PDtot+, psPDmod+) /m²)	Uncertainty (k = 2)
				1 cm ²	4 cm ²	
10 mm	93.3	153	1.27 dB	61.1	57.2	1.28 dB

Distance Horn Aperture to Measured Plane	Prad¹ (mW)	Max E-field (V/m)	Uncertainty (k = 2)	psPDn+, psPDt	Density ot+, psPDmod+ /m²)	Uncertainty (k = 2)
				1 cm ²	4 cm ²	
10 mm	93.3	153	1.27 dB	60.8, 61.1, 61.3	56.9, 57.2, 57.4	1.28 dB

Square Averaging

Distance Horn Aperture to Measured Plane	Prad¹ (mW)	Max E-field (V/m)	Uncertainty (k = 2)	Avg (psPDn+, psl	er Density PDtot+, psP0mod+) /m²)	Uncertainty (k = 2)
				1 cm ²	4 cm ²	
10 mm	93.3	153	1.27 dB	61.0	57.0	1.28 dB

Distance Horn Aperture to Measured Plane	Prad¹ (mW)	Max E-field (V/m)	Uncertainty (k = 2)	psPDn+, psPDt	Density ot+, psPDmod+ /m²)	Uncertainty (k = 2)
			0%	1 cm ²	4 cm ²	
10 mm	93.3	153	1.27 dB	60.8, 61.0, 61.3	56.7, 57.0, 57.3	1.28 dB

Max Power Density

Distance Horn Aperture to Measured Plane	Prad¹ (mW)	Max E-field (V/m)	Uncertainty (k = 2)	Max Power Density Sn, Stot, Stot (W/m²)	Uncertainty (k = 2)
10 mm	93.3	153	1.27 dB	62.4, 62.6, 62.8	1.28 dB

Certificate No: 5G-Veri10-1053_Oct24

Page 3 of 8

Assessed ohmic and mismatch loss plus numerical offset: 0.30 dB




Appendix (Additional assessments outside the scope of SCS 0108)

Antenna Parameters

Impedance, transformed to feed point	$55.4 \Omega + 2.4 j\Omega$
Return Loss	- 25.0 dB

Impedance Measurement Plot





Measurement Report for 5G Verification Source 10 GHz, UID 0 -, Channel 10000 (10000.0MHz)

Validation band

Device under Test Properties

Dimensions [mm] Name, Manufacturer 100.0 x 100.0 x 172.0 5G Verification Source 10 GHz

10.0 mm

IMEI SN; 1053 **DUT Type**

Exposure Conditions

Phantom Section

5G+

Position, Test Distance Band [mm]

Group, CW

10.0

Frequency [MHz], Channel Number 10000.0, 10000

Conversion Factor

5G Scan

60.8

61.1

62.4

62.6

62.8

153 -0.00

1.0

Hardware Setup

Phantom mmWave Phantom - 1002 Medium Air

Probe, Calibration Date EUmmWV3 - SN9374_F1-55GHz, 2024-08-28

DAE, Calibration Date DAE4ip Sn1602, 2023-11-08

Scan Setup

5G Scan Sensor Surface [mm] MAIA MAIA not used **Measurement Results**

2024-10-10, 16:38 Avg. Area (cm²) Avg. Type psPDn+ [W/m²] Circular Averaging psPDtot+ (W/m2) psPDmod+ [W/m²] Max(Sn) [W/m²] Max(Stot) [W/m²] Max(|Stot|) [W/m²] E_{max} [V/m] Power Drift (dB)





Measurement Report for 5G Verification Source 10 GHz, UID 0 -, Channel 10000 (10000.0MHz)

Device under Test Properties

 Name, Manufacturer
 Dimensions [mm]
 IMEI
 DUT Type

 5G Verification Source 10 GHz
 100.0 x 100.0 x 172.0
 SN: 1053

Exposure Conditions

Phantom Section Position, Test Distance [mm] Band Group, Frequency [MHz], Conversion Factor Channel Number

5G 10.0 mm Validation band CW 10000.0, 1.0

Hardware Setup

 Phantom
 Medium
 Probe, Calibration Date
 DAE, Calibration Date


 mmWave Phantom 1002
 Air
 EUmmW93 - SN9374_F1-55GHz, 2023-11-08
 DAE4lp 5n1602, 2023-11-08

Scan Setup

5G Scan SG Scan Sensor Surface [mm] MAIA 10.0 Date 2024-10-10, 16:38 MAIA not used Avg. Area [cm²] Avg. Type psPDn+ [W/m²] Circular Averaging 56.9 psPDtot+ [W/m²] psPDmod+ [W/m²] 57.2 57.4 62.4 Max(Sn) [W/m²] Max(Stot) [W/m²] Max(|Stot|) [W/m²] E_{max} [V/m] 62.8 153

Measurement Results

Power Drift [dB]



Certificate No: 5G-Veri10-1053_Oct24



Measurement Report for 5G Verification Source 10 GHz, UID 0 -, Channel 10000 (10000.0MHz)

Device under Test Properties

menter ament tener trabetti			
Name, Manufacturer	Dimensions [mm]	IMEI	DUT Type
5G Verification Source 10 GHz	100.0 x 100.0 x 172.0	SN: 1053	

Exposure Conditions

Phantom Section	Position, Test Distance [mm]	Band	Group,	Frequency [MHz], Channel Number	Conversion Factor
5G -	10.0 mm	Validation band	CW	10000.0,	1.0

Hardware Setup

Phantom	Medium	Probe, Calibration Date	DAE, Calibration Date
mmWave Phantom - 1002	Air	EUmmWV3 - SN9374_F1-55GHz,	DAE4ip Sn1602,
		2024.08.28	3033.11.08

Scan Setup

	5G Scan		5G Scan
Sensor Surface (mm)	10.0	Date	2024-10-10, 15:38
MAIA	MAIA not used	Avg. Area [cm²]	1.00
		Avg. Type	Square Averaging
		psPDn+ (W/m²)	60.8
		psPDtot+ [W/m²]	61.0
		psPDmod+ [W/m²]	61.3
		Max(5n) [W/m ²]	62.4
		Max(Stot) [W/m²]	62.6
		Max(Stot)[W/m²]	62.8
		Enex (V/m)	153
		Power Drift [dB]	-0.00





Measurement Report for 5G Verification Source 10 GHz, UID 0 -, Channel 10000 (10000.0MHz)

 Device under Test Properties

 Name, Manufacturer
 Dimensions [mm]
 IMEI
 DUT Type

 5G Verification Source 10 GHz
 100.0 x 100.0 x 172.0
 SN: 1053

Exposure Conditions

Phantom Section Position, Test Distance Eand Group, Frequency [MHz], Conversion Factor Channel Number

5G- 10.0 mm Validation band CW 10000.0, 1.0

Hardware Setup

| Probe, Calibration Date | DAE, Calibration Date | DA


Scan Setup

Date
Avg. Area [cm²]
Avg. Type
psPDn+ {W/m²]
psPDtot+ [W/m²]
psPDmod+ [W/m²]
Max[Sn] [W/m²]
Max[Stot] [W/m²]
Max[Stot] [W/m²]
Fau- [V/m]
Power Drift [dB]

Measurement Results

2024-10-10, 16:38 4.00 Square Averaging 56:7 57.0 57.3 62.4 62.6 62.8 153

5G Scan



Certificate No: 5G-Veri10-1053_Oct24

Page 8 of 8



ANNEX C

TEST RESULTS



Measurement Report for A3240, BACK, ISM 2.4 GHz Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 0 (2402.0 MHz)

Model, Manufacturer	Dimensions [mm]	IMEI	DUT Type
A3240,	302.0 x 215.0 x 14.0		Laptop

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 0.00	ISM 2.4 GHz Band	Bluetooth, 10032-CAA	2402.0, 0	7.41	1.78	40.6

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V8.0 (20deg	HBBL-600-10000 DAK 3.5 Head 20.92 deg.C 2024-Oct-30 SYS6 B6.prn, 2024-Oct-30	EX3DV4 - SN7809,	DAE4ip Sn1789,
probe tilt) - 2203		2024-05-13	2024-05-03

Scans Setup

	Area Scan	Zoom Scan
Grid Extents [mm]	140.0 x 200.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4
Graded Grid	n/a	Yes
Grading Ratio	n/a	1.5
MAIA	Υ	N/A
Surface Detection	VMS + 6p	VMS + 6p
Scan Method	Measured	Measured

	Area Scan	Zoom Scan
Date	2024-10-30, 18:31	2024-10-30, 18:38
psSAR1g [W/Kg]	0.195	0.205
psSAR10g [W/Kg]	0.086	0.081
Power Drift [dB]	0.02	0.02
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	Positive only	Positive only
M2/M1 [%]		70.7
Dist 3dB Peak [mm]		6.5






Figure C.01: SAR testing results for the A3240 at 2402 MHz Core 0



Measurement Report for A3240, BACK, ISM 2.4 GHz Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 78 (2480.0 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	IMEI	DUT Type
A3240,	302.0 x 215.0 x 14.0		Laptop

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, HSL	BACK, 0.00	ISM 2.4 GHz Band	Bluetooth, 10032-CAA	2480.0, 78	7.41	1.84	40.5

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V8.0 (20deg	HBBL-600-10000 DAK 3.5 Head 20.92 deg.C 2024-Oct-30 SYS6 B6.prn, 2024-Oct-30	EX3DV4 - SN7809,	DAE4ip Sn1789,
probe tilt) - 2203		2024-05-13	2024-05-03

Scans Setup

ans Setup		
	Area Scan	Zoom Scan
Grid Extents [mm]	140.0 x 200.0	30.0 x 30.0 x 30.0
Grid Steps [mm]	10.0 x 10.0	5.0 x 5.0 x 1.5
Sensor Surface [mm]	3.0	1.4
Graded Grid	n/a	Yes
Grading Ratio	n/a	1.5
MAIA	Υ	N/A
Surface Detection	VMS + 6p	VMS + 6p
Scan Method	Measured	Measured

	Area Scan	Zoom Scan
Date	2024-10-30, 19:53	2024-10-30, 20:01
psSAR1g [W/Kg]	0.204	0.226
psSAR10g [W/Kg]	0.094	0.092
Power Drift [dB]	0.02	0.01
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	Positive only	Positive only
M2/M1 [%]		72.3
Dist 3dB Peak [mm]		7.0






Figure C.02: SAR testing results for the A3240 at 2480 MHz Core 1



Measurement Report for A3240, BACK, Custom Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 5200000 (5200.000 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	IMEI	DUT Type
A3240,	302.0 x 215.0 x 14.0		Laptop

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, Head Simulating Liquid	BACK, 0.00	Custom Band	CW, 10032- CAA	5200.000, 5200000	5.18	4.41	34.9

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V8.0 (20deg probe tilt) - 2202	HBBL-600-10000 DAK 3.5 Head 21.23 deg.C 2024-Oct-30 SYS5 B5, 2024-10-30	EX3DV4 - SN7805, 2024-02-14	DAE4ip Sn1785, 2024-02-13

Scans Setup

ns oetup			
	Area Scan	Zoom Scan	
Grid Extents [mm]	140.0 x 200.0	22.0 x 22.0 x 22.0	
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4	
Sensor Surface [mm]	3.0	1.4	
Graded Grid	N/A	Yes	
Grading Ratio	N/A	1.4	
MAIA	Υ	Υ	
Surface Detection	VMS + 6p	VMS + 6p	
Scan Method	Measured	Measured	

	Area Scan	Zoom Scan
Date	2024-10-31, 04:58	2024-10-31, 05:09
psSAR1g [W/Kg]	0.191	0.211
psSAR10g [W/Kg]	0.072	0.073
Power Drift [dB]	-0.03	-0.19
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	Positive only	Positive only
M2/M1 [%]		59.7
Dist 3dB Peak [mm]		9.2






Figure C.03: SAR testing results for the A3240 at 5200 MHz Core 0



Measurement Report for A3240, BACK, Custom Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 5250000 (5250.000 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	IMEI	DUT Type
A3240,	302.0 x 215.0 x 14.0		Laptop

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, Head Simulating Liquid	BACK, 0.00	Custom Band	CW, 10032- CAA	5250.000, 5250000	5.18	4.47	34.8

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V8.0 (20deg probe tilt) - 2202	HBBL-600-10000 DAK 3.5 Head 21.23 deg.C 2024-Oct-30 SYS5 B5, 2024-10-30	EX3DV4 - SN7805, 2024-02-14	DAE4ip Sn1785, 2024-02-13

Scans Setup

no octup			
	Area Scan	Zoom Scan	
Grid Extents [mm]	140.0 x 200.0	22.0 x 22.0 x 22.0	
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4	
Sensor Surface [mm]	3.0	1.4	
Graded Grid	N/A	Yes	
Grading Ratio	N/A	1.4	
MAIA	Υ	Y	
Surface Detection	VMS + 6p	VMS + 6p	
Scan Method	Measured	Measured	

	Area Scan	Zoom Scan
Date	2024-10-31, 06:23	2024-10-31, 06:32
psSAR1g [W/Kg]	0.182	0.196
psSAR10g [W/Kg]	0.073	0.068
Power Drift [dB]	-0.02	-0.01
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	Positive only	Positive only
M2/M1 [%]		61.3
Dist 3dB Peak [mm]		8.0






Figure C.04: SAR testing results for the A3240 at 5250 MHz Core 1



Measurement Report for A3240, BACK, Custom Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 5788000 (5788.000 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	IMEI	DUT Type
A3240,	302.0 x 215.0 x 14.0		Laptop

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, Head Simulating Liquid	BACK, 0.00	Custom Band	CW, 10032- CAA	5788.000, 5788000	4.63	5.05	33.9

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V8.0 (20deg probe tilt) - 2202	HBBL-600-10000 DAK 3.5 Head 21.23 deg.C 2024-Oct-30 SYS5 B5, 2024-10-30	EX3DV4 - SN7805, 2024-02-14	DAE4ip Sn1785, 2024-02-13

Scans Setup

ns oetup			
	Area Scan	Zoom Scan	
Grid Extents [mm]	140.0 x 200.0	22.0 x 22.0 x 22.0	
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4	
Sensor Surface [mm]	3.0	1.4	
Graded Grid	N/A	Yes	
Grading Ratio	N/A	1.4	
MAIA	Υ	Υ	
Surface Detection	VMS + 6p	VMS + 6p	
Scan Method	Measured	Measured	

	Area Scan	Zoom Scan
Date	2024-10-30, 22:40	2024-10-30, 22:47
psSAR1g [W/Kg]	0.321	0.376
psSAR10g [W/Kg]	0.111	0.109
Power Drift [dB]	0.19	0.21
Power Scaling	Disabled	Disabled
Scaling Factor [dB]		
TSL Correction	Positive only	Positive only
M2/M1 [%]		56.5
Dist 3dB Peak [mm]		6.9






Figure C.05: SAR testing results for the A3240 at 5788 MHz Core 0



Measurement Report for A3240, BACK, Custom Band, IEEE 802.15.1 Bluetooth (GFSK, DH5), Channel 5850000 (5850.000 MHz)

Device Under Test Properties

Model, Manufacturer	Dimensions [mm]	IMEI	DUT Type
A3240,	302.0 x 215.0 x 14.0		Laptop

Exposure Conditions

Phantom Section, TSL	Position, Test Distance [mm]	Band	Group, UID	Frequency [MHz], Channel Number	Conversion Factor	TSL Conductivity [S/m]	TSL Permittivity
Flat, Head Simulating Liquid	BACK, 0.00	Custom Band	CW, 10032- CAA	5850.000, 5850000	4.63	5.12	33.8

Hardware Setup

Phantom	TSL, Measured Date	Probe, Calibration Date	DAE, Calibration Date
ELI V8.0 (20deg probe tilt) - 2202	HBBL-600-10000 DAK 3.5 Head 21.23 deg.C 2024-Oct-30 SYS5 B5, 2024-10-30	EX3DV4 - SN7805, 2024-02-14	DAE4ip Sn1785, 2024-02-13

Scans Setup

ino octup			
	Area Scan	Zoom Scan	
Grid Extents [mm]	140.0 x 200.0	22.0 x 22.0 x 22.0	
Grid Steps [mm]	10.0 x 10.0	4.0 x 4.0 x 1.4	
Sensor Surface [mm]	3.0	1.4	
Graded Grid	N/A	Yes	
Grading Ratio	N/A	1.4	
MAIA	Y	Y	
Surface Detection	VMS + 6p	VMS + 6p	
Scan Method	Measured	Measured	

asurement results			
	Area Scan	Zoom Scan	
Date	2024-10-31, 04:11	2024-10-31, 04:22	
psSAR1g [W/Kg]	0.193	0.212	
psSAR10g [W/Kg]	0.066	0.062	
Power Drift [dB]	0.31	0.20	
Power Scaling	Disabled	Disabled	
Scaling Factor [dB]			
TSL Correction	Positive only	Positive only	
M2/M1 [%]		57.7	
Dist 3dB Peak [mm]		7.3	