

SGS-CSTC Standards Technical Services (Suzhou) Co., Ltd

 Report No.:
 SUCR241100048001

 Rev.:
 01

Appendix A

Detailed System Check Results

1. System Performance Check
System Performance Check 835 MHz Head
System Performance Check 1750 MHz Head
System Performance Check 1950 MHz Head
System Performance Check 2450 MHz Head
System Performance Check 2600 MHz Head

This document is issued by the Company subject to its General Conditions of Service printed overleaf, available on request or accessible at http://www.sgs.com/en/Terms-and-Conditions.aspx and, for electronic format documents, subject to Terms and Conditions for Electronic Documents at http://www.sgs.com/en/Terms-and-Conditions/Terms-e-Document.aspx. Attention is drawn to the limitation of liability, indemrification and jurisdiction issues defined therein. Any holder of this document is advised that information contained hereon reflects the Company's findings at the time of its intervention only and within the limits of Client's instructions, if any. The Company's sole responsibility is to its Client and this document does not exonerate parties to a transaction from exercising all their rights and obligations under the transaction documents. This document cannot be reproduced except in full, without prior written approval of the Company. Any unauthorized alteration, forgery or falsification of the content or appearance of this document is unlawful and offenders may be prosecuted to the fullest extent of the law. Unless otherwise stated the results shown in this test report refer only to the sample(s) tested and such sample(s) are retained for 30 days only.

Attention: To check the authenticity of testing / inspection report & certificate, please contact us at telephone: (86-755) 8307 1443, or email: CN.Doccheck@sgs.com

SGS-CSTC Standards Technical Services (Suzhou) Co., Ltd. Wireless Laboratory

South of No. 6 Plant, No. 1, Runsheng Road, Suzhou Industrial Park, Suzhou Area, China (Jiangsu) Pilot Free Trade Zone 215000 t (86-512) 62992980 www.sgsgroup.com.cn

System Performance Check 835 MHz

DUT: D835V2; Type: Dipole; Serial: 4d161

Communication System: UID 0, CW (0); Frequency: 835 MHz; Duty Cycle: 1:1

Medium: HSL835;Medium parameters used: f = 835 MHz; σ = 0.907 S/m; ϵ_r = 42.025; ρ = 1000 kg/m³ Phantom section: Flat Section

DASY 5 Configuration:


- Probe: EX3DV4 SN3793; ConvF(8.88, 8.88, 8.88); Calibrated: 2024/03/04
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1245; Calibrated: 2024/06/05
- Phantom: SAM 7; Type: SAM; Serial: 1702
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Body/d=15mm, Pin=250mW/Area Scan (7x13x1): Measurement grid: dx=15mm,

dy=15mm Maximum value of SAR (measured) = 3.09 W/kg

Body/d=15mm, Pin=250mW/Zoom Scan (7x7x7) (5x5x7)/Cube 0: Measurement grid:

dx=8mm, dy=8mm, dz=5mm Reference Value = 55.21 V/m; Power Drift = 0.07 dB Peak SAR (extrapolated) = 4.20 W/kg SAR(1 g) = 2.57 W/kg; SAR(10 g) = 1.64 W/kg Maximum value of SAR (measured) = 3.64 W/kg



System Performance Check 1750 MHz

DUT: D1750V2; Type: Dipole; Serial: 1038

Communication System: UID 0, CW (0); Frequency: 1750 MHz; Duty Cycle: 1:1

Medium: HSL1750;Medium parameters used: f = 1750 MHz; $\sigma = 1.325$ S/m; $\epsilon_r = 38.441$; $\rho = 1000$ kg/m³ Phantom section: Flat Section

DASY 5 Configuration:


- Probe: EX3DV4 SN3793; ConvF(7.86, 7.86, 7.86); Calibrated: 2024/03/04
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1245; Calibrated: 2024/06/05
- Phantom: SAM 7; Type: SAM; Serial: 1702
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Body/d=10mm, Pin=250mW/Area Scan (7x13x1): Measurement grid: dx=15mm,

dy=15mm Maximum value of SAR (measured) = 9.07 W/kg

Body/d=10mm, Pin=250mW/Zoom Scan (7x7x7) (5x5x7)/Cube 0: Measurement grid:

dx=8mm, dy=8mm, dz=5mm Reference Value = 76.09 V/m; Power Drift = 0.03 dB Peak SAR (extrapolated) = 13.5 W/kg SAR(1 g) = 8.9 W/kg; SAR(10 g) = 4.54 W/kg Maximum value of SAR (measured) = 11.7 W/kg



System Performance Check 1950 MHz

DUT: D1950V3; Type: Dipole; Serial: 1218

Communication System: UID 0, CW (0); Frequency: 1950 MHz; Duty Cycle: 1:1

Medium: HSL1950;Medium parameters used: f = 1950 MHz; $\sigma = 1.408$ S/m; $\epsilon_r = 38.645$; $\rho = 1000$ kg/m³ Phantom section: Flat Section

DASY 5 Configuration:


- Probe: EX3DV4 SN3793; ConvF(7.57, 7.57, 7.57); Calibrated: 2024/03/04
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1245; Calibrated: 2024/06/05
- Phantom: SAM 7; Type: SAM; Serial: 1702
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Body/d=10mm, Pin=250mW/Area Scan (7x11x1): Measurement grid: dx=15mm,

dy=15mm Maximum value of SAR (measured) = 11.9 W/kg

Body/d=10mm, Pin=250mW/Zoom Scan (7x7x7) (5x5x7)/Cube 0: Measurement grid:

dx=8mm, dy=8mm, dz=5mm Reference Value = 82.27 V/m; Power Drift = 0.05 dB Peak SAR (extrapolated) = 17.4 W/kg SAR(1 g) = 9.78 W/kg; SAR(10 g) = 5.18 W/kg Maximum value of SAR (measured) = 14.9 W/kg



System Performance Check 2450MHz

DUT: D2450V2; Type: Dipole; Serial: 922

Communication System: UID 0, CW; Frequency: 2450 MHz; Duty Cycle: 1:1

Medium: HSL2450;Medium parameters used: f = 2450 MHz; $\sigma = 1.819$ S/m; $\epsilon_r = 38.504$; $\rho = 1000$ kg/m³ Phantom section: Flat Section

DASY 5 Configuration:


- Probe: EX3DV4 SN3793; ConvF(7.18, 7.18, 7.18); Calibrated: 2024/03/04
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1245; Calibrated: 2024/06/05
- Phantom: SAM 7; Type: SAM; Serial: 1702
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Body/d=10mm, Pin=250mW/Area Scan (9x11x1): Measurement grid: dx=12mm,

dy=12mm Maximum value of SAR (measured) = 13.9 W/kg

Body/d=10mm, Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm,

dy=5mm, dz=5mm Reference Value = 74.42 V/m; Power Drift = 0.08 dB Peak SAR (extrapolated) = 21.7 W/kg SAR(1 g) = 12.2 W/kg; SAR(10 g) = 5.66 W/kgMaximum value of SAR (measured) = 18.0 W/kg



System Performance Check 2600MHz

DUT: D2600V2; Type: Dipole; Serial: 1187

Communication System: UID 0, CW (0); Frequency: 2600 MHz; Duty Cycle: 1:1

Medium: HSL2600;Medium parameters used: f = 2600 MHz; $\sigma = 2.026$ S/m; $\epsilon_r = 38.183$; $\rho = 1000$ kg/m³ Phantom section: Flat Section

DASY 5 Configuration:

- Probe: EX3DV4 SN3793; ConvF(7.18, 7.18, 7.18); Calibrated: 2024/03/04
- Sensor-Surface: 1.4mm (Mechanical Surface Detection)
- Electronics: DAE4 Sn1245; Calibrated: 2024/06/05
- Phantom: SAM 7; Type: SAM; Serial: 1702
- DASY52 52.10.4(1527); SEMCAD X 14.6.14(7483)

Body/d=10mm, Pin=250mW/Area Scan (9x11x1): Measurement grid: dx=12mm,

dy=12mm Maximum value of SAR (measured) = 18.0 W/kg

Body/d=10mm, Pin=250mW/Zoom Scan (7x7x7)/Cube 0: Measurement grid: dx=5mm,

dy=5mm, dz=5mm Reference Value = 79.55 V/m; Power Drift = 0.09 dB Peak SAR (extrapolated) = 25.8 W/kg SAR(1 g) = 13.3 W/kg; SAR(10 g) = 5.92 W/kg Maximum value of SAR (measured) = 21.2 W/kg

