



**F2 Labs**  
**16740 Peters Road**  
**Middlefield, Ohio 44062**  
**United States of America**  
**[www.f2labs.com](http://www.f2labs.com)**

## **CERTIFICATION TEST REPORT**

---

**Manufacturer:** **Structured Monitoring Products**  
**151 Innovation Way, Suite 210**  
**Elyria, Ohio 44035 USA**

**Applicant:** **Same as Above**

**Product Name:** **Heart Monitor (VetGuardian)**

**Product Description:** Heart rate and respiratory rate measurement device for animals.

**Operating Voltage/Freq.  
of EUT During Testing:** 12VDC from Host

**Model:** **SMPVG04**  
*\*Denotes actual model tested to add it to product family that includes models SMPVG02 Version 2.5 and SMPVG03.*

**FCC ID:** **2ARN8-SMPVG02**

**Testing Commenced:** 2023-12-18

**Testing Ended:** 2023-12-18

**Test Results:** **In Compliance**

The EUT complies with the EMC requirements when manufactured identically as the unit tested in this report, including any required modifications. Any changes to the design or build of this unit subsequent to this testing may deem it non-compliant.

**Standards:**

- **KDB447498**
- **FCC Part 1.1310**



**Evaluation Conducted by:**

Julius Chiller, Senior Wireless Project Engineer

**Report Reviewed by:**

Ken Littell, Vice President of Operations

F2 Labs  
26501 Ridge Road  
Damascus, MD 20872  
Ph 301.253.4500

F2 Labs  
16740 Peters Road  
Middlefield, OH 44062  
Ph 440.632.5541

F2 Labs  
8583 Zionsville Road  
Indianapolis, IN 46268  
Ph 317.610.0611

This test report may be reproduced in full; partial reproduction only may be made with the written consent of F2 Labs. The results in this report apply only to the equipment tested.



## TABLE OF CONTENTS

1	<a href="#"><u>ADMINISTRATIVE INFORMATION</u></a>
2	<a href="#"><u>SUMMARY OF TEST RESULTS/MODIFICATIONS</u></a>
3	<a href="#"><u>ENGINEERING STATEMENT</u></a>
4	<a href="#"><u>EUT INFORMATION AND DATA</u></a>
5	<a href="#"><u>RF EXPOSURE FOR DEVICE &gt;20cm FROM HUMAN</u></a>



## 1 ADMINISTRATIVE INFORMATION

### 1.1 Measurement Location:

F2 Labs in Middlefield, Ohio. Site description and attenuation data are on file with the FCC's Sampling and Measurement Branch at the FCC Laboratory in Columbia, MD.

### 1.2 Measurement Procedure:

All measurements were performed according to KDB558074.

### 1.4 Document History

Document Number	Description	Issue Date	Approved By
F2P27463-R1-C1A-04E	First Issue	2024-05-29	K. Littell



## 2 SUMMARY OF TEST RESULTS

Test Name	Standard(s)	Results
RF Exposure for Device >20cm from Human	KDB447498 FCC Part 1.1310	Complies

Modifications Made to the Equipment
None



### 3 ENGINEERING STATEMENT

This report has been prepared on behalf of Structured Monitoring Products, Inc. to provide documentation for the testing described herein. This equipment has been tested and found to comply with FCC Rule Part 1.1310 and KDB447498. The test results found in this test report relate only to the item(s) tested.



## 4 EUT INFORMATION AND DATA

### 4.1 Equipment Under Test:

Product: Heart Monitor (VetGuardian)

Model: SMPVG04\*

Serial No.: 1

Firmware: 2.5

Hardware: F

**FCC ID: 2ARN8-SMPVG02**

Contains FCC ID: 2ABCB-RPICM4

*\*Denotes actual model tested to add it to product family that includes models SMPVG02 Version 2.5 and SMPVG03.*

### 4.2 Trade Name:

Structured Monitoring Products

### 4.3 Power Supply:

12VDC from AC Supply

### 4.4 Applicable Rules:

- KDB447498
- FCC Part 1.1310

### 4.5 Antenna:

Integral Antenna of Radar Transmitter, 0dBi Gain

Wi-Fi Antenna for 2.4 GHz transmission, 3.5dBi Gain

Wi-Fi Antenna for 5 GHz transmission, 2.3dBi Gain

### 4.6 Accessories:

Shenzhen AC Adaptor J483-1203500UX

**5 RF EXPOSURE FOR DEVICE >20cm FROM HUMAN****5.1 Requirements: Distance used is 20cm****Limit:** 1mW/cm<sup>2</sup>**Formula used for result:**  $\frac{E.I.R.P.}{4 \pi R^2}$ **Results:** E.I.R.P. of Radar transmission = 0.0143mW

$$P(dBm) = E(dBuVm) + 20 \log(d) - G - 104.77$$

$$76.8 + 9.542425 - 0 - 104.77 = -18.44$$

0.0143mW at the 5870 MHz single channel.

$$\frac{0.0143mW}{4 \pi R^2} = \frac{0.0143mW}{5026.55} = 0.0000028mW/cm^2$$

The highest E.I.R.P. of the Wi-Fi as reported in the authorization for the Wi-Fi module in the 5170 – 5825 MHz range = 112.2 mW

$$\frac{112.2mW}{4 \pi R^2} = \frac{112.2mW}{5026.55} = 0.0223mW/cm^2$$

$$\frac{0.0000028mW/cm^2}{1mW/cm^2} = \text{Ratio of } 0.000003$$

$$\frac{0.0223mW/cm^2}{1mW/cm^2} = \text{Ratio of } 0.0223$$

**The combined MPE of Wi-Fi and Radar is Ratio of 0.000003 + 0.0223 = 0.022303**