


SIX COMBO LABEL INFORMATION

EXACT LOCATION OF THE LABEL:


See the drawing on the next page for the exact location of the label. The label is referred to as the 'NAMEPLATE' on the drawing. The label will be either (a) the US version as per the drawing in this exhibit, or (b) the Canadian version as per the drawing in this exhibit.

NAMEPLATE: FCC OR IC LABEL TO BE AFFIXED HERE.



FA0335-000




PART NUMBER


21-Aug-2017		ADDED NAMEPLATE NUMBERS					C DAVIDSON		
DATE		DESCRIPTION OF CHANGE					CHG BY		
TOLERANCES: UNLESS OTHERWISE SPECIFIED		THIS PRINT AND INFORMATION THEREIN ARE PROPRIETARY TO SYSTEM SENSOR AND SHALL NOT BE USED IN WHOLE OR IN PART WITHOUT THEIR CONSENT.					 SYSTEM SENSOR 3825 Ohio Avenue St. Charles, IL 60174		
.XXX ± HOLES ± ANGLES ± FRAC ±		UNLESS OTHERWISE SPECIFIED, DIMENSIONS AND TOLERANCES ARE IN INCHES		DRAWN BY C DAVIDSON	DATE 12-Jul-2016	SHEET B SIZE			
DO NOT SCALE		TITLE							
SCALE 1:2		OR AS NOTED					DRAWING NUMBER FA0335		REV D
		FINAL ASSEMBLY SIXCOMBO					SHEET 1 OF 3		

ENGINEER'S DRAWING OF THE LABEL





Engineers drawings of the the US label and for the Canadian label are included on the following 2 pages.


NAMEPLATE: SIXCOMBO

 Smoke and Carbon Monoxide Detector Model No SIXCOMBO FCC ID: CFS8DLCOMR6		 Intertek 3180932 ETL Listed Smoke/CO detector Certified to Standard UL268 and UL 2075 SERIAL NO. XXXXXXXX REPLACE BY: Aug/2027 See I56-6241 for installation, maintenance and detector ratings WARNING: Use only Panasonic CR123A Lithium batteries. Lithium batteries may present risk of fire or explosion. Remove all old batteries, wait 10 seconds, then insert four new batteries. See the owner's manual for safety precautions. PATENT: www.Honeywell.com/patents N04-0110-003	
VOLTAGE: 3V DC Photoelectric Smoke Detector Principle and 85DB Sounder Factory Sens: .9 to 2.64%/ft Carbon Monoxide Detection Install/Operating Temp. Range 0° to 38° C (32° to 100° F) DATE CODE: For repair send to: Honeywell 12220 Rojas Drive Suite 700 El Paso, TX 79936 www.security.honeywell.com Country of origin: Mexico			
 WARNING Carbon Monoxide cannot be seen or smelled. If alarm signal sounds. 1) Operate HUSH button 2) Call your emergency services (Fire dept or 911. 3) Immediately move to fresh air-outdoors or by an open door or window N04-0110-103		DO NOT REMOVE N04-0110-203	

8/23/17	PRELIMINARY	CRD	B
DATE	DESCRIPTION OF CHANGE	CHANGED BY	REVISION
THIS PRINT AND INFORMATION THEREIN ARE PROPRIETARY TO SYSTEM SENSOR AND SHALL NOT BE USED IN WHOLE OR IN PART WITHOUT THEIR CONSENT.		 3825 OHIO AVENUE ST. CHARLES, IL 60174	
PART NUMBER N04-0110-003	TITLE NAMEPLATE SIXCOMBO	DRAWING NUMBER N04-0110	SHT:OF 1:1

NAMEPLATE: SIXCOMBO-CN

 Smoke and Carbon Monoxide Detector Model No SIXCOMBO-CN		 Intertek 3180532 ETL Listed Smoke/CO detector Certified to Standard ULC S531 and CSA 6.19 MAR2001 (R2016) SERIAL NO. XXXXXXXX REPLACE BY: Aug/2027 See instructions P/N 156-6243 Voir les instructions N/P, 156-6247 WARNING: Use only Panasonic CR123A Lithium batteries. Lithium batteries may present risk of fire or explosion. Remove all old batteries, wait 10 seconds, then insert four new batteries. See the owner's manual for safety precautions. PATENT: www.Honeywell.com/patents N04-0125-003
IC: 573F-COMR6 HVIN: COMR6 VOLTAGE: 3V DC Photoelectric Smoke Detector Principle and 85DB Sounder Factory Sens: .9 to 2.64%/ft Carbon Monoxide Detection Install/Operating Temp. Range 0° to 38° C (32° to 100° F) DATE CODE: For repair send to: Honeywell 12220 Rojas Drive Suite 700 El Paso, TX 79936 www.security.honeywell.com Country of origin: Mexico		
 WARNING Carbon Monoxide cannot be seen or smelled. If alarm signal sounds. 1) Operate HUSH button 2) Call your emergency services (Fire dept or 911. 3) Immediately move to fresh air-outdoors or by an open door or window N04-0125-103		DO NOT REMOVE N04-0125-203
 AVERTISSEMENT : Le monoxyde de carbone ne peut être ni vu ni senti. Si l'alarme retentit: 1) Appuyez sur le bouton pour couper le signal sonore 2) Appelez les services d'urgence (Pompiers ou 911) 3) Déplacez-vous immédiatement pour respirer de l'air frais en sortant dehors ou en ouvrant une porte ou une fenêtre. N04-0125-303		

8/23/17	PRELIMINARY	CRD	B
DATE	DESCRIPTION OF CHANGE	CHANGED BY	REVISION
THIS PRINT AND INFORMATION THEREIN ARE PROPRIETARY TO SYSTEM SENSOR AND SHALL NOT BE USED IN WHOLE OR IN PART WITHOUT THEIR CONSENT.		 3825 OHIO AVENUE ST. CHARLES, IL 60174	
PART NUMBER N04-0125-003	TITLE NAMEPLATE SIXCOMBO-CN	DRAWING NUMBER N04-0125	SHT:OF 1:1