» User Guide «



CC300 Operator Panel Model 2-DH47-0010

User Guide (Version 1.1)

P/N: XXXX-XXXX



CC300 Operator Panel - User Guide

Disclaimer

Kontron would like to point out that the information contained in this user guide may be subject to alteration, particularly as a result of the constant upgrading of Kontron products. This document does not entail any guarantee on the part of Kontron with respect to technical processes described in the user guide or any product characteristics set out in the user guide. Kontron assumes no responsibility or liability for the use of the described product(s), conveys no license or title under any patent, copyright or mask work rights to these products and makes no representations or warranties that these products are free from patent, copyright or mask work right infringement unless otherwise specified. Applications that are described in this user guide are for illustration purposes only. Kontron makes no representation or warranty that such application will be suitable for the specified use without further testing or modification. Kontron expressly informs the user that this user guide only contains a general description of processes and instructions which may not be applicable in every individual case. In cases of doubt, please contact Kontron.

This user guide is protected by copyright. All rights are reserved by Kontron. No part of this document may be reproduced, transmitted, transcribed, stored in a retrieval system, or translated into any language or computer language, in any form or by any means (electronic, mechanical, photocopying, recording, or otherwise), without the express written permission of Kontron. Kontron points out that the information contained in this user guide is constantly being updated in line with the technical alterations and improvements made by Kontron to the products and thus this user guide only reflects the technical status of the products by Kontron at the time of publishing.

Brand and product names are trademarks or registered trademarks of their respective owners.

©2020 by Kontron S&T AG

Kontron S&T AG

Lise-Meitner-Str. 3-5 86156 Augsburg Germany www.kontron.com

High Risk Applications Hazard Notice

THIS DEVICE AND ASSOCIATED SOFTWARE ARE NOT DESIGNED, MANUFACTURED OR INTENDED FOR USE OR RESALE FOR THE OPERATION OF NUCLEAR FACILITIES, THE NAVIGATION, CONTROL OR COMMUNICATION SYSTEMS FOR AIRCRAFT OR OTHER TRANSPORTATION, AIR TRAFFIC CONTROL, LIFE SUPPORT OR LIFE SUSTAINING APPLICATIONS, WEAPONS SYSTEMS, OR ANY OTHER APPLICATION IN A HAZARDOUS ENVIRONMENT, OR REQUIRING FAIL-SAFE PERFORMANCE, OR IN WHICH THE FAILURE OF PRODUCTS COULD LEAD DIRECTLY TO DEATH, PERSONAL INJURY, OR SEVERE PHYSICAL OR ENVIRONMENTAL DAMAGE (COLLECTIVELY, "HIGH RISK APPLICATIONS").

You understand and agree that your use of Kontron devices as a component in High Risk Applications is entirely at your risk. To minimize the risks associated with your products and applications, you should provide adequate design and operating safeguards. You are solely responsible for compliance with all legal, regulatory, safety, and security related requirements concerning your products. You are responsible to ensure that your systems (and any Kontron hardware or software components incorporated in your systems) meet all applicable requirements. Unless otherwise stated in the product documentation, the Kontron device is not provided with error-tolerance capabilities and cannot therefore be deemed as being engineered, manufactured or setup to be compliant for implementation or for resale as device in High Risk Applications. All application and safety related information in this document (including application descriptions, suggested safety measures, suggested Kontron products, and other materials) is provided for reference only.

Intended Use: The CC300 Operator panel is designed for the use in industrial facilities only.

ACAUTION

Handling and operation of the product is permitted only for trained personnel within a work place that is access controlled. Please follow the "General Safety Instructions for IT Equipment" supplied with the system.

1. Table of Contents

1. Table of Contents	5
1.1. Table of Figures	7
2. Introduction	g
2.1. Symbols used in this User Guide	10
3. Important Instructions	11
3.1. Note on the Warranty	11
3.2. Exclusion of Accident Liability Obligation	11
3.3. Liability Limitation / Exemption from the Warranty Obligation	11
4. General Safety Instructions for	12
4.1. Electrostatic Discharge (ESD)	14
4.1.1. Grounding Methods	14
4.2. Instructions for the Lithium Battery	15
5. Electromagnetic Compatibility	16
5.1. Electromagnetic Compatibility (EU)	
5.2. FCC and RSS Statement (USA & Canada)	
5.3. Nameplate of the CC300 Operator Panel	17
6. Scope of Delivery	18
7. Product Description	19
7.1. Front Side View	22
7.1.1. On/Off Button	23
7.1.2. RFID Read/Write Zone	23
7.1.3. Emergency Stop Switch	24
7.1.4. Buttons for Tilting the CC300 Operator Panel	25
7.1.5. Touch Display	25
7.1.6. Touch Display Care and Cleaning	25
7.1.7. Traversing Buttons	26
7.1.8. Markings for the USB Ports	26
7.1.9. Permissive Button and Program Interrupt Button	27
7.1.10. Rotary/Push Button with Display	27
7.2. Rear View	28
7.2.1. Harting Connector	29
7.2.2. Connection Cables for the Linear Actuator	29
7.2.3. Grounding Cable (PE)	30
7.2.4. LAN Cables	30
7.3. Left and Right Side View	31
7.3.1. USB Ports	32
7.4. Top and Bottom View	33
7.5. Accessing internal Components	34

7.5.1. Opening the CC300 Operator Panel	34
7.5.2. Closing the CC300 Operator Panel	37
8. Cabinet Installation	38
9. Maintenance and Prevention	43
9.1. Replacing the Lithium Battery	43
9.2. Replacing the Emergency Stop Switch	46
9.2.1. Replacing the Button of the Emergency Stop Switch	46
9.2.2. Replacing the Auxiliary Switch Block	46
9.3. Replacing the Rotary/Push Button	48
9.4. Replacing the Cable Gland	50
10. Technical Data	53
10.1. External Connectors and Interfaces	54
10.2. Electrical Specifications	55
10.3. Environmental Specifications	56
10.4. Mechanical Specifications	56
10.5. International Compliance, Approvals and Certificates	59
11. Interfaces – Pin Assignments	61
11.1.1. Harting Connector	61
11.1.2. LAN 0, LAN 2 and LAN 3 Cable	62
11.1.3. LAN 1 Cable	62
11.1.4. DP Connector (Standard: DisplayPort 1.2)	63
11.1.5. USB Ports	64
11.1.6. Grounding Cable (PE)	64

1.1. Table of Figures

Fig.	1: CC300 Operator Panel - Nameplate	17
Fig.	2: Bottom view	21
Fig.	3: Right view	21
Fig.	4: Front view	21
Fig.	5: Rear view	21
Fig.	6: Left view	21
Fig.	7: Top view	21
Fig.	8: Front view of the CC300 operator panel	22
Fig.	9: On/Off button	23
Fig.	10: RFID-read/write zone	23
Fig.	11: Emergency stop switch	24
Fig.	12: Buttons for tilting out and in the CC300 operator panel	25
Fig.	13: Traversing buttons below the touch display	26
Fig.	14: Markings for laterally mounted USB 2.0 ports	26
Fig.	15: Permissive button and program interrupt button	27
Fig.	16: Rotary/push button with illumination and display	27
Fig.	17: Rear side of the CC300 operator panel	28
Fig.	18: Harting connector	29
Fig.	19: Grounding cable	30
Fig.	20: LAN cables	30
Fig.	21: Right side of the CC300 operator panel	31
Fig.	22: Left side of the CC300 operator panel	31
Fig.	23: USB ports	32
Fig.	24: Top view of the CC300 operator panel	33
Fig.	25: Bottom view of the CC300 operator panel	33
Fig.	26: Carefully open the CC300 a few inches	35
Fig.	27: Unlocking and removing the auxiliary switch block	35
Fig.	28: CC300 operator panel, fully opened	36
Fig.	29: CC300 Operator Panel installed in an industrial cabinet	38
Fig.	30: Threaded holes and contact surfaces for holder mounting	38
Fig.	31: Mounting the CC300 Operator Panel to the left holder	39
Fig.	32: Mounting the cable gland to the cabinet	39
Fig.	33: Threaded holes and contact surface for guide sleeve mounting	40
Fig.	34: Mounting the guide sleeve of the actuator to the CC300	40
Fig.	35: Inserting the forcer into the guide sleeve of the actuator	41
Fig.	35: Attaching the top cover of the CC300 cabinet	41
Fig.	36: Inserting the forcer into the guide sleeve of the actuator	42
Fig.	37: Button (cap) of the rotary/push button	43

1. Table of Contents

Fig. 38: Unscrew the cap holder of the rotary/push button	43
Fig. 39: Rotary/push button and CMOS battery, pulled out of the housing	44
Fig. 40: Removing the rotary/push button (shown with battery removed)	44
Fig. 41: Position of the label on the cap holder of the rotary/push button	45
Fig. 42: Button of the emergency stop switch	46
Fig. 43: Dismantling the auxiliary switch block	47
Fig. 44: Switch module, cable, and mounting flange	47
Fig. 45: Button (cap) of the rotary/push button	48
Fig. 46: Unscrew the cap holder of the rotary/push button	48
Fig. 47: Rotary/push button and CMOS battery, pulled out of the housing	48
Fig. 48: Removing the rotary/push button (shown with battery removed)	49
Fig. 49: Position of the label on the cap holder of the rotary/push button	
Fig. 50: Remove screws of the cable gland bracket	50
Fig. 51: Detached cable gland with bracket	50
Fig. 52: Take the bracket out of the cable gland	51
Fig. 53: Cables and cable gland bracket after removing the cable gland	51
Fig. 54: Insert cables from the thicker end into the cable gland	52
Fig. 55: Cable gland with inserted bracket (shown without cables)	52
Fig. 56: Dimensioned view of the CC300 glass front (print side - reversed image)	57
Fig. 57: Dimensioned rear and side view of the CC300 operator panel	58

2. Introduction

2. Introduction

Kontron Europe GmbH would like to point out that the information contained in this manual may be subject to technical alteration, particularly as a result of the constant upgrading of Kontron Europe GmbH products. The attached documentation does not entail any guarantee on the part of Kontron Europe GmbH with respect to technical processes described in the manual or any product characteristics set out in the manual. Kontron Europe GmbH does not accept any liability for any printing errors or other inaccuracies in the manual unless it can be proven that Kontron Europe GmbH is aware of such errors or inaccuracies or that Kontron Europe GmbH is unaware of these as a result of gross negligence and Kontron Europe GmbH has failed to eliminate these errors or inaccuracies for this reason. Kontron Europe GmbH expressly informs the user that this manual only contains a general description of technical processes and instructions which may not be applicable in every individual case. In cases of doubt, please contact Kontron Europe.

This manual is protected by copyright. All rights are reserved by Kontron Europe. Copies of all or part of this manual or translations into a different language may only be made with the prior written consent of Kontron Europe GmbH. Kontron Europe GmbH points out that the information contained in this manual is constantly being updated in line with the technical alterations and improvements made by Kontron Europe GmbH to the products and thus this manual only reflects the technical status of the products by Kontron Europe GmbH at the time of printing.

© 2020 by Kontron Europe

Printing and duplication, even of sections, is only permissible with the express approval of

Kontron Europe GmbH Lise-Meitner-Str. 3-5

86156 Augsburg Germany

2.1. Symbols used in this User Guide

Symbol

Meaning



This symbol indicates the danger of injury to the user or the risk of damage to the product if the corresponding warning notices are not observed.



This symbol indicates that the product or parts thereof may be damaged if the corresponding warning notices are not observed.



This symbol indicates general information about the product and the user guide.



This symbol indicates detail information about the specific product configuration.



This symbol precedes helpful hints and tips for daily use.

3. Important Instructions

This chapter contains instructions which must be observed when using the CC300 Operator Panel. The manufacturer's instructions provide useful information on your device.

3.1. Note on the Warranty

Due to their limited service life, parts which by their nature are subject to a particularly high degree of wear (wearing parts) are excluded from the warranty beyond that provided by law. This applies to batteries, for example.

3.2. Exclusion of Accident Liability Obligation

Kontron Europe GmbH shall be exempted from the statutory accident liability obligation if the user fails to observe the included document: "General Safety Instructions for IT Equipment" the hints in this manual or eventually the warning sign labels on the device.

3.3. Liability Limitation / Exemption from the Warranty Obligation

In the event of damage to the device caused by failure to observe the included document "General Safety Instructions for IT Equipment", the hints in this manual or eventually the warning signs label on the device, Kontron Europe GmbH shall not be required to honor the warranty even during the warranty period and shall be exempted from the statutory accident liability obligation.

4. General Safety Instructions

Please read this section carefully and observe the instructions for your own safety and correct use of the device.

Observe the warnings and instructions on the device and in the manual.

The CC300 Operator Panel has been built and tested by Kontron Europe in accordance to UL 61010-1 - Edition 3 - Revision Date 2019/07/19 and left the company in a perfectly safe condition.

In order to maintain this condition and ensure safe operation, the user must observe the instructions and warnings contained in this manual.

This product shall be supplied by 60950-1 LPS or NEC Class 2 power supply.
The device must be used in accordance with the instructions for use.
The electrical installations in the room must correspond to the requirements of the local (country-specific) regulations.
For DC power connection: The DC power source should be able to be switched off and on via an isolating switch. The unit is only completely disconnected from the DC main power source, when the DC power cord is disconnected either from the power source or the unit. Therefore, the DC power cord and its connectors must always remain easily accessible.
Do not place the device in direct sunlight, near heat sources or in a damp place. Make sure the device has adequate ventilation.
Only devices and components which fulfill the requirements of an SELV circuit (safety extra low voltage) in accordance with EN60950 may be connected to the interfaces of the system.
The device is designed to be used in vertical (diagonal) position. The device generates heat during operation. Make sure it is adequately ventilated. Do not cover the cooling fins on the rear side of the device.
Maintenance or repair on the open device may only be carried out by qualified personnel authorized by Kontron Europe GmbH which is aware of with the associated dangers.
The device may only be opened in accordance with the description in this user guide for replacing the Lithium battery. The device must be switched off and disconnected from the power source.
Only approved original accessories (optional parts) approved by Kontron Europe GmbH may be used.
The DC-input must fulfill SELV requirements of EN60950-1 standard.
The chassis of the CC300 Operator Panel must be protective earthed by establishing a large-area contact between the grounding cable and an appropriate grounding connection point.

4. General Safety Instructions

CC300 Operator Panel – User Guide

- ☐ It must be assumed that safe operation is no longer possible,
 - if the device has visible damage or
 - if the device no longer functions.

In these cases the device must be shut down and secured against unintentional operation.



4.1. Electrostatic Discharge (ESD)

A sudden discharge of electrostatic electricity can destroy static-sensitive devices or micro-circuitry. Therefore proper packaging and grounding techniques are necessary precautions to prevent damage. Always take the following precautions:

- **1.** Transport boards in ESD-safe containers such as boxes or bags.
- 2. Keep electrostatic sensitive parts in their containers until they arrive at the ESD-safe workplace.
- **3.** Always be properly grounded when touching a sensitive board, component, or assembly.
- **4.** Store electrostatic-sensitive boards in protective packaging or on antistatic mats.

4.1.1. Grounding Methods

The following measures help to avoid electrostatic damages to the device:

- **1.** Cover workstations with approved antistatic material. Always wear a wrist strap connected to workplace as well as properly grounded tools and equipment.
- **2.** Use antistatic mats, heel straps, or air ionizers for more protection.
- 3. Always handle electrostatic sensitive components by their edge or by their casing.
- 4. Avoid contact with pins, leads, or circuitry.
- **5.** Turn off power and input signals before inserting and removing connectors or connecting test equipment.
- 6. Keep work area free of non-conductive materials such as ordinary plastic assembly aids and styrofoam.
- 7. Use field service tools such as cutters, screwdrivers, and vacuum cleaners which are conductive.
- **8.** Always place drives and boards PCB-assembly-side down on the foam.

4.2. Instructions for the Lithium Battery

The installed mainboard is equipped with a lithium battery.

For the replacing of this battery please observe the instructions described in the "Replacing the Lithium Battery" chapter.



Warning

Danger of explosion when replacing with wrong type of battery. Replace only with the same or equivalent type recommended by the manufacturer. The lithium battery type must be UL listed.



Do not dispose of lithium batteries in general trash collection. Dispose of the battery according to the local regulations dealing with the disposal of these special materials, (e.g. to the collecting points for dispose of batteries).

5. Electromagnetic Compatibility

5.1. Electromagnetic Compatibility (EU)

This product is intended only for use in industrial areas. The most recent version of the EMC guidelines (EMC Directive 2004/108/EC) and/or the German EMC laws apply. If the user modifies and/or adds to the equipment (e.g. installation of expansion cards) the prerequisites for the CE conformity declaration (safety requirements) may no longer apply.

Warning!

This is a class A product. In domestic environment this product may cause radio interference in which case the user may be required to take adequate measures.

5.2. FCC and RSS Statement (USA & Canada)

This equipment has been tested and found to comply with the limits for a Class A digital device, pursuant to Part 15 of the FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in commercial environment. This equipment generates, uses, and can radiate radio frequency energy and, if not installed and used in accordance with the instruction manual, may cause harmful interference to radio communications. Operation of this equipment in residential area is likely to cause harmful interference in which case the user will be required to correct the interference at his own expense.

This device complies with Part 15 of the FCC Rules.

Operation is subject to the following two conditions:

- (1) this device may not cause harmful interference, and
- (2) this device must accept any interference received, including interference that may cause undesired operation.

In addition to containing other required statements specified elsewhere in this standard or in the applicable RSS.

This device contains licence-exempt transmitter(s)/receiver(s) that comply with Innovation, Science and Economic Development Canada's licence-exempt RSS(s). Operation is subject to the following two conditions:

- (1) This device may not cause interference.
- (2) This device must accept any interference, including interference that may cause undesired operation of the device.

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes : (1) l'appareil ne doit pas produire de brouillage, et (2) l'utilisateur de l'appareil doit accepter tout brouillage radioélectrique subi, même si le brouillage est susceptible d'en compromettre le fonctionnement.

Changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate the equipment.

(English): This Class A digital apparatus complies with the Canadian ICES-003.

(French): Cet appareil numérique de la class A est conforme à la norme NMB-003 du Canada.

5.3. Nameplate of the CC300 Operator Panel

The nameplate is located at the bottom rear side of the cabinet (see also Fig. 17, Pos. 8).



Fig. 1: CC300 Operator Panel - Nameplate

6. Scope of Delivery

Scope of Delivery:	☐ CC300 Operator Panel	
Optional Parts:	Il Parts: DP cable	
	☐ Blind panel	
	☐ Add-on panel	
	☐ Expansion panel	
	☐ Expansion panel 2F	

7. Product Description

The CC300 operator panel is a Human Machine Interface (HMI) system designed for demanding industrial applications. As a workstation system with integrated touch screen display it is designed for installation in an instrument panel or other cabinets. For better handling and readability the operator panel can be tilt continuously out of its vertical position up to a maximum tilt angle of 45 degrees by a linear actuator (outwards, with the lower edge ahead).

The CC300 operator panel consists of two main parts, the front plate and the rear cover.

The front of the CC300 operator panel is designed in glass; between the glass and the 21.5"display a PCAP touch (capacitive touch with multi-touch capability) is laminated on the glass. In addition, the glass front supports an emergency stop switch, an RFID antenna, capacitive buttons with LED backlight and a rotary/push button with LED backlight.

The rear cover consists of die cast aluminum and serves the following functions: Heat sink of the system, chassis for assembling of electronic modules, holder of the linear actuator (of the external tilting mechanism) and cable gland for all outgoing cables.

The CC300 operator panel accommodates an INTEL processor architecture board that will host the "LINUX 64 Bit" operating system. All components, hardware and hardware drivers are designed to support 100% the "ENGEL LINUX x86 64 Bit" operating system. An M.2 drive is installed as storage device. Optionally, the CC300 operator panel can be equipped with a 2.5" SSD or HDD drive.

The CC300 operator panel has two externally accessible USB 3.0 ports located at the left side of the chassis. The position of the USB ports is marked on the front plate with backlit symbols.

The CC300 operator panel provides four external LAN ports with three different NICs. Thus, it can be connected simultaneously e.g. to the corporate LAN and to a stored program control (SPC).

Via the RFID read/write zone at the glass front of the CC300 operator panel e.g. smart cards can be read or written contactless.

The CC300 operator panel is designed for 24V DC operation.



The CC300 operator panel will not meet any safety functions!

Monitoring of all safety-related components (emergency stop, protective covers etc.) will be performed by particular safety modules of the terminal equipment.



The CC300 operator panel complies with IP54 protection class (IP54 not evaluated by UL).

The CC300 operator panel is a fanless system. The cooling of the unit is performed by the surface and the cooling fins of the aluminum cover on the rear side of the chassis.



When powering on the CC300 operator panel, make sure that the cooling fins are not obstructed.



Views of the CC300 operator panel (Fig. 2 to Fig. 7) with cable gland, without tilting mechanism.

7.1. Front Side View




Fig. 8: Front view of the CC300 operator panel

Legend for Fig. 8:

- 1 On/Off button
- 2 RFID read/write zone
- 3 21.5" TFT display with multi-touch
- 4 Traversing buttons
- 5 Markings for the two USB ports (laterally mounted)
- 6 Permissive button

- 7 Program interrupt button
- 8 Rotary/push button (backlit)
- 9 Display of the rotary/push button
- 10 Emergency stop switch
- 11 Buttons for tilting out and in the operator panel (up to 45 degrees max.)

7.1.1. On/Off Button




Fig. 9: On/Off button

The On/Off button allows to boot up/shut down the system. It is a capacitive button with white LED backlight, located top left on the front plate (see also Fig. 8, Pos. 1).



Even when the system is turned off via the On/Off button there is still a standby-voltage on the mainboard. The system is not completely disconnected from the main power supply (DC) by switching off via the On/Off button.

The unit is only completely disconnected from the DC main power supply, when the DC power is cut off by an isolating switch or when the power cord is disconnected either from the DC main power or the unit. Therefore, the DC power cord and its connectors must always remain easily accessible.

To avoid the risk of data loss, always shut down the system before you cut off the power using an isolating switch!

7.1.2. RFID Read/Write Zone




Fig. 10: RFID-read/write zone

On the right side of the On/Off button the RFID read/write zone is located (see also Fig. 8, Pos. 2). At this position the RFID antenna is mounted to the rear side of the front glass. RFID-equipped objects (e.g. ID cards, smart cards, RFID labels) can be read or written by the CC300 operator panel, when held against the front glass within the read/write zone. The RFID data will be processed by the installed software (e.g. user login with different authorizations for different user accounts).

7.1.3. Emergency Stop Switch



Fig. 11: Emergency stop switch

The emergency stop switch is located centered above the display on the glass front (see also Fig. 8, Pos. 10). The emergency stop button has to be pressed firmly. The switch locks in place and can only be released by turning the knob clockwise.

The emergency stop switch has four (optional: six) switching contacts that cut off the connected 24 V circuits when being pressed.



Even though the emergency stop switch is installed in the CC300 operator panel, it is not connected to or monitored by the CC300 electronics!

The emergency stop switch is installed in the CC300 operator panel for the purpose of easy and quick accessibility but it has an entirely independent function.

When the emergency stop switch is pressed, the CC300 operator panel will not be halted or switched off.



The emergency stop switch may only be connected by trained personnel.

The responsibility for safety lies with the customer. The emergency stop switch was only mounted mechanically.



Only connect to a power supply delivering the specified input rating and complying with the requirements of Safety Extra Low Voltage (SELV) and Limited Power Source (LPS) according to IEC UL/IEC 60950-1 or Limited energy circuit according to UL/IEC 61010-1 or Class 2 according to UL1310.

7.1.4. Buttons for Tilting the CC300 Operator Panel




Fig. 12: Buttons for tilting out and in the CC300 operator panel

For better handling and readability the operator panel can be tilt continuously out of its vertical position up to a maximum tilt angle of 45 degrees by a linear actuator.

By pressing the "Tilt out" button, the CC300 operator panel tilts outwards (with the lower edge ahead) until the button is released. When the maximum tilt angle of 45 degrees is reached, the tilt-out process will also be stopped.

By pressing the "Tilt in" button, the CC300 operator panel tilts back (with the lower edge ahead) in the direction of the vertical mounting position until the button is released. When the vertical mounting position is reached, the tilt-in process will also be stopped.

The "Tilt out" and "Tilt in" buttons, as well as their symbols, are backlit white. During being pressed, the particular button and the corresponding symbol are backlit blue.

7.1.5. Touch Display

The CC300 operator panel is equipped with a 21.5" TFT display and a capacitive touch (PCAP) with multitouch capability (see also Fig. 8, Pos. 3). The surface of the display and the touch is protected by the front glass. The touch display responds to the light touch of a finger or glove (the touch display is factory-calibrated for operation with the PU-coated glove types *Solidstar 1327* and *Camapur Cut 620*) and offers the same degree of user comfort as a computer mouse.

For technical specification of the touch display refer to the chapter 10 "Technical Data".



Do not use a hard or a pointed object (like a screw driver) to operate the touch screen or the capacitive buttons, since it can scratch or damage the front glass.

7.1.6. Touch Display Care and Cleaning



The front panel and the touch screen are protected by a continuous glass plate that should be handled with care and cleaned regularly.

Use a lint-free cloth with mild detergent (e.g. glass cleaner) and water for cleaning the glass front. Do not

use strong or abrasive detergents or solvents, which could attack plastic parts (e.g. the rotary/push button) or scratch the front glass.



The capacitive touch screen is factory-calibrated and needs no recalibration.

7.1.7. Traversing Buttons



Fig. 13: Traversing buttons below the touch display

Directly below the touch display, arranged in pairs, six traversing buttons are located, (see also Fig. 8, Pos. 4), which are processed by the capacitive touch of the display. The function of the buttons may be changed by the software; the current function will be displayed on the display directly above the corresponding buttons.

7.1.8. Markings for the USB Ports




Fig. 14: Markings for laterally mounted USB 2.0 ports

At the bottom left of the front plate, an USB symbol and two markings for the positions of the laterally (behind the front plate) mounted USB ports are located (see also Fig. 8, Pos. 5 and Fig. 23). The USB symbol and the markings are backlit white.

7.1.9. Permissive Button and Program Interrupt Button




Fig. 15: Permissive button and program interrupt button

Below the traverse buttons, on the right of the USB markings, the permissive button (see also Fig. 8, Pos. 6) and the program interrupt button (see also Fig. 8, Pos. 7) are located.

The capacitive permissive button will be used in certain situations in addition to a traverse button or a button displayed on the display. In idle mode, the permissive button and its related symbol are backlit white. The backlight changes to blue when the permissive button is pressed.

By pressing the capacitive program interrupt button (error acknowledgement button), all upcoming error messages will be acknowledged an a running automatic cycle will be interrupted. In idle mode, the program interrupt button and its related symbol are backlit *white*. The backlight changes to *orange* when the program interrupt button is pressed.

7.1.10. Rotary/Push Button with Display




Fig. 16: Rotary/push button with illumination and display

At the bottom right of the front plate, below the touch display, the rotary/push button with display is located (see also Fig. 8, Pos. 8 and Pos. 9). The rotary/push button can be adjusted to the left and to the right to a maximum of 30 degrees and is self-resetting when released. Furthermore, the rotary/push button provides a push button function. Around the rotary/push button a white backlit ring is mounted that can change its color to red, green and orange by software.

The display of the rotary/push button is part of the touch display and visualizes the set values.

7.2. Rear View




Fig. 17: Rear side of the CC300 operator panel

Legend for Fig. 17:

- 1 Screws that secure the rear cover at the front plate
- 2 Threaded holes for mounting the CC300
- 3 Aluminum rear cover of the CC300
- 4 Cooling fins of the aluminum rear cover
- 5 Harting connector (24-pole)
- 6 4x LAN cables (Ethernet 10/100/1000; 3x male, 1x female)

- 7 2x USB 3.0 ports
- 8 Nameplate
- 9 Threaded holes for mounting the linear actuator
- 10 Connection cables for the linear actuator
- 11 Grounding cable
- 12 Cable gland (flexible cable inlet)



Optionally, an additional DP cable (DisplayPort cable) can be connected to the mainboard and led out through the cable gland. A digital display can be connected to the DP cable.

7.2.1. Harting Connector



Fig. 18: Harting connector

All outgoing cables of the CC300 operator panel are routed through the cable gland at the rear side of the cabinet (see also Fig. 17, Pos. 12). Except for the cables for the linear actuator and the grounding cable, all single wires are combined in the 24-pole Harting connector (Fig. 18). For the pin assignment of the Harting connector, refer to chapter 11.1.1 "Harting Connector".

7.2.1.1. Power Supply via the Harting Connector

The power supply of the CC300 operator panel will be provided via pin 7 (24 Volts; cable No. 6) and pin 19 (0 Volts; cable No. 5) of the Harting connector.



Only connect to a power supply delivering the specified input rating and complying with the requirements of Safety Extra Low Voltage (SELV) and Limited Power Source (LPS) according to IEC UL/IEC 60950-1 or Limited energy circuit according to UL/IEC 61010-1 or Class 2 according to UL1310.


7.2.1.2. Control and Signal Lines

The power supply of the linear actuator, the interrupt circuits 1 to 4 (optional: 1 to 6) of the emergency stop switch and other control lines (power transformer switch-off, Dig In 1) are also routed through the 24-pin Harting connector. For the pin assignment of the Harting connector, refer to chapter 11.1.1 "Harting Connector".

7.2.2. Connection Cables for the Linear Actuator

The two single cables marked "1" and "2" (see Fig. 17, Pos. 10) will be connected to the linear actuator of the tilting mechanism. The maximum allowed connection power is 44 W.

7.2.3. Grounding Cable (PE)



Grounding cable (yellow/green)

Fig. 19: Grounding cable

The CC300 operator panel must be grounded by establishing a **large-area contact** between the grounding cable (see also Fig. 17, Pos. 11) and an appropriate grounding contact. The cross section of the grounding cable is 6 mm².

7.2.4. LAN Cables




Fig. 20: LAN cables

The "ETH 0" LAN cable (green) is equipped with a male RJ 45 connector (Ethernet 10/100/1000). The "ETH 1" LAN cable (black) is equipped with a female RJ 45 connector (Ethernet 10/100/1000). The "ETH 2" LAN cable (blue) is equipped with a male RJ 45 connector (Ethernet 10/100/1000). The "ETH 3" LAN cable (white) is equipped with a male RJ 45 connector (Ethernet 10/100/1000).



ETH 2 and ETH 3 are internally connected to a switch and share a common MAC address. To avoid network problems, do not connect both LAN cables (ETH2 and ETH3) to the same network device (e.g. Ethernet switch).

7.3. Left and Right Side View




Fig. 21: Right side of the CC300 operator panel




Fig. 22: Left side of the CC300 operator panel

Legend for Fig. 21 and Fig. 22:

- 1 Emergency stop switch
- 2 Front plate of the CC300
- 3 Aluminum rear cover of the CC300
- 4 Rotary/push button

- 5 Screws that secure the rear cover at the front plate
- 6 Cable gland
- 7 Cavity with 2x USB 3.0 ports

7.3.1. USB Ports



Fig. 23: USB ports

In a cavity at the left side of the aluminum cover, two USB 3.0 ports (see also Fig. 22, Pos. 7) are located. The cavity is deep enough that plugged-in USB sticks will not restrain the tilting mechanism of the CC300 operator panel.

7.4. Top and Bottom View




Fig. 24: Top view of the CC300 operator panel




Fig. 25: Bottom view of the CC300 operator panel

Legend for Fig. 24 and Fig. 25:

- 1 Cable gland
- 2 Cooling fins of the aluminum rear cover
- 3 Aluminum rear cover of the CC300
- 4 Screws that secure the rear cover at the front 8 2x USB 3.0 Ports plate
- 5 Emergency stop switch
- 6 Rotary/push button
- 7 Front plate of the CC300

7.5. Accessing internal Components

This section contains important information that you must read before accessing internal components. Follow these procedures properly when handling any internal components of the system.



The replacement of the lithium battery (optional: the installation and removal of memory modules, drives or cables) should only be carried out by qualified specialists, in accordance with the description contained in this manual.

Before removing the cover of the CC300 operator panel in order to gain access to the internal components, the system must be powered down and the power cord has to be disconnected from the power source.

It is not allowed to operate the system without installed cover.



Please observe the safety instruction for handling assemblies with static sensitive device. Disregarding of this warning instruction can result in damage to the device.

7.5.1. Opening the CC300 Operator Panel

To open the CC300 operator panel, perform the following steps:

- 1. Place the device on a soft underlayment (e.g. a thick PE foam sheet) with the front plate facing down (see Fig. 26). Make sure that the underlayment is dimensioned so that only the glass plate rests on the underlayment and the emergency stop switch and the rotary/push button do not rest on the underlayment or table.
- 2. Remove the 10x screws (M5 x 10) and the bonded seals that fix the rear cover to the front plate (see Fig. 17, Pos. 1).



The screws (M5 x 10) and the bonded seals must be replaced after 3 to 5 times of tightening and loosening for continuing compliance with IP54 protection class!

3. Lift the rear cover on the left side (seen from behind, with the emergency stop switch at the top!) carefully a few inches (see Fig. 26).



Fig. 26: Carefully open the CC300 a few inches



Attention: The device can only be opened fully after the auxiliary switch block (of the emergency stop switch) has been removed!

(It is recommended that the rear cover is held by a second person while the auxiliary switch block is removed!)

4. Unlock the auxiliary switch block with a screwdriver and pull it out of its mounting (see Fig. 27).




Fig. 27: Unlocking and removing the auxiliary switch block

5. Now the CC300 operator panel can be folded apart carefully.




Fig. 28: CC300 operator panel, fully opened

Legend for Fig. 28:

- 1 Circuit area above the display
- Mounting of the auxiliary switch block (of the emergency stop switch)
- 3 Front plate with aluminum frame
- 4 Display with capacitive touch
- 5 Surrounding seal
- 6 Housing of rotary/push button and CMOS battery
- 7 2x USB ports (externally accessible)

- 8 Battery cable from CMOS battery (pos. 6) to CPU board
- 9 CPU board (mainboard)
- 10 Aluminum rear cover
- 11 I/O board
- 12 Mounting and opening of the cable gland
- 13 Auxiliary switch block (detached)
- 14 DRAM module

7.5.2. Closing the CC300 Operator Panel

Closing the CC300 operator panel will be performed in reversed order:

- **1.** Carefully fold the aluminum rear cover back onto the front plate, but leave the rear cover open a few inches (see Fig. 26).
 - It is recommended that the rear cover is held by a second person while the auxiliary switch block is inserted into its mounting!
- **2.** Press the auxiliary switch block of the emergency stop switch (see Fig. 28, Pos.13) into its mounting so that it clicks into place (see Fig. 28, Pos.2 and Fig. 27).
- **3.** Carefully close the housing completely. Make sure that no cables are jammed and that the surrounding seal is in correct position and will not be damaged (see Fig. 28, Pos. 5).
- **4.** Fix the rear cover to the front plate with the 10x screws (M5 x 10) and bonded seals removed in chapter 7.5.1 "Opening the CC300 Operator Panel", step 2 (see Fig. 17, Pos. 1).



Do not exceed the maximum torque of 2.7 Nm when fastening the cabinet screws!

8. Cabinet Installation

For operation, the CC300 Operator Panel will be installed into an industrial cabinet.



Fig. 29: CC300 Operator Panel installed in an industrial cabinet

To install the CC300 Operator Panel into its cabinet, proceed as follows:

1. Mount the CC300 to the holders of the cabinet. At least two persons are needed for this operation: One holds the CC300, the other screws it to the left and right holder.



The left and right holder (or any other holders which are suitable for mounting the CC300) must be mounted directly and firmly to the attachment points of the CC300 without any space between the contact surface of the holder and the contact surface of the CC300 (see Fig. 30 and Fig. 31).

Minimum requirements for the mounting screws: Property class 8.8 (minimum) M5 screws. The screws must be screwed in to a minimum depth of 4 mm and a maximum depth of 7.5 mm.



Fig. 30: Threaded holes and contact surfaces for holder mounting




Fig. 31: Mounting the CC300 Operator Panel to the left holder

2. Route all cables from the cable gland through the cable opening of the cabinet.




Fig. 32: Mounting the cable gland to the cabinet

- 3. Screw the free end of the cable gland to the cable opening
- **4.** Route the two cables for the actuator back to the actuator using the second cable feedthrough and connect it to the actuator.
- **5.** Mount the guide sleeve of the actuator to the rear of the CC300 cabinet with 2x screws and washers.



The guide sleeve must be mounted directly and firmly to the attachment point of the CC300 without any space between the contact surface of the guide sleeve and the contact surface of the CC300 (see Fig. 33 and Fig. 34).

Minimum requirements for the mounting screws: Property class 8.8 (minimum) M5 screws. The screws must be screwed in to a minimum depth of 4 mm and a maximum depth of 7.5 mm.



Fig. 33: Threaded holes and contact surface for guide sleeve mounting




Fig. 34: Mounting the guide sleeve of the actuator to the CC300

8. Cabinet Installation

6. Insert the forcer of the actuator into the guide sleeve




Fig. 35: Inserting the forcer into the guide sleeve of the actuator

7. Attach the top cover to the cabinet




Fig. 36: Attaching the top cover of the CC300 cabinet

8. Connect the Harting connector to its mating connector at the rear side of the cabinet and lock it in place



Fig. 37: Inserting the forcer into the guide sleeve of the actuator

9. Connect the grounding cable to the appropriate grounding connector and all the remaining cables to their corresponding connectors.

Further information about cabling and connecting the CC300 Operator panel to the corresponding devices is not subject of this manual.



The Harting connector 09 33 024 2601 must not be used for disconnecting or connecting while product is in operation. Furthermore, this connector is to be used only with female connector 09 33 024 2701.

9. Maintenance and Prevention

Kontron Europe systems require minimal maintenance and care to keep them operating correctly.

- Occasionally wipe the system with a soft dry cloth.
- ☐ You should only remove persistent dirt by use of a soft, slightly damp cloth (use only a mild detergent).
- ☐ For the touch screen cleaning refer to the chapter 7.1.6. "Touch Display Care and Cleaning".

9.1. Replacing the Lithium Battery

The mainboard of the CC300 operator panel is equipped with a lithium CMOS battery. To replace the lithium battery, proceed as follows:

1. Pull the button (cap) of the rotary/push button off of the glass front. The cap holder of the rotary/push button with three screws is now accessible from the outside (see Fig. 46, Fig. 47).



Fig. 38: Button (cap) of the rotary/push button

2. Remove three 2.5 mm (0.98 inch) Allen screws from the rotary/push button at the glass front (see Fig. 47).



Fig. 39: Unscrew the cap holder of the rotary/push button

3. Pull the rotary/push button and the lithium battery carefully out of the front panel.




Fig. 40: Rotary/push button and CMOS battery, pulled out of the housing

- **4.** Remove the battery cable from the board of the rotary/push button (see Fig. 40).
- **5.** Removing the lithium battery: Press down the cable lock and pull the battery cable connector out of its mating connector (see Fig. 41).




Fig. 41: Removing the rotary/push button (shown with battery removed)

6. Install the new lithium battery in reverse order:

- ☐ Plug the battery cable into the mating connector until it locks in place
- Re-attach the battery cable to the rotary/push button board as a strain relief
- ☐ Insert the battery and the rotary/push button into the opening of the front panel
- Attach the holder of the rotary/push button so that the white label on the side of the cap holder is in top position (see Fig. 42).
- Secure the rotary/push button with the 3 Allen screws removed in step 2. Fasten the screws to a torque of 0.32 Nm.




Fig. 42: Position of the label on the cap holder of the rotary/push button

7. Reattach the button (cap) of the rotary/push button at the glass front. In neutral position, the "Engel" writing on the button should be horizontal (see Fig. 42).



The lithium battery must only be replaced with the same type of battery or with a type of battery recommended by Kontron Europe GmbH. The type of the lithium battery must be UL listed.



Do not dispose of lithium batteries in general trash collection. Dispose of the battery according to the local regulations dealing with the disposal of these special materials, (e.g. to the collecting points for dispose of batteries).

9.2. Replacing the Emergency Stop Switch

The emergency stop switch consists of the button mounted in the front plate and the auxiliary switch block attached to the rear side of the button. To replace the particular components of the emergency stop switch, proceed as follows:

9.2.1. Replacing the Button of the Emergency Stop Switch

- **1.** Open the CC300 operator panel, as described in chapter 7.5.1 "Opening the CC300 Operator Panel", steps 1 to 5. The auxiliary switch block will thereby be removed from the pushbutton in step 4.
- **2.** Loosen and remove the plastic cap nut from the button of the emergency stop switch using an appropriate tool (see Fig. 43) and pull the button out (from the outside of the glass front).
- **3.** When inserting the new button, make sure that the large cut-out of the inner part of the button points in the direction of the red connector (see Fig. 43).
- **4.** Tighten the cap nut to a torque of 2.2 Nm.




Fig. 43: Button of the emergency stop switch

9.2.2. Replacing the Auxiliary Switch Block

The auxiliary switch block consists of four switch modules. Three of them are engaged next to each other on the mounting flange, the fourth switch module is engaged to the rear of the middle switch. By pressing the emergency stop switch, all four switches are operated simultaneously. To replace the switch modules, proceed as follows:

1. Open the CC300 operator panel, as described in chapter 7.5.1 "Opening the CC300 Operator Panel", steps 1 to 5. The auxiliary switch block will thereby be removed from the pushbutton in step 4 (see Fig. 27 and Fig. 28, Pos. 13).

2. Detach the switch modules from the mounting flange (and from each other respectively) by pushing the locks outwards with a small screwdriver (see Fig. 44).




Fig. 44: Dismantling the auxiliary switch block

3. The cables are fitted with fork type cable lugs which are fastened with screws to the switch modules (two cables per switch). Loosen the screws and pull the cables and the lugs out of the switch module. The individual modules can now be replaced (see Fig. 45).




Fig. 45: Switch module, cable, and mounting flange

- **4.** The new switch modules will be mounted in reversed order:
 - Attach the cable lugs to the switch modules and fasten the screws.
 - Attach the switch modules to the mounting flange (three modules will be attached next to each other directly to the mounting flange and the fourth module will be attached to the rear side of the middle module).
 - ☐ Close the CC300 operator panel as described in chapter 7.5.2 "Closing the CC300 Operator Panel".

9.3. Replacing the Rotary/Push Button

To replace the complete rotary/push button, proceed as follows:

1. Pull the button (cap) of the rotary/push button off of the glass front. The cap holder of the rotary/push button with three screws is now accessible from the outside (see Fig. 46, Fig. 47).



Fig. 46: Button (cap) of the rotary/push button

2. Remove three 2.5 mm (0.98 inch) Allen screws from the rotary/push button at the glass front (see Fig. 47).



Fig. 47: Unscrew the cap holder of the rotary/push button

- 3. Pull the rotary/push button and the CMOS battery carefully out of the front panel.
- 4. Remove the battery cable from the board of the rotary/push button (see Fig. 48)




Fig. 48: Rotary/push button and CMOS battery, pulled out of the housing

5. Removing the rotary/push button: Press the two arms of the cable lock together and pull the ribbon cable connector out.




Fig. 49: Removing the rotary/push button (shown with battery removed)

- **6.** Install the new rotary/push button module in reverse order:
 - Plug the ribbon cable into the connector of the rotary/push button board until it locks in place
 - Re-attach the battery cable to the rotary/push button board as a strain relief
 - ☐ Insert the battery and the rotary/push button into the opening of the front panel
 - Attach the holder of the rotary/push button so that the white label on the side of the cap holder is in top position (see Fig. 50).
 - ☐ Secure the rotary/push button with the 3 Allen screws removed in step 2. Fasten the screws to a torque of 0.32 Nm.




Fig. 50: Position of the label on the cap holder of the rotary/push button

7. Reattach the button (cap) of the rotary/push button at the glass front. In neutral position, the "Engel" writing on the button should be horizontal.

9.4. Replacing the Cable Gland

To replace the cable gland, proceed as follows:

- 1. Open the CC300 operator panel as described in chapter 7.5.1 "Opening the CC300 Operator Panel", steps 1 to 5. The bracket of the cable gland is located at the top inside the aluminum rear cover (see Fig. 28, Pos. 12).
- 2. Remove the four retaining screws that secure the cable gland bracket and the cable holder (strain relief) at the inside of the cabinet (see Fig. 51). The cable straps which secure the cables at the cable holder do not need to be removed!




Fig. 51: Remove screws of the cable gland bracket

3. Pull the cable gland and the cable gland bracket out of the cabinet while the cables are still inserted (see Fig. 52).




Fig. 52: Detached cable gland with bracket

4. Take the bracket out of the cable gland (with the cables still inserted). Later, the cables will be pulled out of the cable gland but the bracket will remain on the cables (see Fig. 53).




Fig. 53: Take the bracket out of the cable gland

5. Pull the cables out of the cable gland successively. Begin with the single cables with smaller connectors to obtain maximum space for the largest connector. Finally, pull the Harting connector out of the cable gland. The cable gland is now free and can be replaced. The cable gland bracket remains on the cables (see Fig. 54).




Fig. 54: Cables and cable gland bracket after removing the cable gland

- **6.** The new cable gland will be installed in reversed order:
 - ☐ Make sure that all cables are inserted through the ring of the cable gland bracket.
 - Thread the cables through the new cable gland. Start with the Harting connector. Only then thread the remaining cables through the cable gland. The cables must be inserted from the "thicker end" (the side ending with a ridge) into the cable gland so that they come out at the "thinner end" (neck between two ridges; see Fig. 55, Fig. 52).




Fig. 55: Insert cables from the thicker end into the cable gland

☐ Reinsert the bracket into the cable gland (see Fig. 56)



Fig. 56: Cable gland with inserted bracket (shown without cables)

Reattach the cable gland with the cable gland bracket to the cabinet by inserting the threaded
bolts of the bracket into the corresponding holes.
Put the cable holder (strain relief) onto the two upper threaded bolts from the inside of the rear
cover (see Fig. 51).
Fasten the four M4 nuts of the cable gland bracket to a torque of 1.3 Nm (see also Fig. 51).
Close the CC300 operator panel as described in chapter 7.5.2 "Closing the CC300 Operator Panel".

10. Technical Data

CC300 Operator Panel	Technical Data		
System	Customer-specific HMI panel PC with glass front		
Operating System	ENGEL LINUX x86 64bit		
Cooling Concept	Fanless system		
Cabinet	Front: glass front with aluminum frame, Rear: die cast aluminum cover		
Protection Class	IP 54 (entire system)		
Power Supply	24 V DC (see also chater 10.2 "Electrical Specifications")		
External Interfaces	See chapter 10.1 "External Connectors and Interfaces"		
Display	TFT LCD Display, 21.5", 1920x1080, 16:9 portrait format, multi-touch, contrast: 400:1, 16 million colors, brightness: 250 cd minimum, LED backlight, view angle: 85x85x85x85 minimum Optionally, an additional external display can be connected via DP cable		
Touch Screen	Capacitive PCAP multi-touch		
RFID	EM65 (Euromap Standard RFID ISO15693), 13.56 Mhz, read and write functionality, implementation for user login		
Emergency Stop Switch	Four (optional: six) emergency stop circuits (24V break circuits), switch is self-locking and can only be unlocked by turning the button		
Front Glass	Clear glass, thermally tempered, thickness: 5mm (+/- 0.2 mm), printed on the rear side, 5 capacitive buttons integrated in the glass, LED backlight for buttons and symbols		
Buttons in the Glass Front	Capacitive buttons (milled in the front glass) with LED backlight, partly with software-controlled color change when pressed		
Rotary/Push Button	Can be adjusted to the left/right to a maximum of 30 degrees, self-resetting when released, push button function, white backlit ring that can change its color to red, green and orange by software		
Mainboard	EXC-KLU 3965U		
CPU	Intel Celeron 3965U 2.2 GHz		
Memory	2GB (1 socket, SO DIMM, DDR3, 1.066 MHz)		
Drives	1x M.2, 30 GB (optional: 2.5" HDD/SSD via SATA, drive bay available)		
LAN	4x Ethernet 10/100/1000		
IO Board	EN01-0153 IO board, reverse voltage protection and short circuit protection		

10.1. External Connectors and Interfaces

Interface	Amount	Position	Data	
LAN cable	4	external	Type:Connector:Source:	10/100/1000 Mbit RJ45 CPU board & IO board
DP cable optional	1	external	Type:Connector:Source:	Display port DP (DisplayPort) CPU board
Power cable	1	external	Type:Connector:Source:	Power Connector Main Harting 24-pin I/O board
Emergency Stop circuits	1	external	Type:Connector:Source:	Control 8 wires in Harting connector Emergency Stop switch
USB Port	2	external	Type:Connector:Source:	USB 3.0 USB A CPU board
Grounding (PE) cable	1	external	Type:Connector:Source:	Functional Earth End-sleeve Chassis internal

10.2. Electrical Specifications

CC300 Operator Panel	Electrical Data		
Power Supply	24 V panel power supply => 24 VDC (+/- 20%), 3.5 A		
	24 VDC (+/- 20%), 3.5 A max.		
24V panel power supply	24 VDC (+/- 20%), 3.5 A max.		
24V power transformer (linear actuator)	24 VDC (+/- 20%), 3 A max.		
Component	Theoretical Value		
CPU Board (including Intel Celeron 3965U)	20	W	
LCD Panel	13	W	
SSD M.2	1.8	W	
I/O-Board	2	W	
RFID	1	W	
Rotary/push button	2	W	
USB internal 2x - power	1	W	
Total dissipated internal	40.8	W	
USB external 2x	9	W	
Linear actuator CAHB	44	W	
Total input power (including all possible loads)	93.8	W	

10.3. Environmental Specifications

Thermal Management	Passive Cooling (CPU and entire system)		
Operating Temperature	+5°C to 40°C (41°F to 104°F)		
Storage/Transit Temperature	-20°C to +60°C (-4°F to 140°F)		
Operating Rel. Humidity	5% to 93%, non-condensing		
Storage/Transit Rel. Humidity	5% to 93%, non-condensing		
Operating Altitude	0 m to 3000 m (0 ft. to 6560 ft.)		
Storage/Transit Altitude	0 m to 5000 m (0 ft. to 32800 ft.)		
Operating Shock	15 G, 11 ms duration, half-sine		
Storage/Transit Shock	30 G, 11 ms duration, half-sine		
Operating Vibration	5 Hz to 150 Hz, 0.5 G		
Storage/Transit Vibration	5 Hz to 150 Hz, 1.0 G		
Protection Class	IP54 (entire system)		

10.4. Mechanical Specifications

Dimensions	CC300 Operator Panel
Height	675 mm (26.57")
Width	346 mm (13.62")
Depth	76 mm (2.99")
Weight	13 kg (28.66 lbs)




Fig. 57: Dimensioned view of the CC300 glass front (print side - reversed image)




Fig. 58: Dimensioned rear and side view of the CC300 operator panel

10.5. International Compliance, Approvals and Certificates

CE-Mark	Electromagnetic Compatibility	Directive 2014/30/EU
Compliant	Low Voltage	Directive 2014/35/EU
with EU	Radio Equipment Directive (RED)	Directive 2014/53/EU
Directives	RoHS II	Directive 2011/65/EU
EMC 2014/30/EU Emission	EN 55011 / CISPR 11	Industrial, scientific and medical equipment - Radio- frequency disturbance characteristics - Limits and methods of measurement
	EN 61000-6-4	Electromagnetic compatibility (EMC), Part 6-4: Generic
	EN 55032 / CISPR 32	standards - Emission standard for industrial environment
EMC 2014/30/EU Immunity	EN 61000-6-2	Electromagnetic compatibility (EMC), Part 6-2: Generic standards- Immunity for industrial environment
EMC 2014/53/EU Article 3.1(b)	EN 301 489-1 V2.2.1	ElectroMagnetic Compatibility (EMC) standard for radio equipment and services; Part 1: Common technical requirements; Harmonised Standard covering the essential requirements of article 3.1(b) of Directive 2014/53/EU and the essential requirements of article 6 of Directive 2014/30/EU
	EN 301 489-3 V2.2.1	Electromagnetic compatibility and Radio spectrum Matters (ERM); ElectroMagnetic Compatibility (EMC) standard for radio equipment and services; Part 3: Specific conditions for Short-Range Devices (SRD) operating on frequencies between 9 kHz and 246 GHz
RF Spectrum Efficiency & Spurious Emission 2014/53/EU Article 3.2	EN 300 330 V2.1.1	Short Range Devices (SRD);Radio equipment in the frequency range 9 kHz to 25 MHz and inductive loop systems in the frequency range 9 kHz to 30 MHz; Harmonised Standard covering the essential requirements of article 3.2 of Directive 2014/53/EU
EMC	ANSI C63.4	The American National Standards Institute standard ANSI
CFR 47 Part	CISPR 16	C63.4 is the key standard for measuring electrical and
15, Subpart B & C	ICES-003	electronic equipment for showing compliance to FCC and Industry Canada regulations.
Safety	IEC 61010-1	Safety requirements for electrical equipment for
2014/35/EU	EN 61010-1	measurement, control and laboratory use - Part 1: General
	UL 61010-1	requirements.
	IEC 61010-2-201	Safety requirements for electrical equipment for
	EN 61010-2-201	measurement, control and laboratory use - Part 2-201: Particular requirements for control equipment.
	UL 61010-2-201	Tarticular requirements for control equipment.


Safety and Health 2014/35/EU 2014/53/EU Article 3.1(a)	EN 62479	Assessment of the compliance of low power electronic and electrical equipment with the basic restrictions related to human exposure to electromagnetic fields (10 MHz to 300 GHz).
WEEE 2002/96/EC	The Waste Electrical and Electronic Equipment Directive (WEEE Directive)	Compliant with the Waste Electrical and Electronic Equipment (WEEE) directive to reduce waste of electrical and electronic equipment, encourage recycling and environmental disposal and increase the environmental awareness of producers.

61

11. Interfaces – Pin Assignments

Low-active signals are indicated by a minus sign.

11.1.1. Harting Connector





24-pole Harting connector (Type Harting HAN 24 E, wire cross section: AWG 18)


Pin No.	Wire No.	Signal Name	Pin	Wire No.	Signal Name	
Pin 1	8	Emergency Stop channel 1 - 1	Pin 13	12	Emergency Stop channel 1 - 2	
Pin 2	9	Emergency Stop channel 2 - 1	Pin 14	13	Emergency Stop channel 2 - 2	
Pin 3	10	Emergency Stop channel 3 - 1	Pin 15	14	Emergency Stop channel 3 - 2	
Pin 4	11	Emergency Stop channel 4 - 1	Pin 16	15	Emergency Stop channel 4 - 2	
Pin 5		Emergency Stop channel 5 - 1 (not implemented)			Emergency Stop channel 5 - 2 (not implemented)	
Pin 6		Emergency Stop channel 6 - 1 (not implemented)	Pin 18		Emergency Stop channel 6 - 2 (not implemented)	
Pin 7	6	24V panel power supply	Pin 19	5	5 OV panel power supply	
Pin 8	4	24V power transformer (linear actuator)	Pin 20	3	0V power transformer (linear actuator)	
Pin 9	7	Power transformer switch-off	Pin 21	16	Dig In 1	
Pin 10		free	Pin 22		free	
Pin 11		free	Pin 23		free	
Pin 12		free	Pin 24		free	
		Connector grounding (lateral)		•		

11.1.2. LAN 0, LAN 2 and LAN 3 Cable

Pin	Signal Name	Standard Modular Plug (RJ45)
1	MDI0+	8
2	MDI0-	
3	MDI1+	
4	MDI2+	EIA/TIA-568B
5	MDI2-	
6	MDI1-	
7	MDI3+	
8	MDI3-	

(The LAN cable is connected to the LAN 0 port of the mainboard and led out of the cabinet.)

11.1.3. LAN 1 Cable



(The LAN extension cable is connected to the LAN 1 port of the mainboard and led out of the cabinet.)

11.1.4. DP Connector (Standard: DisplayPort 1.2)

Pin	Signal Name	20-pin DP Connector
1	ML LANE 0+	
2	GND (ML LANE 0)	16.10
3	ML LANE 0-	PN 19 9.00 PIN 1
4	ML LANE 1+	
5	GND (ML LANE 1)	S THE SECOND STATE OF THE
6	ML LANE 1-	PN 20
7	ML LANE 2+	1.54 0.00 PIN 2
8	GND (ML LANE 2)	825 REF 16.50
9	ML LANE 2-	
10	ML LANE 3+	
11	GND (ML LANE 3)	
12	ML LANE 3-	
13	AUX_SEL#	
14	Pull-down to GND	
15	AUX CH+	
16	GND (AUX CH)	
17	AUX CH-	
18	Hotplug	
19	GND (GND_DDC)	
20	+3.3V (DDC EEPROM power) 750mA fused	
		phoand and can be entionally led out of the cabinet via DP cable or

(The DisplayPort is located on the mainboard and can be optionally led out of the cabinet via DP cable or DP extension cable.)

11.1.5. USB Ports

	USB 2.0 contact pins		USB 3.0 contact pins	9-pin USB Connector Type A Version 3.0/2.0
Pin	Signal Name	Pin	Signal Name	Type A Version 5.0/2.0
1	VCC, fused (900 mA max.)	5	StdA_SSRX-	
2	Data-	6	StdA_SSRX+	9 8 7 6 5
3	Data+	7	GND_DRAIN	
4	GND	8	StdA_SSTX-	
		9	StdA_SSTX+	

The two externally accessible USB 3.0 ports are connected to the mainboard via cable. The 5V outputs are electronically fused. Each port supports up to 900mA.

11.1.6. Grounding Cable (PE)

	Grounding Cable (PE)
Cross section: 6mm ²	
Cable color: Yellow/green	0.2 - 3.5
Connector: End sleeve 6.0mm ² /12mm	20