

Intertek 731 Enterprise Drive Lexington, KY 40510

Tel 859 226 1000 Fax 859 226 1040

www.intertek.com

Midmark Corporation SAR EXEMPTION REPORT

SCOPE OF WORK

SAR EXEMPTION CALCULATION ON THE WIRELESS FOOT CONTROL

REPORT NUMBER 105489075LEX-001ccc

ISSUE DATE 7/18/2024

PAGES 10

DOCUMENT CONTROL NUMBER Non-Specific EMC Report Shell Rev. December 2017 © 2017 INTERTEK





SAR EXEMPTION TEST REPORT

Report Number:105489075LEX-001cccProject Number:G105489075Report Issue Date:7/18/2024Product Name:Wireless Foot Control
Model 029-3929-03Standards:FCC Part 2.1093

RSS-102 Issue 6

Tested by: Intertek Testing Services NA, Inc. 731 Enterprise Drive Lexington, KY 40510 USA Client: Midmark Corporation 60 Vista Dr. Versailles, OH 45342 USA

Report prepared by

Ai to

Brian Lackey, Staff Engineer

Report reviewed by

Michael aulam

Michael Carlson, Team Leader

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to copy or distribute this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.



Table of Contents

1	11	ntroduction and Conclusion	
2	T	est Summary4	
3	С	Client Information	
4	D	Description of Equipment under Test and Variant Models	
	4.1 4.2	Variant Models:	
5	F	CC SAR Exemption Criteria	,
6	- 19	SED SAR Exemption Criteria	
7	R	20 Revision History	



1 Introduction and Conclusion

SAR exemption calculations were performed on the product constructed as described in section 4. Information provided by the client including maximum output power, antenna gain(s), and minimum separation distance(s) was used to determine if the product under evaluation was exempt from SAR. Any change in these stated values may invalidate these results. No additions, deviations, or exclusions have been made from the standard(s) unless specifically noted.

Based on the results of our investigation, we have concluded the product under evaluation is **exempt** from SAR requirements for each of the standard(s) indicated. The results obtained in this test report pertain only to the item(s) evaluated. Intertek does not make any claims of compliance for samples or variants which were not evaluated.

2 Test Summary

Section	Requirement	Result
5	FCC SAR Exemption Criteria	Exempt from SAR
	(FCC TITle 47 CFR Part 1.1307, 2.1093)	
6	ISED SAR Exemption Criteria (RSS-102 Issue 6)	Exempt from SAR



3 Client Information

This product was tested at the request of the following:

Client Information			
Client Name:	Midmark Corporation		
Address:	60 Vista Dr.		
	Versailles, OH 45342		
	USA		
Contact:	Nick Stammen		
Telephone: +1 (973) 528-7546			
Email:	nstammen@midmark.com		
	Manufacturer Information		
Manufacturer Name:	Midmark Corporation		
Manufacturer Address: 60 Vista Dr.			
	Versailles, OH 45342		
	USA		



4 Description of Equipment under Test and Variant Models

Equipment Under Test					
Product Name	Wireless Foot Control				
Model Numbers 029-3929-03					
Hardware Version 015-2084-01					
Rated Voltage 3VDC, 2xAA batteries					
Frequency Band(s)	2400 – 2483.5MHz				
Test Channel(s)	2405MHz, 2445MHz, 2475MHz				
Maximum Antenna Gain (dBi) ¹	0.47 dBi				
Description of Equipment Under Test (provided by client)					
The wireless foot control allows the user to energize the motor(s) of the chair/table to move the orientation of					
the chair/table.					

4.1 Variant Models:

There were no variant models covered by this evaluation.

4.2 Maximum Output Power

The maximum peak conducted output power was measured and reported in Intertek report 105489075LEX-001bbb:

Frequency (MHz)	Receiver Reading (dBm)	Receiver Reading (dBuV)	Antenna Factor (dB/m)	Cable Loss (dB)	E Field (dBuV/m)	EIRP (dBm)
2405	-54.19	52.80	32.5	8.0	93.30	-1.93
2445	-56.20	50.79	32.5	8.0	91.29	-3.94
2475	-56.07	50.92	32.5	8.0	91.42	-3.81

Frequency (MHz)	EIRP (dBm)	Antenna Gain (dBi)	Conducted Output Power / PSD (dBm)
2405	-1.93	0.47	-2.40
2445	-3.94	-0.29	-3.65
2475	-3.81	-2.83	-0.98

¹ Values were taken from ezurio report "Midmark Controllers 2024-03-25.xlsx" provided by the client. Deviations from these values may affect compliance. Intertek does not make any claims of compliance for values other than those shown.



5 FCC SAR Exemption Criteria

FCC Title 47 CFR Part 1.1307(3)(i):

For single RF sources (i.e., any single fixed RF source, mobile device, or portable device, as defined in paragraph (b)(2) of this section): A single RF source is exempt if:

- (A) The available maximum time-averaged power is no more than 1 mW, regardless of separation distance. This exemption may not be used in conjunction with other exemption criteria other than those in paragraph (b)(3)(ii)(A) of this section. Medical implant devices may only use this exemption and that in paragraph (b)(3)(ii)(A);
- (B) Or the available maximum time-averaged power or effective radiated power (ERP), whichever is greater, is less than or equal to the threshold Pth (mW) described in the following formula. This method shall only be used at separation distances (cm) from 0.5 centimeters to 40 centimeters and at frequencies from 0.3 GHz to 6 GHz (inclusive). Pth is given by:

$$P_{th} (mW) = \begin{cases} ERP_{20 \ cm} (d/20 \ cm)^x & d \le 20 \ cm \\ ERP_{20 \ cm} & 20 \ cm < d \le 40 \ cm \end{cases}$$

Where

$$x = -\log_{10}\left(\frac{60}{ERP_{20\ cm}\sqrt{f}}\right) \text{ and } f \text{ is in GHz};$$

and

$$ERP_{20 \ cm} \ (\text{mW}) = \begin{cases} 2040f & 0.3 \ \text{GHz} \le f < 1.5 \ \text{GHz} \\ \\ 3060 & 1.5 \ \text{GHz} \le f \le 6 \ \text{GHz} \end{cases}$$

d = the separation distance (cm);

FCC KDB 447498 D04 Interim General RF Exposure Guidance v01 § 2.1.1:

Finally, when 10-g extremity SAR applies, SAR test exemption may be considered by applying a factor of 2.5 to the SAR-based exemption thresholds.

The maximum output power was determined to be -0.98 dBm or 0.797 mW. Since the output power is less than 1 mW, the device is exempt from SAR requirements.

6 ISED SAR Exemption Criteria

RSS-102 Issue 6 § 6.3: SAR exemption limits

Devices operating at or below the applicable output power levels (adjusted for tune-up tolerance) specified in table 11, based on the separation distance, are exempt from SAR evaluation. The separation distance, defined as the distance between the user and/or bystander and the antenna and/or radiating element of the device or the outer surface of the device, shall be less than or equal to 20 cm for these exemption limits to apply.

Frequency (MHz)	≤ 5 mm (mW)	10 mm (mW)	15 mm (mW)	20 mm (mW)	25 mm (mW)	30 mm (mW)	35 mm (mW)	40 mm (mW)	45 mm (mW)	> 50 mm (mW)
≤ 300	45	116	139	163	189	216	246	280	319	362
450	32	71	87	104	124	147	175	208	248	296
835	21	32	41	54	72	96	129	172	228	298
1900	6	10	18	33	57	92	138	194	257	323
2450	3	7	16	32	56	89	128	170	209	245
3500	2	6	15	29	50	72	94	114	134	158
5800	1	5	13	23	32	41	54	74	102	128

Table 11: Power limits for exemption from routine SAR evaluation based on the separation distance

The exemption limits in Table 11 are based on measurements and simulations of half-wave dipole antennas at separation distances of 5 mm to 50 mm from a flat phantom, which provides a SAR value of approximately 0.4 W/kg for 1 g of tissue.

For limb-worn devices where the 10 gram of tissue applies, the exemption limits for routine evaluation in table 11 are multiplied by a factor of 2.5.

For controlled-use devices where the 8 W/kg for 1 gram of tissue applies, the exemption limits for routine evaluation in table 11 Table 11 are multiplied by a factor of 5.

When the operating frequency of the device is between two frequencies located in table 11, linear interpolation shall be applied for the applicable separation distance. If the separation distance of the device is between two distances located in table 11, linear interpolation may be applied for the applicable frequency. Alternatively, the limit corresponding to the smaller distance may be employed. For example, in case of a 7 mm separation distance, either use the exception value for a 5 mm separation distance or interpolate between the limits corresponding to 5 mm and 10 mm separation distances.

For implanted medical devices, the exemption limit for routine SAR evaluation is set at an output power of 1 mW, regardless of frequency.

The SAR levels from exempted transmitters shall be included in the compliance assessment and the determination of the TER. Detailed guidance is included in sections 7.1.8 and 8.2.2.1.



RF Source	Frequency (GHz)	Separation Distance (mm)	Output Power (mW)	P _{th} (mW)	Exempt from SAR?
Zigbee Radio	2.475	5	0.797	7.5	Yes

$$SAR_{estimated} = rac{P_{max}}{P_{max,exemption}} imes 0.25 imes SAR_{limit} W/kg$$
 (2)

SAR_{estimated} = (0.797 mW) / (7.5 mW) x 0.25 x 4 W/kg = 0.106 W/kg



7 Revision History

Revision Level	Date	Report Number	Prepared By	Reviewed By	Notes
0	7/18/2024	105489075LEX-001ccc	BB	MC	Original Issue