

Product Information and Regulatory Statement

Important Safety Information - Read First!

Before installing, configuring, or operating any equipment, all relevant technical documentation must be read, understood, and followed. Savant technical documentation may contain important product-specific installation, mounting, and safety instructions, and can be accessed through the Savant Store.

Scan the QR code or visit the URL below, enter the relevant product name or SKU in the **Search Savant** prompt, and select the product purchased to find documents, specifications and more.

https://store.savant.com/DefaultStore/ccrz__HomePage



Safety Statements

All safety instructions below must be read, understood, and carefully followed under all applicable circumstances when working with any Savant equipment.

1. Follow all input power ratings marked on product near power input!
2. If fuse replacement is required, replacement fuse should match fuse rating marked on the product.
3. Do not use equipment near water.
4. Clean only with dry cloth.
5. Do not block any ventilation openings or install near any heat sources such as heat registers, stoves, radiators, amplifiers, etc.
6. Refer all servicing to qualified service personnel. Servicing is required when any part of the apparatus has been damaged in any way, or fails to operate normally for any reason.
7. Use only attachments/accessories specified by the manufacturer, following all relevant safety precautions for any such attachments/accessories.
8. For applicable equipment, use the included power cord with the grounding prong intact to insure proper grounding of the device.
9. If the provided plug does not fit the desired outlet, contact a licensed electrician to replace the obsolete outlet.
10. Protect any power cord from being walked on, pinched, strained, or otherwise potentially damaged, especially at the outlet or device connections.
11. Disconnect any outlet powered apparatus from its power source during lightning storms or when unused for long periods of time.
12. To completely disconnect equipment from AC mains power, disconnect the power supply cord plug from the AC receptacle on the device.
13. For any hardwired or fixed in-wall apparatus, carefully follow all wiring diagrams and instructions. All electrical wiring and servicing should be performed by a properly licensed electrician.

Déclarations de Sécurité

Toutes les instructions de sécurité ci-dessous doivent être lues, comprises et soigneusement suivies dans toutes les circonstances applicables lorsque vous travaillez avec un équipement Savant.

1. Suivez toutes les puissances nominales indiquées sur le produit près de la puissance absorbée!
2. Si le remplacement du fusible est nécessaire, le fusible de remplacement doit correspondre à la valeur nominale du fusible indiquée sur le produit.
3. N'utilisez pas d'équipement près de l'eau.
4. Nettoyer uniquement avec un chiffon sec.
5. Ne bloquez pas les ouvertures de ventilation et n'installez pas à proximité de sources de chaleur telles que les registres de chaleur, les cuisinières, les radiateurs, les amplificateurs, etc.
6. Confiez toutes les réparations à un technicien qualifié. Un entretien est requis lorsqu'une partie de l'appareil a été endommagée de quelque manière que ce soit ou ne fonctionne pas normalement pour une raison quelconque.
7. Utilisez uniquement les attachements / accessoires spécifiés par le fabricant, en suivant toutes les précautions de sécurité applicables à ces attachements / accessoires.
8. Pour l'équipement applicable, utilisez le cordon d'alimentation inclus avec la broche de mise à la terre intacte pour assurer une mise à la terre correcte de l'appareil.
9. Si la fiche fournie ne correspond pas à la prise souhaitée, contactez un électricien agréé pour remplacer la prise obsolete.
10. Protégez tout cordon d'alimentation contre les piétinements, les pincements, les tensions ou autres dommages potentiels, en particulier au niveau de la prise ou des connexions de l'appareil.
11. Débranchez tout appareil alimenté par une prise de courant de sa source d'alimentation pendant les orages ou lorsqu'il n'est pas utilisé pendant de longues périodes.
12. Pour déconnecter complètement l'équipement du secteur, débranchez la fiche du cordon d'alimentation de la prise secteur de l'appareil.
13. Pour tout appareil encastré ou câblé, suivez attentivement tous les schémas de câblage et les instructions. Tout le câblage électrique et l'entretien doivent être effectués par un électricien dûment agréé.



IMPORTANT NOTES:

- For product mounting, installation, safety instructions, technical specifications, and more, refer to the product Quick Reference Guide, available via the link or QR code noted above.
- For regulatory and compliance information, see reverse of this sheet and/or product packaging.

FCC Regulations

This device complies with part 15 of the FCC Rules. Operation is subject to the following two conditions:

1. This device may not cause harmful interference, and
2. This device must accept any interference received, including interference that may cause undesired operation.

This equipment has been tested and found to comply with the limits for CLASS B digital devices, pursuant to Part 15 of FCC Rules. These limits are designed to provide reasonable protection against harmful interference when the equipment is operated in a residential installation. This equipment generates, uses and can radiate radio frequency energy and, if not installed and used in accordance with the instructions, may cause harmful interference to radio communications. If this equipment does cause harmful interference to radio or television reception, which can be determined by turning the equipment off and on, the user is encouraged to try correcting the interference with one or more of the following measures:

- Reorient or relocate the receiving antenna.
- Increase the separation between the equipment and the receiver.
- Connect this equipment to an outlet on a circuit different from that to which the receiver is connected.
- Consult the dealer or an experienced radio/TV technician for help.

FCC Caution

Any changes or modifications not expressly approved by the party responsible for compliance could void the user's authority to operate this equipment. This transmitter must not be co-located or operating in conjunction with any other antenna or transmitter.

Radiation Exposure Statement - Wireless and Handheld Devices Only

This equipment complies with FCC and IC radiation exposure limits set forth for an uncontrolled environment. This equipment should be installed and operated with minimum distance of 20 cm between the radiator and your body.

FCC and IC Identifier - Devices with Integrated Screen or User Interface Only

This device electronically displays the FCC declaration of conformity logo as well as the FCC and IC identifier. This information can be found on the device by accessing:

(Service menu) > About (A propos de)



IC Statement

This device complies with Industry Canada license-exempt RSS standard(s). Operation is subject to the following two conditions:

1. This device may not cause interference, and
2. This device must accept any interference, including interference that may cause undesired operation of the device.

This Class B digital apparatus complies with Canadian ICES-003/NMB-003.

This device complies with RSS-247 of Industry Canada. Operation is subject to the condition that this device does not cause harmful interference.

This device and its antenna(s) must not be co-located or operating in conjunction with any other antenna or transmitter, except tested built-in radios. The Country Code Selection feature is disabled for products marketed in the US/Canada.

Déclaration IC

Le présent appareil est conforme aux CNR d'Industrie Canada applicables aux appareils radio exempts de licence. L'exploitation est autorisée aux deux conditions suivantes:

1. L'appareil ne doit pas produire de brouillage, et
2. Cet appareil accepter toute interférence, y compris les interférences pouvant provoquer fonctionnement indésirable d'appareil.

Déclaration d'exposition aux radiations

Cet équipement est conforme aux limites d'exposition aux radiations de la FCC définies pour un environnement non contrôlé. Cet équipement doit être installé et utilisé avec une distance minimale de 20 cm entre le radiateur et votre corps.

Identificateur de la FCC et d'IC

Ce périphérique par voie électronique affiche le logo de déclaration de conformité FCC ainsi que l'identificateur de la FCC et d'IC. Cette information peut être trouvée sur le terminal en accédant à:

(Menu de service) > About (A propos de)



SAVANT

Dual 24V DC Control Relay Companion Module Quick Reference and Installation Guide


Box Contents

- (1) Dual 24V DC Control Relay Companion Module
 - GPM-QP2PWL-21 QO™ w/Plug-on Neutral
 - GPM-Q2PWL-21 QO™ w/Pigtail
- (1) Product Information and Regulatory Insert (009-1950)
- (1) Quick Reference and Installation Guide (this document)

Specifications

Environmental				
Temperature	32° to 104° F (0° to 40° C)			
Humidity	5% to 85% Relative Humidity (non-condensing)			
Location	Indoor Use Only			
Dimensions and Weights				
	Height	Width	Depth	Weight
Module (QO)	1.48 in. (3.76 cm)	4.97 in. (12.63 cm)	2.60 in. (6.61 cm)	.5 lbs (.23 kg)
Shipping	1.71 in. (4.34 cm)	7.50 in. (19.05 cm)	4.30 in. (10.92 cm)	1.0 lbs. (.45 kg)
Power				
Input Power (powers the module)	120V AC (+/- 10%) @ 60 Hz, 0.1A (max)			
Input Power (voltage feed from a plug-on power supply)	24V DC / 10A (max)			
Output Power	24V DC (10A per output)			
Features of Automatic Action	Type 1.B action			
Standards				
Wireless	Bluetooth 5 Low Energy (BLE) - 2.4 GHz radio frequency			
Regulatory				
Safety and Emissions	FCC Part 15	UL	ICES 003	
				
Contains FCC ID:	PUU-QP2PWL			
Contains IC:	10798A-QP2PWL			
RoHS	Compliant			
Recommended Load Center Types				
All QO™ compatible modules fit into ¾ inch load centers.				
Supported Load Types				
Standard Configuration	Relay On/Off type loads (home automation)			
Electrical and Safety Characteristics				
Tighten Torque	3.0 Nm			
Wire Type	Copper (Cu) only			
Pollution Degree	2			
Purpose of Control	Operating Control, Smart Relay Control Module or the equivalent.			
Software	Class A			
Impulse Voltage	2500V			
Construction of Control				
Open Type	Independently mounted for flush mounting.			
Supported Software				
Savant OS	da Vinci 10.2			

Descriptions



- A

Multi-Page LCD screen that can display the following:

 - Firmware, Mac Address, and Regulatory Info.
 - UID of the Host that the module is communicating with.
 - Real-time Bluetooth status connectivity icon.
 - Real-time status of the outputs.
- B

Manual Load Switches - Toggle to the ON position to apply 24V DC to outputs A, B, or both. Toggle to AUTO for normal operation. Switch A controls output A, Switch B controls output B.
- C

PAIR Button - The PAIR button is a multi-use button. The duration that the button is pressed and held determines the function that gets initiated:

Press and Release - Cycles through the screens available on the LCD (INFO 1 > INFO 2).

Press and hold - Press and hold for 2 seconds to put the module into pairing mode. Press and hold for 5 seconds to reset the module. The pairing status stays intact after reset.
- D

Input Power Connections - Connect the outputs from a 24V DC source such as the QOPLPS to inputs A and B on the module. See the [Wiring](#) section below.
- E

Output Power Connections - Connect output A and output B to the control wire on a remote controlled breaker. See the [Wiring](#) section below.
- F

120V AC Connection - Plugs into the 120V AC bus bar in the breaker panel. The voltage at this connection powers the module.
- G

Neutral - The model number of the module determines the type of neutral connection on the module.

 - **Plug-On Neutral Clip (not seen in diagram)** - Plugs into the plug-on neutral bar in the breaker panel.
 - **Pigtail Neutral** - A neutral wire protrudes from the module's rear and gets wired to the neutral bar in the breaker panel.

Features

- Can switch On and Off a Powerlink remotely controlled breaker.
- All QO™ style relay modules are compatible with Schneider/Electric Square D™ QO™ load centers.
- Dynamic remote management of loads.
- Communicates over the air using Bluetooth Low Energy (BLE) technology.
- Two load switches on the front panel can manually toggle the power to outputs A and B.
- Color LCD display for easy identification and load status.

Important Information

- A separate 240V AC to 24V DC power supply such as the Schneider electric QOPLPS is needed. This power supply feeds the module with the required 24V DC.
- Each relay output can switch up to 10 amps.
- To determine the number of spaces needed in each panel, add the number of spaces required for each device described below.
 - Each QOPLPS power supply requires two spaces.
 - Each relay module requires two spaces.
 - Each Powerlink remote controlled breaker requires two spaces.
- Savant recommends not connecting any mission-critical loads such as medical devices when interfacing with this module.

- **ELECTRIC SHOCK!** The 120V AC, 60 Hz source poses an electrical shock hazard that has the potential to cause serious injury to installers and end users.
- **CAUTION!** Risk of Electric Shock - More than one disconnect switch may be required to de-energize the device before servicing.
- **IMPORTANT!** A licensed electrician is required to install any of Savant's Relay Companion Modules.

Branch Circuit Minimum Size of Conductors (General circuit wiring, Copper Conductors)					
15A	20A	30A	40A	50A	60A
#14 AWG	#12 AWG	#10 AWG	#8 AWG	#6 AWG	#4 AWG


NOTE: This wiring requirement was based on the National Electric Code (NEC) (ANSI/NFPA70), Canadian Electric Code, Part 1 (CEC), and local codes Minimum Size of Conductors.

Installation into a Breaker Panel

1. Switch off the breaker panel’s main breaker so no power is supplied to the panel.
 2. Position and install the QOPLPS power supply into the slots where it will be installed in the inCharge Module Panel. Press firmly until the power supply is seated onto the appropriate bus bars.
 3. Position and install the Relay Module into appropriate slot. Press firmly until fully seated onto the appropriate bus bars. This relay module is typically installed in the same panel as the power supply installed in step 2 above.
 4. Position and install the Powerlink remotely controlled breaker into one of the slots in the main electrical panel. Press firmly until the breaker is fully seated onto the appropriate bus bars.
- **HELPFUL!** The Powerlink remotely controlled breaker is typically installed in a separate electrical panel that is set up to accommodate all remotely controlled circuit breakers.
5. Make connections. Refer to the [Wiring](#) section on the next page.

Wiring

Use the diagram below when making connections between the module, associated breakers, and load(s). Additional wiring diagrams are available in the **Savant Panelized Lighting Deployment Guide** available on the [Savant Community](#).



- **IMPORTANT!**
- When making connections, observe all general electrical practices including local wire sizing guidelines. See the **Branch Circuit Minimum Size of Conductors** table on the previous page.
 - The GPM-Q2PWL-21 module was designed for breaker panels that don't contain a plug-on neutral bar. This module contains a neutral wire that gets wired to the neutral bar in panels that don't have a plug-on type neutral bar.

Additional Documentation

- Panel Bridge Controller with PoE (PBC-P1000) QRG
- Savant Panelized Lighting Deployment Guide