

Calibration certificates RISE equipment used for test report P110766-F30

|                                      | Serial number on equipment            | RISE number | File name/<br>Page number           |
|--------------------------------------|---------------------------------------|-------------|-------------------------------------|
| R&S FSW 43                           | 100 560                               | 902 073     | 902 073 -<br>FSW43.pdf              |
| R&S ESU 40                           | 100 321                               | 901 385     | 901 385 -<br>ESU40.pdf              |
| R&S ZNB 40                           | 101 544                               | BX50051     | BX50051 -<br>ZNB40.pdf              |
| Mixer FS-Z60                         | 100 996                               | BX90566     | BX90566<br>R&S Mixer<br>FS-Z60.pdf  |
| Mixer FS-Z110                        | 101 467                               | BX81425     | BX81425<br>R&S Mixer<br>FS-Z110.pdf |
| Bilog antenna Schaffner 6143A        | 23 169                                | 504 079     | 2 – 9                               |
| EMCO Horn Antenna 3115               | 9509-4562                             | 502 175     | 10 – 16                             |
| EMCO Horn Antenna 3115               | 00143 161                             | 902 212     | 17 – 21                             |
| EMCO Horn Antenna 3116               | 9904-2426                             | 503 279     | 22 – 28                             |
| Mixer FS-Z90                         | 101 871                               | BX90567     | 29 – 35                             |
| Flann STD Gain Horn Antenna 20240-20 | Manufacturer provided gain<br>275170  | KWP02600    | 36                                  |
| Flann STD Gain Horn Antenna 22240-20 | Manufacturer provided gain<br>274184  | KWP02601    | 37                                  |
| Flann STD Gain Horn Antenna 24240-20 | Manufacturer provided gain<br>141     | BX92414     | 38                                  |
| Flann STD Gain Horn Antenna 26240-20 | Manufacturer provided gain<br>124 440 | BX92416     | 39                                  |
| Flann STD Gain Horn Antenna 27240-20 | Manufacturer provided gain<br>281     | BX92417     | 40                                  |



# Certificate of Calibration



0478

## BICONICAL-LOG HYBRID ANTENNA

Model: Teseq CBL 6143A

Serial number: 23169

*This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.*

**FOR:**

RISE  
Brinellgatan 4  
SE-504 62 BORÅS  
Sweden

Order no. IX84237

**DESCRIPTION:**

Teseq CBL 6143A biconical-log hybrid antenna with an operating frequency range of 30 MHz to 3000 MHz. The low frequency elements were of a modified triangular type (L-shaped).

**IDENTIFICATION:**

The antenna is marked with the manufacturer's serial number 23169. The antenna was calibrated with the customer supplied 6 dB attenuator attached, with the customer number BX61531.

**MEASUREMENTS COMPLETED ON:**

4 July 2018

The reported uncertainty is based on a coverage factor  $k=2$ , providing a level of confidence of approximately 95%

**Reference : 2018050459-1**

**Page 1 of 8**

**Date of Issue : 4 July 2018**

**Signed :**

**(Authorised Signatory)**

**Checked by :**

**Name : D A Knight**

**on behalf of NPLML**



*This certificate is consistent with the capabilities that are included in Appendix C of the MRA drawn up by the CIPM. Under the MRA, all participating institutes recognise the validity of each other's calibration and measurement certificates for the quantities, ranges and measurement uncertainties specified in Appendix C (for details see <http://www.bipm.org>).*

## MEASUREMENT PROCEDURE

### Antenna Factor

The measurement method is traceable to field standards which have been validated on the national standard open field site (OFS) at NPL. The OFS comprises a 60 m by 30 m metal ground plane, flat to within  $\pm 6$  mm. The receiver linearity has been calibrated, traceable to national standards, and its frequency accuracy has been shown to be better than 10 ppm. On request a complete set of antenna factors, and the complex components of the reflection coefficient can be supplied in ASCII format by email.

The antenna was positioned in the configuration required for each measurement, and where necessary the RF cables were supported in order to minimise parasitic reflections. A summary of the applicable parameters for each measurement is given below. Each summary refers to a later table which contains a subset of results, and the accompanying graphs present the full data set.

The antenna was calibrated according to ANSI C63.5 (see Annex) as one of three antennas, which were calibrated by the height scanning method described in the procedure. The customer's antenna is defined as the Antenna Under Test (AUT). The other antenna in any pair is defined as ANT2. HP and VP are horizontal and vertical polarisation respectively.

#### Summary of applicable parameters in Table 1

|                           |                                                                                                                        |
|---------------------------|------------------------------------------------------------------------------------------------------------------------|
| Measurement range         | From 30 MHz to 1000 MHz                                                                                                |
| Measurement parameter     | ANSI C63.5:2017 10.0 m separation,<br>AUT Scanned (1.0 m - 4.0 m), ANT2 at HP 2.0 m<br>Near Free Space Antenna Factors |
| Measurement uncertainty * | $\pm 1.0$ dB                                                                                                           |

- \* The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k = 2$ , providing a coverage probability of approximately 95 %. The uncertainty evaluation has been carried out in accordance with UKAS requirements. The uncertainty applies only to the measured values and gives no indication of the long term stability of the antenna. See annex concerning exemptions to the stated uncertainty.

### Balance Test (applies to frequencies below 300 MHz - see Annex)

This test indicated no significant balun imbalance.

The balun balance was measured according to ANSI C63.5:2017, with an estimated expanded uncertainty of  $\pm 0.25$  dB.

The antenna was positioned in a near free-space environment and the complex reflection coefficient,  $S_{11}$ , was measured. The result is presented as return loss and VSWR. The estimated uncertainty in the measured reflection coefficient is  $\pm 0.05$  units.

During calibration NPL uses good quality matching attenuators on the transmit and receive cables, which ensure a return loss better than 10dB. In order to meet the CISPR 16-1-4 requirement for emission measurements a calibrated attenuator should be used on the receive cable to ensure a minimum match of 10dB. When requested NPL will calibrate the antenna with a supplied attenuator attached and the attenuation will be included in the antenna factor and the measured return loss. Alternatively, if no attenuator is supplied, the calibrated value of the attenuator may be included in the loss of the receive cable. ANSI C63.4:2014 requires a match of 2.5:1 VSWR, which equates to a return loss of 7.4dB; it is possible to meet this requirement with a 4dB attenuator. It is recommended to use a 6dB attenuator for hybrid or biconical antennas which have a poor match at 30MHz.

The measuring equipment was in a temperature controlled room at  $22^{\circ}\text{C} \pm 2^{\circ}\text{C}$ . In our experience there is no significant variation in the performance of passive antennas in the temperature range  $-5^{\circ}\text{C}$  to  $+35^{\circ}\text{C}$ .

The annex describes some sources of possible measurement uncertainty when biconical-log hybrid antennas are used for emission testing. The antenna factor uncertainty and any additional measurement uncertainty can be combined by following the guidance given by UKAS[1].

- [1] The expression of uncertainty in EMC testing, LAB 34, UKAS, August 2002.
- [2] The annex for the biconical-log hybrid antenna can be found on the NPL website, [www.npl.co.uk](http://www.npl.co.uk), search on "Antennas and Field Probes support documentation" with the address <http://www.npl.co.uk/emc-certificates>

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

| Table 1<br>ANSI C63.5:2017 10.0 m separation,<br>AUT Scanned (1.0 m - 4.0 m), ANT2 at HP 2.0 m<br>Teseq CBL 6143A, s/n 23169 |                          |                 |                          |
|------------------------------------------------------------------------------------------------------------------------------|--------------------------|-----------------|--------------------------|
| Frequency (MHz)                                                                                                              | Antenna Factor<br>(dB/m) | Frequency (MHz) | Antenna factor<br>(dB/m) |
| 30                                                                                                                           | 28.4                     | 520             | 23.1                     |
| 40                                                                                                                           | 23.4                     | 540             | 24.1                     |
| 60                                                                                                                           | 16.1                     | 560             | 24.5                     |
| 80                                                                                                                           | 13.3                     | 580             | 24.4                     |
| 100                                                                                                                          | 16.0                     | 600             | 24.4                     |
| 120                                                                                                                          | 18.7                     | 620             | 24.6                     |
| 140                                                                                                                          | 18.4                     | 640             | 24.9                     |
| 160                                                                                                                          | 16.6                     | 660             | 24.6                     |
| 180                                                                                                                          | 16.2                     | 680             | 24.7                     |
| 200                                                                                                                          | 17.5                     | 700             | 24.7                     |
| 220                                                                                                                          | 18.5                     | 720             | 25.0                     |
| 240                                                                                                                          | 17.8                     | 740             | 25.3                     |
| 260                                                                                                                          | 18.5                     | 760             | 25.5                     |
| 280                                                                                                                          | 18.7                     | 780             | 25.9                     |
| 300                                                                                                                          | 19.2                     | 800             | 25.7                     |
| 320                                                                                                                          | 19.6                     | 820             | 25.8                     |
| 340                                                                                                                          | 19.7                     | 840             | 26.1                     |
| 360                                                                                                                          | 20.3                     | 860             | 26.2                     |
| 380                                                                                                                          | 20.8                     | 880             | 26.6                     |
| 400                                                                                                                          | 22.0                     | 900             | 26.3                     |
| 420                                                                                                                          | 21.6                     | 920             | 26.4                     |
| 440                                                                                                                          | 21.9                     | 940             | 26.6                     |
| 460                                                                                                                          | 22.5                     | 960             | 26.9                     |
| 480                                                                                                                          | 22.9                     | 980             | 26.9                     |
| 500                                                                                                                          | 22.9                     | 1000            | 27.4                     |

Reference : 2018050459-1

Page 4 of 8

Date of Issue : 4 July 2018

Checked by : TF

Figure 1

ANSI C63.5:2017 10.0 m separation,  
AUT Scanned (1.0 m - 4.0 m), ANT2 at HP 2.0 m  
Teseq CBL 6143A, s/n 23169.




Figure 2  
VSWR  
Teseq CBL 6143A, s/n 23169.




Figure 3

Return Loss for antenna model: Teseq CBL 6143A, s/n 23169.






Figure 4

Balance test for antenna model: Teseq CBL 6143A, s/n 23169.





NATIONAL PHYSICAL LABORATORY

Teddington Middlesex UK TW11 0LW Telephone +44 20 8977 3222

# Certificate of Calibration



0478

EMCO 3115

Double Ridged Guide Horn Antenna s/n 9509-4562

*This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.*

## REPLACEMENT FOR CERTIFICATE 2018050459-2

FOR:

RISE  
Brinellgatan 4  
SE-504 62 BORÅS  
Sweden

DESCRIPTION:

EMCO 3115 Double Ridged Guide Horn Antenna

IDENTIFICATION:

s/n 9509-4562

CALIBRATION FREQUENCIES: 0.7 GHz to 18.0 GHz in 0.1 GHz steps

DATE(S) OF CALIBRATION: 28 June to 5 July 2018

Reference: 2018050459-2R

Page 1 of 7

Date of Issue: 15 July 2020

Signed:

(Authorised Signatory)

Checked by:

Name: D A Knight

on behalf of NPLML



*This certificate is consistent with the capabilities that are included in Appendix C of the MRA drawn up by the CIPM. Under the MRA, all participating institutes recognise the validity of each other's calibration and measurement certificates for the quantities, ranges and measurement uncertainties specified in Appendix C (for details see <http://www.bipm.org>).*

# NATIONAL PHYSICAL LABORATORY

## Continuation Sheet

### MEASUREMENTS

The measurements in the frequency range 1.0 GHz to 18.0 GHz were made in accordance with the ANSI 63.5:2017 standard. The results of this calibration comply with the basic requirement set out in section 5.1.3.1 a) 1) ii) of the standard: “AFs measured at distances with  $0.62 \sqrt{D^3 / \lambda} \leq R < 2D^2 / \lambda$  shall be deemed acceptable at the calibrated distance” for radiated emission measurements.

In the following, the IEEE definition of gain is used: the gain of an antenna in a given direction is defined as “the ratio of the radiation intensity, in a given direction, to the radiation intensity that would be obtained if the power accepted by the antenna were isotropically radiated”. The apparent gain is obtained by multiplying the gain by the factor  $(1 - |\Gamma|^2)$ , where  $\Gamma$  is the reflection coefficient of the antenna.

The apparent gain of the antenna was measured by the three antenna technique. The antenna separation was 3 m, measured from the aperture of the antenna. A vector network analyser was used to measure the complex reflection coefficients of the antennas and components used in the measurement circuit. Mismatch corrections were calculated from these measurements and applied to the measured gains to give the apparent gains. The antenna factors were calculated from the apparent gains using the following formula:

$$AF = 30.23 + 20\log_{10}(F_{\text{GHz}}) - G_{\text{dBi}} \quad [\text{dB (1/m)}]$$

where  $F_{\text{GHz}}$  is the frequency in GHz and  $G_{\text{dBi}}$  is the apparent gain in dBi.

All measurements were made in a temperature controlled electromagnetic anechoic chamber in a screened laboratory at a temperature of  $23 \pm 2^\circ \text{C}$ .

### CALIBRATION DATA

This certificate contains a subset of the full calibration data. A complete set of results will be provided via email in Excel format.

## MEASUREMENT UNCERTAINTIES

The estimated uncertainty in the apparent gain is  $\pm 1.0$  dB for frequencies below 1.0 GHz and  $\pm 0.8$  dB for frequencies 1.0 GHz and above. The uncertainties in the real or imaginary parts of the reflection coefficients are given in the table below. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k = 2$ , providing a coverage probability of approximately 95 %. The uncertainty evaluation has been carried out in accordance with UKAS requirements. These uncertainties apply only to the measured values and give no indication of the long term stability of the antenna.

### Uncertainties in the components of the reflection coefficients.

| Frequency range [GHz] | Uncertainty in real or imaginary parts |
|-----------------------|----------------------------------------|
| 0.7 to 0.9            | $\pm 0.050$ units                      |
| 1.0 to 1.5            | $\pm 0.015$ units                      |
| 1.6 to 18.0           | $\pm 0.011$ units                      |

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet


## RESULTS

| Apparent Gain and Antenna Factor<br>at 3 m from the antenna aperture. |                |                               |
|-----------------------------------------------------------------------|----------------|-------------------------------|
| Frequency [GHz]                                                       | Gain 3 m [dBi] | Antenna Factor<br>[dB (1/m) ] |
| 0.70                                                                  | -1.1           | 28.2                          |
| 0.80                                                                  | 2.4            | 25.9                          |
| 0.90                                                                  | 5.1            | 24.2                          |
| 1.00                                                                  | 5.7            | 24.6                          |
| 1.50                                                                  | 8.3            | 25.5                          |
| 2.00                                                                  | 8.8            | 27.4                          |
| 2.50                                                                  | 9.8            | 28.4                          |
| 3.00                                                                  | 9.8            | 29.9                          |
| 3.50                                                                  | 10.0           | 31.1                          |
| 4.00                                                                  | 9.9            | 32.4                          |
| 4.50                                                                  | 11.0           | 32.3                          |
| 5.00                                                                  | 10.7           | 33.5                          |
| 5.50                                                                  | 10.9           | 34.1                          |
| 6.00                                                                  | 11.5           | 34.3                          |
| 6.50                                                                  | 12.1           | 34.4                          |
| 7.00                                                                  | 11.8           | 35.4                          |
| 7.50                                                                  | 11.4           | 36.3                          |
| 8.00                                                                  | 11.6           | 36.7                          |
| 8.50                                                                  | 11.4           | 37.4                          |
| 9.00                                                                  | 11.3           | 38.0                          |
| 9.50                                                                  | 11.4           | 38.4                          |
| 10.00                                                                 | 10.8           | 39.4                          |
| 10.50                                                                 | 10.9           | 39.7                          |
| 11.00                                                                 | 12.2           | 38.8                          |
| 11.50                                                                 | 12.5           | 39.0                          |
| 12.00                                                                 | 12.5           | 39.4                          |
| 12.50                                                                 | 13.3           | 38.8                          |
| 13.00                                                                 | 13.4           | 39.1                          |
| 13.50                                                                 | 12.3           | 40.5                          |
| 14.00                                                                 | 11.6           | 41.6                          |
| 14.50                                                                 | 10.7           | 42.7                          |
| 15.00                                                                 | 12.7           | 41.0                          |
| 15.50                                                                 | 16.1           | 37.9                          |
| 16.00                                                                 | 16.7           | 37.6                          |
| 16.50                                                                 | 16.2           | 38.4                          |
| 17.00                                                                 | 14.1           | 40.7                          |
| 17.50                                                                 | 10.6           | 44.5                          |
| 18.00                                                                 | 8.0            | 47.3                          |

Reference: 2018050459-2R

Page 4 of 7

Checked by:



# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

| Reflection Coefficients and VSWR |           |                |       |
|----------------------------------|-----------|----------------|-------|
| Freq [GHz]                       | Real Part | Imaginary Part | VSWR  |
| 0.70                             | 0.801     | 0.241          | 11.26 |
| 0.80                             | 0.641     | -0.143         | 4.82  |
| 0.90                             | 0.373     | -0.201         | 2.47  |
| 1.00                             | 0.370     | -0.177         | 2.39  |
| 1.50                             | -0.162    | -0.219         | 1.75  |
| 2.00                             | -0.337    | -0.006         | 2.02  |
| 2.50                             | -0.238    | 0.066          | 1.65  |
| 3.00                             | -0.134    | 0.087          | 1.38  |
| 3.50                             | 0.091     | 0.085          | 1.29  |
| 4.00                             | 0.139     | -0.112         | 1.44  |
| 4.50                             | -0.092    | -0.094         | 1.30  |
| 5.00                             | -0.183    | 0.171          | 1.67  |
| 5.50                             | -0.003    | 0.306          | 1.88  |
| 6.00                             | 0.160     | 0.172          | 1.62  |
| 6.50                             | 0.166     | -0.070         | 1.44  |
| 7.00                             | -0.023    | -0.171         | 1.42  |
| 7.50                             | -0.114    | -0.021         | 1.26  |
| 8.00                             | 0.019     | 0.088          | 1.20  |
| 8.50                             | 0.134     | 0.019          | 1.31  |
| 9.00                             | 0.132     | -0.118         | 1.43  |
| 9.50                             | -0.010    | -0.239         | 1.63  |
| 10.00                            | -0.238    | -0.176         | 1.84  |
| 10.50                            | -0.149    | 0.060          | 1.38  |
| 11.00                            | -0.095    | -0.053         | 1.24  |
| 11.50                            | -0.121    | 0.016          | 1.28  |
| 12.00                            | -0.009    | 0.050          | 1.11  |
| 12.50                            | 0.043     | -0.053         | 1.15  |
| 13.00                            | -0.051    | -0.129         | 1.32  |
| 13.50                            | -0.152    | -0.044         | 1.38  |
| 14.00                            | -0.093    | 0.091          | 1.30  |
| 14.50                            | 0.100     | 0.083          | 1.30  |
| 15.00                            | 0.193     | -0.125         | 1.60  |
| 15.50                            | 0.042     | -0.303         | 1.88  |
| 16.00                            | -0.183    | -0.268         | 1.96  |
| 16.50                            | -0.292    | -0.037         | 1.84  |
| 17.00                            | -0.122    | 0.215          | 1.66  |
| 17.50                            | 0.216     | 0.129          | 1.67  |
| 18.00                            | 0.218     | -0.235         | 1.95  |

Reference: 2018050459-2R


Page 5 of 7

Checked by: 

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

EMCO 3115 Double Ridged Guide Horn Antenna s/n 9509-4562



Reference: 2018050459-2R

Page 6 of 7

Checked by: *Elmh*

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

## CHANGES TO CERTIFICATE

This re-issued certificate contains the requested ANSI 63.5:2017 statement.

**Reference:** 2018050459-2R

**Checked by:** 

**Page 7 of 7**



NATIONAL PHYSICAL LABORATORY

Teddington Middlesex UK TW11 0LW Telephone +44 20 8977 3222

# Certificate of Calibration



0478

ETS-Lindgren 3115  
Double Ridged Guide Horn Antenna S/N: 00143161

*This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.*

**FOR:**

RISE  
Box 857  
Se 501 15  
Boras  
Sweden

**DESCRIPTION:**

ETS-Lindgren 3115 Double Ridged Guide Horn Antenna

**IDENTIFICATION:**

S/N:00143161

**CALIBRATION FREQUENCIES:** 1.0 GHz to 18.0 GHz in 0.1 GHz steps

**DATE(S) OF CALIBRATION:** 11 December 2018

**Reference:** 2018100184-1

**Page 1 of 5**

**Date of Issue:** 11 December 2018

**Signed:** D G Gentle

**(Authorised Signatory)**

**Checked by:**

*A Beardon*

**Name:** D G Gentle

**on behalf of NPLML**



*This certificate is consistent with the capabilities that are included in Appendix C of the MRA drawn up by the CIPM. Under the MRA, all participating institutes recognise the validity of each other's calibration and measurement certificates for the quantities, ranges and measurement uncertainties specified in Appendix C (for details see <http://www.bipm.org>).*

# NATIONAL PHYSICAL LABORATORY

## Continuation Sheet

### MEASUREMENTS

The measurements were made in accordance with the ANSI 63.5:2017 standard. The results of this calibration comply with the basic requirement set out in section 5.1.3.1 a) 1) ii) of the standard: "AFs measured at distances with  $0.62 \sqrt{D^3/\lambda} \leq R < 2D^2/\lambda$  shall be deemed acceptable at the calibrated distance" for radiated emission measurements.

In the following, the IEEE definition of gain is used: the gain of an antenna in a given direction is defined as "the ratio of the radiation intensity, in a given direction, to the radiation intensity that would be obtained if the power accepted by the antenna were isotropically radiated". The apparent gain is obtained by multiplying the gain by the factor  $(1 - |\Gamma|^2)$ , where  $\Gamma$  is the reflection coefficient of the antenna.

The apparent gain of the antenna was measured by the three antenna technique. The antenna separation was 3 m, measured from the aperture of the antenna. A vector network analyser was used to measure the complex reflection coefficients of the antennas and components used in the measurement circuit. Mismatch corrections were calculated from these measurements and applied to the measured gains to give the apparent gains. The antenna factors were calculated from the apparent gains using the following formula:

$$AF = 30.23 + 20\log_{10}(F_{\text{GHz}}) - G_{\text{dBi}} \quad [\text{dB (1/m)}]$$

where  $F_{\text{GHz}}$  is the frequency in GHz and  $G_{\text{dBi}}$  is the apparent gain in dBi.

All measurements were made in a temperature controlled electromagnetic anechoic chamber in a screened laboratory at a temperature of  $23 \pm 2^\circ \text{C}$ .

### CALIBRATION DATA

This certificate contains a subset of the full calibration data. A complete set of results will be provided via email in Excel format.

### MEASUREMENT UNCERTAINTIES

The estimated uncertainty in the apparent gain is  $\pm 0.8 \text{ dB}$  and the uncertainties in the real or imaginary parts of the reflection coefficients are given in the table below. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k = 2$ , providing a coverage probability of approximately 95%. The uncertainty evaluation has been carried out in accordance with UKAS requirements. These uncertainties apply only to the measured values and give no indication of the long term stability of the antenna.

#### Uncertainties in the components of the reflection coefficients.

| Frequency range [GHz] | Uncertainty in real or imaginary parts |
|-----------------------|----------------------------------------|
| 1.0 to 1.5            | $\pm 0.015$ units                      |
| 1.6 to 18.0           | $\pm 0.011$ units                      |

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

## RESULTS

| Apparent Gain and Antenna Factor<br>at 3 m from the antenna aperture. |                |                               |
|-----------------------------------------------------------------------|----------------|-------------------------------|
| Frequency [GHz]                                                       | Gain 3 m [dBi] | Antenna Factor<br>[dB (1/m) ] |
| 1.00                                                                  | 6.6            | 23.6                          |
| 1.50                                                                  | 8.3            | 25.5                          |
| 2.00                                                                  | 7.8            | 28.4                          |
| 2.50                                                                  | 10.4           | 27.8                          |
| 3.00                                                                  | 10.7           | 29.1                          |
| 3.50                                                                  | 10.7           | 30.4                          |
| 4.00                                                                  | 10.5           | 31.7                          |
| 4.50                                                                  | 11.3           | 32.0                          |
| 5.00                                                                  | 11.3           | 32.9                          |
| 5.50                                                                  | 11.3           | 33.8                          |
| 6.00                                                                  | 10.5           | 35.3                          |
| 6.50                                                                  | 10.9           | 35.6                          |
| 7.00                                                                  | 10.5           | 36.6                          |
| 7.50                                                                  | 10.4           | 37.3                          |
| 8.00                                                                  | 11.3           | 37.0                          |
| 8.50                                                                  | 11.3           | 37.5                          |
| 9.00                                                                  | 11.7           | 37.6                          |
| 9.50                                                                  | 11.8           | 38.0                          |
| 10.00                                                                 | 12.0           | 38.2                          |
| 10.50                                                                 | 12.1           | 38.5                          |
| 11.00                                                                 | 12.6           | 38.5                          |
| 11.50                                                                 | 12.7           | 38.7                          |
| 12.00                                                                 | 13.0           | 38.8                          |
| 12.50                                                                 | 13.4           | 38.8                          |
| 13.00                                                                 | 12.7           | 39.8                          |
| 13.50                                                                 | 12.3           | 40.6                          |
| 14.00                                                                 | 11.9           | 41.2                          |
| 14.50                                                                 | 12.4           | 41.0                          |
| 15.00                                                                 | 13.9           | 39.9                          |
| 15.50                                                                 | 14.6           | 39.5                          |
| 16.00                                                                 | 14.9           | 39.5                          |
| 16.50                                                                 | 13.6           | 41.0                          |
| 17.00                                                                 | 12.6           | 42.2                          |
| 17.50                                                                 | 12.1           | 43.0                          |
| 18.00                                                                 | 12.6           | 42.7                          |

Reference: 2018100184-1

Page 3 of 5

Checked by:

*A. Beaudouin*

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

| Reflection Coefficients and VSWR |           |                |      |
|----------------------------------|-----------|----------------|------|
| Freq [GHz]                       | Real Part | Imaginary Part | VSWR |
| 1.00                             | 0.119     | -0.161         | 1.50 |
| 1.50                             | -0.331    | -0.011         | 1.99 |
| 2.00                             | -0.400    | 0.172          | 2.54 |
| 2.50                             | -0.158    | 0.225          | 1.76 |
| 3.00                             | 0.000     | 0.175          | 1.43 |
| 3.50                             | 0.172     | 0.208          | 1.74 |
| 4.00                             | 0.283     | 0.107          | 1.87 |
| 4.50                             | 0.102     | 0.010          | 1.23 |
| 5.00                             | -0.060    | 0.150          | 1.38 |
| 5.50                             | 0.058     | 0.278          | 1.80 |
| 6.00                             | 0.255     | 0.164          | 1.87 |
| 6.50                             | 0.348     | -0.053         | 2.08 |
| 7.00                             | 0.234     | -0.254         | 2.05 |
| 7.50                             | -0.008    | -0.222         | 1.57 |
| 8.00                             | -0.065    | -0.003         | 1.14 |
| 8.50                             | 0.069     | 0.055          | 1.19 |
| 9.00                             | 0.133     | -0.067         | 1.35 |
| 9.50                             | 0.080     | -0.205         | 1.57 |
| 10.00                            | -0.052    | -0.245         | 1.67 |
| 10.50                            | -0.135    | -0.162         | 1.53 |
| 11.00                            | -0.129    | -0.069         | 1.34 |
| 11.50                            | -0.109    | -0.030         | 1.25 |
| 12.00                            | -0.094    | 0.002          | 1.21 |
| 12.50                            | -0.050    | 0.000          | 1.10 |
| 13.00                            | -0.030    | -0.059         | 1.14 |
| 13.50                            | -0.091    | -0.109         | 1.33 |
| 14.00                            | -0.188    | -0.061         | 1.49 |
| 14.50                            | -0.219    | 0.090          | 1.62 |
| 15.00                            | -0.104    | 0.254          | 1.76 |
| 15.50                            | 0.114     | 0.268          | 1.82 |
| 16.00                            | 0.262     | 0.133          | 1.83 |
| 16.50                            | 0.280     | -0.043         | 1.79 |
| 17.00                            | 0.179     | -0.162         | 1.63 |
| 17.50                            | 0.037     | -0.116         | 1.28 |
| 18.00                            | 0.092     | 0.074          | 1.27 |

Reference: 2018100184-1

Page 4 of 5


Checked by:

*A. R. R. R.*

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

ETS-Lindgren 3115 Double Ridged Guide Horn Antenna s/n 00143161



Reference: 2018100184-1

Page 5 of 5

Checked by:

*A. Beanhare*



NATIONAL PHYSICAL LABORATORY

Teddington Middlesex UK TW11 0LW Telephone +44 20 8977 3222

# Certificate of Calibration



0478

EMCO 3116

Double Ridged Guide Horn Antenna S/N: 9904-2426

*This certificate is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to the SI system of units and/or to units of measurement realised at the National Physical Laboratory or other recognised national metrology institutes. This certificate may not be reproduced other than in full, except with the prior written approval of the issuing laboratory.*

## REPLACEMENT FOR CERTIFICATE 2018050459-3

FOR:

RISE  
Brinellgatan 4  
SE-504 62 BORÅS  
Sweden

DESCRIPTION:

EMCO 3116 Double Ridged Guide Horn Antenna

IDENTIFICATION:

S/N 9904-2426

CALIBRATION FREQUENCIES:

18.00 GHz to 40.00 GHz in 0.25 GHz steps

DATE(S) OF CALIBRATION:

19 July 2018

Reference: 2018050459-3R

Page 1 of 7

Date of Issue: 15 July 2020

Signed:

(Authorised Signatory)

Checked by:

Name: D A Knight

on behalf of NPLML



*This certificate is consistent with the capabilities that are included in Appendix C of the MRA drawn up by the CIPM. Under the MRA, all participating institutes recognise the validity of each other's calibration and measurement certificates for the quantities, ranges and measurement uncertainties specified in Appendix C (for details see <http://www.bipm.org>).*

# NATIONAL PHYSICAL LABORATORY

## Continuation Sheet

### MEASUREMENTS

The measurements were made in accordance with the ANSI 63.5:2017 standard. The results of this calibration comply with the basic requirement set out in section 5.1.3.1 a) 1) iii) of the standard: “AFs measured at distances with  $R \geq 2D^2/\lambda$  shall be deemed acceptable at the calibrated distance and greater” for radiated emission measurements.

In the following, the IEEE definition of gain is used: the gain of an antenna in a given direction is defined as “the ratio of the radiation intensity, in a given direction, to the radiation intensity that would be obtained if the power accepted by the antenna were isotropically radiated”. The apparent gain is obtained by multiplying the gain by the factor  $(1 - |\Gamma|^2)$ , where  $\Gamma$  is the reflection coefficient of the antenna.

The apparent gain of the antenna was measured by the three antenna technique. The antenna separation was 3 m measured from the aperture of the antenna. A vector network analyser was used to measure the complex reflection coefficients of the antennas and components used in the measurement circuit. Mismatch corrections were calculated from these measurements and applied to the measured gains to give the apparent gains. The antenna factors were calculated from the apparent gains using the following formula:

$$AF = 30.23 + 20\log_{10}(F_{\text{GHz}}) - G_{\text{dBi}} \quad [\text{dB (1/m)}]$$

where  $F_{\text{GHz}}$  is the frequency in GHz and  $G_{\text{dBi}}$  is the apparent gain in dBi.

All measurements were made in a temperature controlled electromagnetic anechoic chamber in a screened laboratory at a temperature of  $23 \pm 2^\circ \text{C}$ .

### CALIBRATION DATA

This certificate contains a subset of the full calibration data. A complete set of results will be provided via email in Excel format.

## MEASUREMENT UNCERTAINTIES

The estimated uncertainty in the apparent gain is  $\pm 0.8$  dB and the uncertainty in the real or imaginary parts of the reflection coefficients are given in the table below. The reported expanded uncertainty is based on a standard uncertainty multiplied by a coverage factor  $k = 2$ , providing a coverage probability of approximately 95 %. The uncertainty evaluation has been carried out in accordance with UKAS requirements. These uncertainties apply only to the measured values and give no indication of the long term stability of the antenna.

### Uncertainties in the components of the reflection coefficients.

| Frequency range [GHz] | Uncertainty in real or imaginary parts |
|-----------------------|----------------------------------------|
| 18.00 to 26.50        | $\pm 0.028$ units                      |
| 26.75 to 40.00        | $\pm 0.043$ units                      |

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

## RESULTS

| Apparent Gain and Antenna Factor<br>at 3 m from the antenna aperture. |                |                               |
|-----------------------------------------------------------------------|----------------|-------------------------------|
| Frequency [GHz]                                                       | Gain 3 m [dBi] | Antenna Factor<br>[dB (1/m) ] |
| 18.00                                                                 | 11.9           | 43.4                          |
| 18.50                                                                 | 11.6           | 44.0                          |
| 19.00                                                                 | 11.2           | 44.6                          |
| 19.50                                                                 | 10.7           | 45.4                          |
| 20.00                                                                 | 10.7           | 45.5                          |
| 20.50                                                                 | 10.9           | 45.6                          |
| 21.00                                                                 | 10.5           | 46.2                          |
| 21.50                                                                 | 10.6           | 46.3                          |
| 22.00                                                                 | 11.0           | 46.0                          |
| 22.50                                                                 | 11.2           | 46.1                          |
| 23.00                                                                 | 11.8           | 45.6                          |
| 23.50                                                                 | 11.9           | 45.8                          |
| 24.00                                                                 | 12.5           | 45.4                          |
| 24.50                                                                 | 12.8           | 45.2                          |
| 25.00                                                                 | 12.5           | 45.7                          |
| 25.50                                                                 | 12.3           | 46.1                          |
| 26.00                                                                 | 12.3           | 46.2                          |
| 26.50                                                                 | 12.3           | 46.4                          |
| 27.00                                                                 | 12.6           | 46.2                          |
| 27.50                                                                 | 12.6           | 46.4                          |
| 28.00                                                                 | 12.5           | 46.7                          |
| 28.50                                                                 | 12.8           | 46.5                          |
| 29.00                                                                 | 12.8           | 46.6                          |
| 29.50                                                                 | 13.2           | 46.4                          |
| 30.00                                                                 | 13.5           | 46.3                          |
| 30.50                                                                 | 13.4           | 46.6                          |
| 31.00                                                                 | 13.1           | 47.0                          |
| 31.50                                                                 | 13.0           | 47.2                          |
| 32.00                                                                 | 12.5           | 47.9                          |
| 32.50                                                                 | 11.9           | 48.6                          |
| 33.00                                                                 | 11.3           | 49.3                          |
| 33.50                                                                 | 10.5           | 50.2                          |
| 34.00                                                                 | 10.2           | 50.6                          |
| 34.50                                                                 | 10.0           | 51.0                          |
| 35.00                                                                 | 9.2            | 51.9                          |
| 35.50                                                                 | 10.0           | 51.2                          |
| 36.00                                                                 | 11.5           | 49.8                          |
| 36.50                                                                 | 13.3           | 48.2                          |
| 37.00                                                                 | 14.9           | 46.7                          |
| 37.50                                                                 | 15.7           | 46.0                          |
| 38.00                                                                 | 16.0           | 45.8                          |
| 38.50                                                                 | 16.3           | 45.6                          |
| 39.00                                                                 | 16.5           | 45.6                          |
| 39.50                                                                 | 15.9           | 46.2                          |
| 40.00                                                                 | 15.1           | 47.2                          |

Reference: 2018050459-3R

Page 4 of 7

Checked by: 

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

| Reflection Coefficients and VSWR |           |                |      |
|----------------------------------|-----------|----------------|------|
| Freq [GHz]                       | Real Part | Imaginary Part | VSWR |
| 18.00                            | 0.123     | 0.000          | 1.28 |
| 18.50                            | 0.095     | -0.151         | 1.43 |
| 19.00                            | -0.059    | -0.200         | 1.53 |
| 19.50                            | -0.163    | -0.145         | 1.56 |
| 20.00                            | -0.238    | -0.067         | 1.66 |
| 20.50                            | -0.253    | 0.070          | 1.71 |
| 21.00                            | -0.167    | 0.159          | 1.60 |
| 21.50                            | -0.102    | 0.182          | 1.53 |
| 22.00                            | -0.017    | 0.207          | 1.52 |
| 22.50                            | 0.063     | 0.152          | 1.39 |
| 23.00                            | 0.085     | 0.116          | 1.34 |
| 23.50                            | 0.142     | 0.066          | 1.37 |
| 24.00                            | 0.133     | -0.034         | 1.32 |
| 24.50                            | 0.072     | -0.083         | 1.25 |
| 25.00                            | 0.015     | -0.101         | 1.23 |
| 25.50                            | -0.055    | -0.078         | 1.21 |
| 26.00                            | -0.068    | -0.007         | 1.15 |
| 26.50                            | -0.037    | 0.023          | 1.09 |
| 27.00                            | -0.008    | 0.044          | 1.09 |
| 27.50                            | 0.045     | 0.031          | 1.12 |
| 28.00                            | 0.062     | -0.012         | 1.13 |
| 28.50                            | 0.068     | -0.047         | 1.18 |
| 29.00                            | 0.055     | -0.105         | 1.27 |
| 29.50                            | -0.005    | -0.138         | 1.32 |
| 30.00                            | -0.062    | -0.138         | 1.36 |
| 30.50                            | -0.122    | -0.124         | 1.42 |
| 31.00                            | -0.179    | -0.066         | 1.47 |
| 31.50                            | -0.194    | 0.008          | 1.48 |
| 32.00                            | -0.177    | 0.081          | 1.48 |
| 32.50                            | -0.114    | 0.145          | 1.45 |
| 33.00                            | -0.025    | 0.142          | 1.34 |
| 33.50                            | 0.032     | 0.090          | 1.21 |
| 34.00                            | 0.039     | 0.017          | 1.09 |
| 34.50                            | -0.013    | -0.027         | 1.06 |
| 35.00                            | -0.062    | -0.015         | 1.14 |
| 35.50                            | -0.084    | 0.009          | 1.18 |
| 36.00                            | -0.103    | 0.041          | 1.25 |
| 36.50                            | -0.100    | 0.085          | 1.30 |
| 37.00                            | -0.075    | 0.120          | 1.33 |
| 37.50                            | -0.031    | 0.150          | 1.36 |
| 38.00                            | 0.031     | 0.145          | 1.35 |
| 38.50                            | 0.064     | 0.103          | 1.28 |
| 39.00                            | 0.073     | 0.073          | 1.23 |
| 39.50                            | 0.072     | 0.042          | 1.18 |
| 40.00                            | 0.060     | 0.020          | 1.13 |

Reference: 2018050459-3R


Page 5 of 7

Checked by: 

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

EMCO 3116 Double Ridged Guide Horn Antenna s/n 9904-2426



Reference: 2018050459-3R

Page 6 of 7

Checked by: *E. H. M.*

# NATIONAL PHYSICAL LABORATORY

Continuation Sheet

## CHANGES TO CERTIFICATE

This re-issued certificate contains the requested ANSI 63.5:2017 statement.

**Reference:** 2018050459-3R

**Checked by:** 

**Page 7 of 7**

# Calibration Certificate

Kalibrierschein

Certificate Number 24-0090-101871-01

Zertifikatsnummer

## Unit Data

Item  
Gegenstand  
**Harmonic Mixer, 60 GHz to 90 GHz**

Manufacturer  
Hersteller  
**ROHDE & SCHWARZ**

Type  
Typ  
**R&S® FS-Z90**

Material Number  
Materialnummer  
**1048.0371.02**

Serial Number  
Seriennummer  
**101871**

Asset Number  
Inventarnummer

This calibration certificate documents, that the named item is tested and measured against defined specifications. Measurement results are located usually in the corresponding interval with a probability of approx. 95% (coverage factor  $k = 2$ ). Calibration is performed with test equipment and standards directly or indirectly traceable by means of approved calibration techniques to the PTB/DKD or other national/international standards, which realize the physical units of measurement according to the International System of Units (SI). In all cases where no standards are available, measurements are referenced to standards of the R&S laboratories. Principles and methods of calibration correspond with EN ISO/IEC 17025. This calibration certificate may not be reproduced other than in full. Calibration certificates without signatures are not valid. The user is obliged to have the object recalibrated at appropriate intervals.

## Order Data

Customer  
Auftraggeber

Order Number  
Bestellnummer

Date of Receipt  
Eingangsdatum

## Performance

Place and Date of Calibration  
Ort und Datum der Kalibrierung

**Meckenheim, 2019-01-10**

Scope of Calibration  
Umfang der Kalibrierung

**Standard Calibration**

Statement of Compliance  
(Incoming)  
Konformitätsaussage  
(Anlieferung)

**New device**

Statement of Compliance  
(Outgoing)  
Konformitätsaussage  
(Auslieferung)

**All measured values are within the data sheet specifications.**

Extend of Calibration Documents  
Umfang des Kalibrierdokuments

**2 pages Calibration Certificate  
5 pages Outgoing Results**

Dieser Kalibrierschein dokumentiert, dass der genannte Gegenstand nach festgelegten Vorgaben geprüft und gemessen wurde. Die Messwerte lagen im Regelfall mit einer Wahrscheinlichkeit von annähernd 95% im zugeordneten Werteintervall (Erweiterte Messunsicherheit mit  $k = 2$ ). Die Kalibrierung erfolgte mit Messmitteln und Normalen, die direkt oder indirekt durch Ableitung mittels anerkannter Kalibriertechniken rückgeführt sind auf Normale der PTB/DKD oder anderer nationaler/internationaler Standards zur Darstellung der physikalischen Einheiten in Übereinstimmung mit dem Internationalen Einheitensystem (SI). Wenn keine Normale existieren, erfolgt die Rückführung auf Bezugsnormale der R&S-Laboratorien. Grundsätze und Verfahren der Kalibrierung beziehen sich auf EN ISO/IEC 17025. Dieser Kalibrierschein darf nur vollständig und unverändert weiterverbreitet werden. Kalibrierscheine ohne Unterschriften sind ungültig. Für die Einhaltung einer angemessenen Frist zur Wiederholung der Kalibrierung ist der Benutzer verantwortlich.

## Radiometer Physics GmbH; Meckenheim

Date of Issue  
Ausstellungsdatum

**2019-01-11**

Head of Laboratory  
Laborleitung

Schulze

Person Responsible  
Bearbeiter



Heinze

Page (Seite) 1/2  
Vers2010-05-05/  
RPG2014-02-28

Calibration Method  
Kalibrieranweisung

RPG-PAQA-TN-2014-002

Relative Humidity 20 % - 80 %  
Relative LuftfeuchteAmbient Temperature  
Umgebungstemperatur(23 <sup>+7</sup><sub>-3</sub>) °CWorking standards used (having a significant effect on the accuracy)  
Verwendete Gebrauchsnormale (mit signifikantem Einfluss auf die Genauigkeit)

| Item<br>Gegenstand      | Type<br>Typ  | Serial Number<br>Seriennummer | Calibration Certificate Number<br>Kalibrierscheinnummer | Cal. Due<br>Kalibr. bis |
|-------------------------|--------------|-------------------------------|---------------------------------------------------------|-------------------------|
| Vector Network Analyzer | R&S® ZVA67   | 101097                        | 20-300432406                                            | 2020-07-21              |
| Powersensor             | R&S® NRP-Z55 | 140093                        | 20-300426316                                            | 2019-05-17              |
| Powersensor             | R&S® NRP-Z58 | 101063                        | 0001-300474490                                          | 2019-08-06              |
| Calibration kit         | WR12         | E10001                        | RPG-PAQA-TN-2014-005                                    | 2019-02-01              |

**UGB1** A compliance statement may be possible where a confidence level of less than 95 % is acceptable.  
Die Bestätigung der Konformität ist möglich, sofern ein Grad des Vertrauens von weniger als 95 % akzeptabel ist.

**UGB2** A non-compliance statement may be possible where a confidence level of less than 95 % is acceptable.  
Die Bestätigung der Nicht-Konformität ist möglich, sofern ein Grad des Vertrauens von weniger als 95 % akzeptabel ist.

Ref.: ILAC-G8:03/2009 'Guidelines on the Reporting of Compliance with Specification'.

**Notes**

## Anmerkungen


If the new product is stored under the climate conditions as specified in the data sheet upon delivery, the product's accuracy is not significantly affected within 12 month after its calibration in our factory. In this case, the recommended calibration interval starts on the date when the product is actually put into operation.

## Outgoing Results

The following abbreviations may be used in this document

|            |                                                                                                                                                                                                                                                                            |
|------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| {a}        | No measurement uncertainty stated because the errors always add together.<br>So it is sure that a measurement result evaluated as "PASS" is pass.                                                                                                                          |
| {b}        | The measurement uncertainty depends on the measurement result. The stated measurement uncertainty is valid for the close area around the specification. Measurement results outside the close area have a higher measurement uncertainty but are within the specification. |
| {c}        | Functional test, therefore no measurement uncertainty is stated.                                                                                                                                                                                                           |
| {d}        | Typical value, refer to performance test.                                                                                                                                                                                                                                  |
| {e}        | The measurement uncertainty is taken into account when setting the measuring system.                                                                                                                                                                                       |
| DL or DT   | Data Limit for symmetrical tolerance limits                                                                                                                                                                                                                                |
| DLL        | Datasheet Lower Limit                                                                                                                                                                                                                                                      |
| DUL        | Datasheet Upper Limit                                                                                                                                                                                                                                                      |
| MU         | Measurement Uncertainty                                                                                                                                                                                                                                                    |
| MLL or MLV | Measurement Uncertainty Lower Value                                                                                                                                                                                                                                        |
| MUL or MUV | Measurement Uncertainty Upper Value                                                                                                                                                                                                                                        |
| Nom.       | Nominal Value                                                                                                                                                                                                                                                              |
| Dev.       | Deviation                                                                                                                                                                                                                                                                  |
| MErr.      | Measurement Error                                                                                                                                                                                                                                                          |
| Act.       | Actual Value                                                                                                                                                                                                                                                               |
| UGB        | Uncertainty Guard Band: Measuring uncertainty violates the data (spec.) limit.                                                                                                                                                                                             |
| UGB1       | Measurement results marked as UGB1 show conformity with a probability of >50 % and <95 %.                                                                                                                                                                                  |
| UGB2       | Measurement results marked as UGB2 show non-conformity with a probability of >50 % and <95 %.                                                                                                                                                                              |
| DU         | Datasheet Uncertainty                                                                                                                                                                                                                                                      |

### Explanation of charts




**Software used for measurement**

| Item Type                               | Version | Remark |
|-----------------------------------------|---------|--------|
| Measurement Studio Professional Edition | 2013    |        |
| MixerCertification                      | 7_09    |        |

## 1.1 RF Input – VSWR


Measurement uncertainty: 0.05 (VSWR)



## 1.2 Conversion loss

LO level +14 dBm nominal  
Bias 0 A

Measurement uncertainty: 1.5 dB



**Note:** Numeric calibration data can be found attached to the PDF file of the calibration certificate. Click the “paper clip” symbol to display the file.

The file has been renamed for safety reasons.

When downloading the file onto your PC, please delete the “.file” extension and unzip the data.

### 1.3 Frequency response within 1 GHz

|                                 | DUL           | Actual<br>(worst case) | Evaluation    |
|---------------------------------|---------------|------------------------|---------------|
| IF = 404.4 MHz,<br>6th harmonic | 6 dB          | 2.76 dB                | PASS          |
| IF = 404.4 MHz,<br>8th harmonic | not specified | 1.83 dB                | not specified |
| IF = 729 MHz,<br>6th harmonic   | 6 dB          | 2.71 dB                | PASS          |
| IF = 1330 MHz,<br>6th harmonic  | 6 dB          | 2.02 dB                | PASS          |




# Standard Gain Horn

Model 20240-20


Waveguide Size: WG20 (WR42, R220)  
 Nominal Gain: 20 dBi  
 Operating Frequencies: 17.6 - 26.7 GHz

Overall Length (A): 120.3 mm (4.736 inch)  
 Aperture Width (B): 52.00 mm (2.047 inch)  
 Aperture Height (C): 37.40 mm (1.472 inch)  
 Waveguide Width (D): 10.668 mm (0.420 inch)  
 Waveguide Height (E): 4.318 mm (0.170 inch)  
 Flare Length (F): 115.20 mm (4.535 inch)



## Typical Performance Data

| Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane | Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane | Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane |
|-----------------|------------|-------------------|-------------------|-----------------|------------|-------------------|-------------------|-----------------|------------|-------------------|-------------------|
| 17.6            | 18.11      | 23.1°             | 22.3°             | 20.7            | 19.42      | 19.7°             | 19.0°             | 23.85           | 20.54      | 17.1°             | 16.5°             |
| 17.7            | 18.15      | 23.0°             | 22.2°             | 20.85           | 19.48      | 19.5°             | 18.8°             | 24              | 20.59      | 17.0°             | 16.4°             |
| 17.85           | 18.22      | 22.8°             | 22.0°             | 21              | 19.54      | 19.4°             | 18.7°             | 24.15           | 20.64      | 16.9°             | 16.3°             |
| 18              | 18.29      | 22.6°             | 21.8°             | 21.15           | 19.59      | 19.2°             | 18.6°             | 24.3            | 20.69      | 16.8°             | 16.2°             |
| 18.15           | 18.36      | 22.4°             | 21.6°             | 21.3            | 19.65      | 19.1°             | 18.4°             | 24.45           | 20.74      | 16.6°             | 16.1°             |
| 18.3            | 18.42      | 22.2°             | 21.4°             | 21.45           | 19.71      | 19.0°             | 18.3°             | 24.6            | 20.79      | 16.5°             | 16.0°             |
| 18.45           | 18.49      | 22.1°             | 21.3°             | 21.6            | 19.76      | 18.8°             | 18.2°             | 24.75           | 20.83      | 16.4°             | 15.9°             |
| 18.6            | 18.56      | 21.9°             | 21.1°             | 21.75           | 19.82      | 18.7°             | 18.0°             | 24.9            | 20.88      | 16.3°             | 15.8°             |
| 18.75           | 18.62      | 21.7°             | 20.9°             | 21.9            | 19.87      | 18.6°             | 17.9°             | 25.05           | 20.93      | 16.3°             | 15.7°             |
| 18.9            | 18.69      | 21.5°             | 20.8°             | 22.05           | 19.93      | 18.5°             | 17.8°             | 25.2            | 20.97      | 16.2°             | 15.6°             |
| 19.05           | 18.75      | 21.4°             | 20.6°             | 22.2            | 19.98      | 18.3°             | 17.7°             | 25.35           | 21.02      | 16.1°             | 15.5°             |
| 19.2            | 18.82      | 21.2°             | 20.4°             | 22.35           | 20.03      | 18.2°             | 17.6°             | 25.5            | 21.06      | 16.0°             | 15.4°             |
| 19.35           | 18.88      | 21.0°             | 20.3°             | 22.5            | 20.09      | 18.1°             | 17.4°             | 25.65           | 21.11      | 15.9°             | 15.3°             |
| 19.5            | 18.94      | 20.9°             | 20.1°             | 22.65           | 20.14      | 18.0°             | 17.3°             | 25.8            | 21.15      | 15.8°             | 15.2°             |
| 19.65           | 19.00      | 20.7°             | 20.0°             | 22.8            | 20.19      | 17.9°             | 17.2°             | 25.95           | 21.20      | 15.7°             | 15.1°             |
| 19.8            | 19.06      | 20.6°             | 19.8°             | 22.95           | 20.24      | 17.7°             | 17.1°             | 26.1            | 21.24      | 15.6°             | 15.0°             |
| 19.95           | 19.13      | 20.4°             | 19.7°             | 23.1            | 20.29      | 17.6°             | 17.0°             | 26.25           | 21.28      | 15.5°             | 15.0°             |
| 20.1            | 19.19      | 20.3°             | 19.5°             | 23.25           | 20.35      | 17.5°             | 16.9°             | 26.4            | 21.33      | 15.4°             | 14.9°             |
| 20.25           | 19.25      | 20.1°             | 19.4°             | 23.4            | 20.40      | 17.4°             | 16.8°             | 26.55           | 21.37      | 15.3°             | 14.8°             |
| 20.4            | 19.31      | 20.0°             | 19.2°             | 23.55           | 20.45      | 17.3°             | 16.7°             | 26.7            | 21.41      | 15.2°             | 14.7°             |
| 20.55           | 19.36      | 19.8°             | 19.1°             | 23.7            | 20.50      | 17.2°             | 16.6°             |                 |            |                   |                   |



### Notes:

Gain calculations based on NRL Report 4433 - accuracy to approx  $\pm 0.3$  dBi  
 Half-power (3dB) beamwidth estimates calculated using  $50.8 \lambda / C$  (E-Plane) and  $68.1 \lambda / B$  (H-Plane). This is a 'large aperture' approximation that breaks down at gain values smaller than around 12 dBi. For 10dBi Standard Gain Horns, beamwidths are approximately 63° at the lowest frequency and 48° at the highest frequency.

## FLANN MICROWAVE LTD

Dunmere Road  
 Bodmin, Cornwall  
 PL31 2QL  
 United Kingdom  
 Tel: +44 (0)1208 77777  
 Fax: +44 (0)1208 76426

[sales@flann.com](mailto:sales@flann.com)

## FLANN MICROWAVE INC

One Boston Place  
 Suite 2600  
 Boston  
 Massachusetts, MA 02108-4407  
 Tel: 617 621 7034  
 Fax: 617 577 8234


[www.flann.com](http://www.flann.com)

# STANDARD GAIN HORN

Model 22240-20


Waveguide Size: WG22 (WR28, R320)  
 Nominal Gain: 20 dBi  
 Operating Frequencies: 26.4 - 40.1 GHz

Overall Length (A): 86.0 mm (3.386 inch)  
 Aperture Width (B): 34.20 mm (1.346 inch)  
 Aperture Height (C): 24.80 mm (0.976 inch)  
 Waveguide Width (D): 7.112 mm (0.280 inch)  
 Waveguide Height (E): 3.556 mm (0.140 inch)  
 Flare Length (F): 75.00 mm (2.953 inch)



Typical Performance Data

| Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane | Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane | Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane |
|-----------------|------------|-------------------|-------------------|-----------------|------------|-------------------|-------------------|-----------------|------------|-------------------|-------------------|
| 26.4            | 18.03      | 23.3°             | 22.6°             | 31.5            | 19.47      | 19.5°             | 18.9°             | 36.75           | 20.69      | 16.7°             | 16.2°             |
| 26.5            | 18.06      | 23.2°             | 22.5°             | 31.75           | 19.53      | 19.3°             | 18.8°             | 37              | 20.74      | 16.6°             | 16.1°             |
| 26.75           | 18.14      | 22.9°             | 22.3°             | 32              | 19.60      | 19.2°             | 18.6°             | 37.25           | 20.80      | 16.5°             | 16.0°             |
| 27              | 18.22      | 22.7°             | 22.1°             | 32.25           | 19.66      | 19.0°             | 18.5°             | 37.5            | 20.85      | 16.4°             | 15.9°             |
| 27.25           | 18.29      | 22.5°             | 21.9°             | 32.5            | 19.72      | 18.9°             | 18.4°             | 37.75           | 20.90      | 16.3°             | 15.8°             |
| 27.5            | 18.37      | 22.3°             | 21.7°             | 32.75           | 19.78      | 18.7°             | 18.2°             | 38              | 20.95      | 16.2°             | 15.7°             |
| 27.75           | 18.44      | 22.1°             | 21.5°             | 33              | 19.84      | 18.6°             | 18.1°             | 38.25           | 21.00      | 16.0°             | 15.6°             |
| 28              | 18.52      | 21.9°             | 21.3°             | 33.25           | 19.90      | 18.5°             | 17.9°             | 38.5            | 21.05      | 15.9°             | 15.5°             |
| 28.25           | 18.59      | 21.7°             | 21.1°             | 33.5            | 19.96      | 18.3°             | 17.8°             | 38.75           | 21.10      | 15.8°             | 15.4°             |
| 28.5            | 18.66      | 21.5°             | 20.9°             | 33.75           | 20.02      | 18.2°             | 17.7°             | 39              | 21.15      | 15.7°             | 15.3°             |
| 28.75           | 18.73      | 21.4°             | 20.8°             | 34              | 20.08      | 18.1°             | 17.6°             | 39.25           | 21.20      | 15.6°             | 15.2°             |
| 29              | 18.80      | 21.2°             | 20.6°             | 34.25           | 20.14      | 17.9°             | 17.4°             | 39.5            | 21.25      | 15.5°             | 15.1°             |
| 29.25           | 18.87      | 21.0°             | 20.4°             | 34.5            | 20.19      | 17.8°             | 17.3°             | 39.75           | 21.30      | 15.4°             | 15.0°             |
| 29.5            | 18.94      | 20.8°             | 20.2°             | 34.75           | 20.25      | 17.7°             | 17.2°             | 40              | 21.34      | 15.3°             | 14.9°             |
| 29.75           | 19.01      | 20.6°             | 20.1°             | 35              | 20.31      | 17.5°             | 17.1°             | 40.1            | 21.36      | 15.3°             | 14.9°             |
| 30              | 19.08      | 20.5°             | 19.9°             | 35.25           | 20.36      | 17.4°             | 16.9°             |                 |            |                   |                   |
| 30.25           | 19.14      | 20.3°             | 19.7°             | 35.5            | 20.42      | 17.3°             | 16.8°             |                 |            |                   |                   |
| 30.5            | 19.21      | 20.1°             | 19.6°             | 35.75           | 20.48      | 17.2°             | 16.7°             |                 |            |                   |                   |
| 30.75           | 19.28      | 20.0°             | 19.4°             | 36              | 20.53      | 17.1°             | 16.6°             |                 |            |                   |                   |
| 31              | 19.34      | 19.8°             | 19.3°             | 36.25           | 20.58      | 16.9°             | 16.5°             |                 |            |                   |                   |
| 31.25           | 19.41      | 19.6°             | 19.1°             | 36.5            | 20.64      | 16.8°             | 16.3°             |                 |            |                   |                   |



## Notes:

Gain calculations based on NRL Report 4433 - accuracy to approx  $\pm 0.3$  dBi. Antenna Gain is only valid within the 'far-field' of the antenna. For more details, please see Ch 16, 'Antenna Theory, Analysis & Design' Balanis, Wiley or Ch 18 'Antenna', Kraus, McGraw-Hill. Half-power (3dB) beamwidth estimates calculated using  $50.8 \lambda / C$  (E-Plane) and  $68.1 \lambda / B$  (H-Plane). This is a 'large aperture' approximation that breaks down at gain values smaller than around 12 dBi. For 10dBi Standard Gain Horns, beamwidths are approximately 63° at the lowest frequency and 48° at the highest frequency.



**FLANN MICROWAVE**  
 Dunmere Road  
 Bodmin, Cornwall  
 PL31 2QL  
 United Kingdom

Tel: +44 (0) 1208 77777  
 Fax: +44 (0) 1208 76426  
 mail@flann.com  
 www.flann.com



# STANDARD GAIN HORN

Model No: 24240-20

Nominal Gain: 20dB

## Typical Performance Data

3dB Beamwidth (deg.)

| Frequency<br>(GHz) | Gain dBi<br>(acc. $\pm$ .25dB) | E-PLANE | H-PLANE |
|--------------------|--------------------------------|---------|---------|
| 39.3               | 18.0                           | 24      | 23      |
| 40.0               | 18.2                           | 23      | 22      |
| 41.0               | 18.4                           | 23      | 22      |
| 42.0               | 18.6                           | 22      | 21      |
| 43.0               | 18.8                           | 22      | 21      |
| 44.0               | 19.0                           | 21      | 20      |
| 45.0               | 19.2                           | 21      | 20      |
| 46.0               | 19.3                           | 20      | 20      |
| 47.0               | 19.5                           | 20      | 19      |
| 48.0               | 19.7                           | 19      | 19      |
| 49.0               | 19.9                           | 19      | 18      |
| 50.0               | 20.0                           | 19      | 18      |
| 51.0               | 20.2                           | 18      | 18      |
| 52.0               | 20.3                           | 18      | 17      |
| 53.0               | 20.5                           | 18      | 17      |
| 54.0               | 20.6                           | 17      | 17      |
| 55.0               | 20.8                           | 17      | 16      |
| 56.0               | 20.9                           | 17      | 16      |
| 57.0               | 21.1                           | 16      | 16      |
| 58.0               | 21.2                           | 16      | 16      |
| 59.0               | 21.4                           | 16      | 15      |
| 59.7               | 21.4                           | 16      | 15      |



**FLANN MICROWAVE**

Dunmere Road  
Cornwall

PL31 2QL

Tel: +44 (0) 1208 77777  
Email: mail@flann.com

Bodmin  
England

Fax: +44 (0) 1208 76426  
www.flann.com



BS EN ISO 9002 Certificate No. 2536

# STANDARD GAIN HORN

Model No: 26240-20dB

Nominal Gain: 20dB

## Typical Performance Data

| Frequency<br>(GHz) | Gain dBi<br>(acc. $\pm$ .25dB) | 3dB Beamwidth (deg.) |         |
|--------------------|--------------------------------|----------------------|---------|
|                    |                                | E-PLANE              | H-PLANE |
| 60.5               | 18.1                           | 23                   | 23      |
| 62.0               | 18.3                           | 23                   | 22      |
| 64.0               | 18.6                           | 22                   | 22      |
| 66.0               | 18.9                           | 21                   | 21      |
| 68.0               | 19.1                           | 21                   | 20      |
| 70.0               | 19.4                           | 20                   | 20      |
| 72.0               | 19.6                           | 19                   | 19      |
| 74.0               | 19.8                           | 19                   | 19      |
| 76.0               | 20.0                           | 18                   | 18      |
| 78.0               | 20.2                           | 18                   | 18      |
| 80.0               | 20.4                           | 17                   | 17      |
| 82.0               | 20.5                           | 17                   | 17      |
| 84.0               | 20.8                           | 17                   | 17      |
| 86.0               | 21.0                           | 16                   | 16      |
| 88.0               | 21.2                           | 16                   | 16      |
| 90.0               | 21.4                           | 16                   | 16      |
| 92.0               | 21.6                           | 15                   | 15      |



**FLANN MICROWAVE**

Dunmere Road  
Cornwall

Tel: +44 (0) 1208 77777  
Email: mail@flann.com

PL31 2QL

Bodmin  
England

Fax: +44 (0) 1208 76426  
www.flann.com




# Standard Gain Horn

Model 27240-20


Waveguide Size: WG27 (WR10, R900)  
Nominal Gain: 20 dBi  
Operating Frequencies: 73.8 - 112 GHz

Overall Length (A): 32.5 mm (1.280 inch)  
Aperture Width (B): 12.40 mm (0.488 inch)  
Aperture Height (C): 9.00 mm (0.354 inch)  
Waveguide Width (D): 2.540 mm (0.100 inch)  
Waveguide Height (E): 1.270 mm (0.050 inch)  
Flare Length (F): 26.00 mm (1.024 inch)



## Typical Performance Data

| Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane | Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane | Frequency (GHz) | Gain (dBi) | Beamwidth E-Plane | Beamwidth H-Plane |
|-----------------|------------|-------------------|-------------------|-----------------|------------|-------------------|-------------------|-----------------|------------|-------------------|-------------------|
| 73.8            | 18.12      | 22.9°             | 22.3°             | 89.25           | 19.66      | 19.0°             | 18.4°             | 105             | 20.92      | 16.1°             | 15.7°             |
| 74.25           | 18.17      | 22.8°             | 22.2°             | 90              | 19.72      | 18.8°             | 18.3°             | 105.75          | 20.98      | 16.0°             | 15.6°             |
| 75              | 18.26      | 22.6°             | 21.9°             | 90.75           | 19.79      | 18.6°             | 18.1°             | 106.5           | 21.03      | 15.9°             | 15.5°             |
| 75.75           | 18.34      | 22.3°             | 21.7°             | 91.5            | 19.85      | 18.5°             | 18.0°             | 107.25          | 21.08      | 15.8°             | 15.3°             |
| 76.5            | 18.42      | 22.1°             | 21.5°             | 92.25           | 19.92      | 18.3°             | 17.8°             | 108             | 21.14      | 15.7°             | 15.2°             |
| 77.25           | 18.50      | 21.9°             | 21.3°             | 93              | 19.98      | 18.2°             | 17.7°             | 108.75          | 21.19      | 15.6°             | 15.1°             |
| 78              | 18.57      | 21.7°             | 21.1°             | 93.75           | 20.04      | 18.0°             | 17.6°             | 109.5           | 21.24      | 15.4°             | 15.0°             |
| 78.75           | 18.65      | 21.5°             | 20.9°             | 94.5            | 20.11      | 17.9°             | 17.4°             | 110.25          | 21.29      | 15.3°             | 14.9°             |
| 79.5            | 18.73      | 21.3°             | 20.7°             | 95.25           | 20.17      | 17.8°             | 17.3°             | 111             | 21.34      | 15.2°             | 14.8°             |
| 80.25           | 18.80      | 21.1°             | 20.5°             | 96              | 20.23      | 17.6°             | 17.1°             | 111.75          | 21.39      | 15.1°             | 14.7°             |
| 81              | 18.88      | 20.9°             | 20.3°             | 96.75           | 20.29      | 17.5°             | 17.0°             | 112             | 21.41      | 15.1°             | 14.7°             |
| 81.75           | 18.95      | 20.7°             | 20.1°             | 97.5            | 20.35      | 17.3°             | 16.9°             |                 |            |                   |                   |
| 82.5            | 19.03      | 20.5°             | 20.0°             | 98.25           | 20.41      | 17.2°             | 16.8°             |                 |            |                   |                   |
| 83.25           | 19.10      | 20.3°             | 19.8°             | 99              | 20.47      | 17.1°             | 16.6°             |                 |            |                   |                   |
| 84              | 19.17      | 20.1°             | 19.6°             | 99.75           | 20.53      | 17.0°             | 16.5°             |                 |            |                   |                   |
| 84.75           | 19.24      | 20.0°             | 19.4°             | 100.5           | 20.58      | 16.8°             | 16.4°             |                 |            |                   |                   |
| 85.5            | 19.31      | 19.8°             | 19.3°             | 101.25          | 20.64      | 16.7°             | 16.3°             |                 |            |                   |                   |
| 86.25           | 19.38      | 19.6°             | 19.1°             | 102             | 20.70      | 16.6°             | 16.1°             |                 |            |                   |                   |
| 87              | 19.45      | 19.4°             | 18.9°             | 102.75          | 20.76      | 16.5°             | 16.0°             |                 |            |                   |                   |
| 87.75           | 19.52      | 19.3°             | 18.8°             | 103.5           | 20.81      | 16.3°             | 15.9°             |                 |            |                   |                   |
| 88.5            | 19.59      | 19.1°             | 18.6°             | 104.25          | 20.87      | 16.2°             | 15.8°             |                 |            |                   |                   |



### Notes:

Gain calculations based on NRL Report 4433 - accuracy to approx  $\pm 0.3$  dBi

Half-power (3dB) beamwidth estimates calculated using  $50.8 \lambda / C$  (E-Plane) and  $68.1 \lambda / B$  (H-Plane). This is a 'large aperture' approximation that breaks down at gain values smaller than around 12 dBi. For 10dBi Standard Gain Horns, beamwidths are approximately 63° at the lowest frequency and 48° at the highest frequency.



**FLANN MICROWAVE**

Dunmere Road  
Bodmin, Cornwall  
PL31 2QL  
United Kingdom

Tel: +44 (0) 1208 77777  
Fax: +44 (0) 1208 76426  
mail@flann.com  
www.flann.com

