

EXHIBIT 4

CFS8DL5808LP

Equipment Photographs

PHOTOELECTRONIC
DETECTION PRINCIPLE
AND 135°F (57°C)
THERMAL
MAXIMUM INSTALLATION
AMBIENT TEMPERATURE
100°F (37.8°C)
5911
 Underwriters
Laboratories Inc.®
LISTED
SMOKE-AUTOMATIC FIRE
DETECTOR WITH INTEGRAL
HEAT DETECTOR FOR OPEN
AREA PROTECTION.
ISSUE NO. XXXXXXXX
WARNING: REPLACE BOTH BATTERIES
WITH A PANASONIC CR123A OR ADEMCO
465 ONLY. WAIT 15 SECONDS AFTER
REMOVAL OF OLD BATTERIES BEFORE
INSERTING NEW BATTERIES.
USE OF ANOTHER BATTERY MAY
PRESENT RISK OF FIRE OR
EXPLOSION. SEE OWNER'S MANUAL
FOR SAFETY PRECAUTIONS.
N04-1251-00 MADE IN MEXICO

ADEMCO
MODEL NO. 5808LP
SMOKE
DETECTOR TRANSMITTER
(FCC ID: CFS 8DL 5808LP)
THIS DEVICE COMPLIES
WITH PART 15 OF THE
FCC RULES. OPERATION
IS SUBJECT TO THE
FOLLOWING CONDITIONS:
(1) THIS DEVICE
MAY NOT CAUSE HARMFUL
INTERFERENCE, AND
(2) THIS DEVICE MUST
ACCEPT ANY INTERFERENCE
THAT MAY
BE RECEIVED, INCLUDING INTERFERENCE THAT MAY
CAUSE UNDESIRABLE OPERATION.
MAINTENANCE: DISABLE THE SYSTEM, OPEN
THE DETECTOR, AND CLEAN THE CHAMBER.
SEE A0200-00-00 FOR DETAILED INSTALLATION
AND MAINTENANCE INSTRUCTIONS.
NOMINAL SENSITIVITY 2.4±.7%/FT
MOD 400(R) RANGE 0.29 - 0.85 VOLTS
FOR REPAIR RETURN TO: 9034
ADEMCO
165 EILEEN WAY
SYOSSET, NY
11791 U.S.A.
TEST WEEKLY BY DEPRESSING THE TEST BUTTON.

Sample of
label, as
shown in
attached
photographs.

FCC ID: CFS8DL5808LP