



RX SPURIOUS EMISSION

Test of: SIEMENS CT56, SN:001002000031406

Date(s) of Test: 07/26/02 07/26/02

Lab:

Siemens Information and Communication Mobile LLC 16745 West Bernardo Drive Suite 400 San Diego, CA 92127

Tested by:

the an Milton de Leon 🗡

07/26/02 Ich Nuc

Checked by:

Peter Nevermann





1 INTRODUCTION	3
2 TEST SET UP	3
2.1 Equipment Description	3
2.2 Accessories	3
2.3 Equipment Under Test	3
2.4 Test Set –up Block Diagram	4
3 TEST DESCRIPTION	4
3.1 Equipment settings	4
3.2 Test procedure	5
3.3 Specification	5
4 TEST RESULTS	6
4.1 Spurious emission at TX Channel 128 (824.20 MHz)	6
4.2 Spurious emission at TX Channel 190 (836.60 MHz)	7
4.3 Spurious emission at TX Channel 251 (848.80MHz)	8
5 APPENDICES	9
5.1 Certificate reports	9
5.2 FCC Test Acceptance	13



1 INTRODUCTION

THIS DOCUMENT SHOWS THE PERFORMANCE OF CT56 SIEMENS MOBILE PHONE, REGARDING TO SPURIOUS EMISSION ON RX FREQUENCIES DURING OPERATION AT GSM850 BAND.

2 TEST SET UP

2.1 Equipment Description

1.	FSEM 30 – Spectrum Analyzer 20Khz to	Serial No. 100024
	26.5Ghz	Calibration Report No. 85639
	RODE&SCHWARTZ	
2.	8652A – Power Meter	Serial No. 8650929
	Giga-tronics	Calibration Report No. 85605
3.	80420A – Power Sensor	Serial No. 1834334
	Giga-tronics	Calibration Report No. 85606
4.	CMU-200 – Radio Communication Tester	Serial No. 100432
	RODE&SCWARTZ	Calibration Report No. 85612
5.	85902A – Burst Carrier Trigger	Serial No. 3308A01293
	Agilent	Calibration Certificate No. N/A

2.2 Accessories

1.	4226-20 – Directional Coupler 0.5 to 18Ghz
	Narda Microwave
2.	WD-00003 – Duplexer Filter
	Lorch Microwave
3.	6B5W – 5Watts 10 dB Attenuator
	INMET
4.	15542 – Power Splitter
	Mini-Circuits
5.	MCL BW-S3W2 3dB Attenuator
6.	MCL BW-S3W2 6dB Attenuator
7.	Coaxial Adapters (several)
8.	Coaxial Cables (several)

2.3 Equipment Under Test

CT56 Siemens Mobile Phone	Serial No. 001002000031406 (labeled: 20)
FCC ID	PWX-CT56





2.4 Test Set –up Block Diagram



3 TEST DESCRIPTION

3.1 Equipment settings

CMU200 – Communication Tester	GSM850 Signaling Mode/Default settings
	RF Attenuation = according total set-up losses
FSEM – Spectrum Analyzer	Frequency: 869 Mhz to 894 Mhz
	RBW: 30 kHz (Manual)
	VBW: 30 kHz (Manual)
	Sweep: Auto selected (70ms)
	Detector: Sample
	Trace: Averaging over 200 cycles
	Trigger: pulsed, gated to transmit pulse
	Offset: according total set-up losses
8652A Power Meter	Sensor Set-up: Burst Average Power
	Offset: according total set-up losses





3.2 Test procedure

- Use the CMU200 as a base station and the MMI to establish a call with the EUT.
- Set the EUT power level to PLC=5 (Unit operates approximately at +31.0 dBm at this power level)
- Set the Tx channel No. to 128 (824.20 Mhz)
- Measure the Spurious emission at RX Band with the Spectrum Analyzer
- Repeat the procedure for TX channel No. 190 (836.60 Mhz) and 251 (848.80 Mhz)

3.3 Specification

- The power level of any emissions at the receive band, measure with 30Khz RBW, shall not exceed -80dBm.





4 Test Results

4.1 Spurious emission at TX Channel 128 (824.20 MHz)









4.2 Spurious emission at TX Channel 190 (836.60 MHz)







4.3 Spurious emission at TX Channel 251 (848.80MHz)





5.1 Certificate reports

Calibr	ation Report		9	235 Activity Road Suite 107 San Diego CA 92126
Customer	SIEMENS ICM SAN DIEGO,	CA, 92127	7 P	h. (858) 547-0217 Fax (858) 547-0241
Account:2	8651			
Instrumen	t: BB2118 RADIO C	OMMUNIC	ATION TEST	ER
Mfg:ROHDE	& SCHWARZ Model:	CMU 200	Seri	al #:100432
Size:	Resltn	:NA	Repo	ort Date:11/26/01
Job Numbe	r:D17466 P.O.:4	151301000	Repo	ort #: 85612
Cust Ctrl	:201742 Dept:P.	A	Loca	ation:NA
Work Perfo Parts Repl Received C	<pre>rmed:Inspected and cali; aced:None ondition:In tolerance ted</pre>	brated. Ret	Curned Conditi	page 1 of 1 on:In tolerance
runction les			Readings Art	
	ALL PARAME	TERS TESTED	FOUND TO BE WIT	HIN
	MANUFACTUR	ER'S SPECIF	ICATIONS.	
and a second and the second second second				
			tig an and the second second second second second	
anna an				
Servic All wo:	es provided conform to ANSI/ rk performed complies with M	NCSL Z540-1 PC Quality	-1994 (Formerly System QM 540-94	Mil-Std 45662A). , Rev 1c.
Std Ctrl #	Standards Used	Due Date	Traceability F	ef Model
L1056	RECEIVER, MEASURI 8902A	030502	2453T594801	8902A 002
L1497	MODULE, SENSOR 11722A	032702	2453X040101	11722A COMPANY
J6551	GENERATOR, SIGNAL 83640A	062202	2453W813201	83640A
J6552	ANALYZER, SPECTRU 8592L	062202	2453X189401	8592L
Environme	ntal:74F 50% RH		Test Date:112	2601
Uncertain	ty of test:Accuracy Rat	io > 4:1	Cycle:12	00
Cal Proce	dure:MANUFACTURER		Due Date:1126	502 CC
Cu1 11000				

All standards used are either traceable to the National Institute of Standards or have intrinsic accuracy. All services performed have used proper manufacturer and industrial service techniques and are warranted for no less than (30) days. This report may not be reproduced in permission of Micro Precision's Quality Assurance Manager.







Calibration Report

Customer: SIEMENS ICM SAN DIEGO CA 92127

Account:28651

Instrument: BB2112 POWER METER

Mfg:GIGATRONICS	Model:8652A	Serial #:8650929
Size:	Resltn:NA	Report Date:11/26/01
Job Number:D17466	P.O.:4151301000	Report #: 85605
Cust Ctrl:201788	Dept:PA	Location:NA

Work Performed: Inspected and calibrated.

page 1 of

Parts Replaced:None

Received Condition: In tolerance Returned Condition: In tolerance

Function Tested	Readings Before	Readings	After	Tolerance
	ALL PARAMETERS TEST	ed found to be	WITHIN	
	MANUFACTURER'S SPEC	IFICATIONS.		
			2	
a sa			14 S.	
			and the second	

Services provided conform to ANSI/NCSL Z540-1-1994 (Formerly Mil-Std 45662A). All work performed complies with MPC Quality System QM 540-94, Rev 1c.

Std Ctrl #	Standards Used	Due Date	Traceability Ref	Model
X5200	METER, POWER 432A	050702		432A)9002
BA6129	THERMISTOR MOUNT 478A	051802		478А СЕБ СОМРАНУ
T5173	MULTIMETER, DIGIT 3458A	052902	2453X107101	-3458A
Environme	ntal:73F 42% RH		Test Date:11260	1
Uncertain	ty of test:Accuracy Rat	io > 4:1	Cycle:12	QC
Cal Procedure:MANUFACTURER Technician:SCOTT STANCO			Due Date:112602	20
			Quality Approva	1:
				Rev 3 03/00

All standards used are either traceable to the National Institute of Standards or have intrinsic accuracy. All services performed have used proper manufacturer and industrial service techniques and are warranted for no less than (30) days. This report may not be reproduced in part without written permission of Micro Precision's Quality Assurance Manager.



Calibration Report

Instrument: BB2142

Mfg:ROHDE & SCHWARZ

Job Number: D17466

Cust Ctrl:201430

Parts Replaced:None

Account:28651

Size:

Customer SIEMENS ICM SAN DIEGO, CA, 92127

Work Performed: Inspected and calibrated.





Received Condition: In	tolerance	Returned	Condition: In	tolerance
Function Tested	Readings Before	e Rea	dings After	Tolerance
	ALL PARAMETERS	TESTED FOUND	TO BE WITHIN	
	MANUFACTURER 'S	SPECIFICATION	IS .	
		ang da pang kanalan da sa sa s		
			an a	

SPECTRUM ANALYZER

Model:FSEM 30

P.O.:41S1301000

Resltn:NA

Dept: TDMA

Services provided conform to ANSI/NCSL Z540-1-1994 (Formerly Mil-Std 45662A) All work performed complies with MPC Quality System QM 540-94, Rev 1c.

Std Ctrl #	Standards Used	Due Date	Traceability Ref	Model
J6551	GENERATOR, SIGNAL 83640A	062202	2453W813201	83640A002
L8600	GENERATOR, SIGNAL 8657A	020502	BA8401/031501	8657A D COMPANY
BA8401	TIME & FREQUENCY 58503A	031502	GPS INTRINSIC	58503A
L9709	SENSOR, POWER 8485A	040902	2453X050202	8485A
Environme	ntal:75F 43% RH	de conservation de la conservation	Test Date:11270	1
Uncertain	ty of test:Accuracy Rat:	io > 4:1	Cycle:12	
Cal Proce	dure:MANUFACTURER		Due Date:112702	
Technicia	n:CHAD INNISS		Quality Approva	l:
				Rev 3 03/00

All standards used are either traceable to the National Institute of Standards or have intrinsic accuracy. All services performed have used proper manufacturer and industrial service techniques and are warranted for no less than (30) days. This report may not be reproduced in part without written permission of Micro Precision's Quality Assurance Manager.





Calibr	ation Report						O PRECISION IBRATION INC
			9235 A	Activity Road, Suite 10	7, San Diego, CA 92120		
Customer	SIEMENS ICM SAN I	DIEGO,	CA, 9212	7	Pn. (8	58) 547-0217	Fax (858) 547-0241
Account:2	28651						
Instrumer	nt: BB2113 POW	VER SI	ENSOR				atomatica and a state of the state
Mfg:GIGAT	TRONICS N	Model:8	30420A		Serial	#:1834334	
Size:	I	Resltn	:NA		Report	Date:11/26/0	01
Job Numbe	er:D17466	P.O.:41	LS1301000		Report	#: 85606	
Cust Ctrl	I:NONE I	Dept:PF	1		Locati	on: NA	
Work Perfo Parts Rep] Received (Function Tes	ormed:Inspected and aced:None Condition:In tolera ted Rea	d calik	Re Re	turned Con Readings	dition After	page :In tolerance Tolerance	1 of
	ALL	PARAMET	CERS TESTED	D FOUND TO BE	WITHIN	T	
	MAN	UFACTURE	ER'S SPECIF	FICATIONS.			
	an a	9					
					-		
						•	
Servic All wo	es provided conform to rk performed complies	O ANSI/N with MF	CSL Z540-1 C Quality	L-1994 (Forme System QM 54	erly Mil 0-94, R	-Std 45662A). Nev 1c.	
Std Ctrl #	Standards Used		Due Date	Traceabili	ty Ref	Model	
J6551	GENERATOR, SIGNAL 83	3640A	062202	2453W81320	1	83640A 002	
L4500	SENSOR, POWER 8481A		031702	2451F55170	1	8481A COMPANY	
L9708	SPLITTER, POWER 1160	57A	010302	242850,245	416	11667A	r (* 1999) 1990 - Standard Hannes (* 1990) 1991 - Standard Hanne
T8988	METER, POWER 438A		010402	2453W21530	1	438A	
Environme	ental:73F 42% RH			Test Date	:112603	1	
Uncertain	ty of test:Accurac	y Rati	.0 > 4:1	Cycle:12		00	
Cal Procedure:MANUFACTURER				Due Date:	112602		
Technicia	n:SCOTT STANCO			Quality Ap	oprova	1. 20	
						Rev 3 03/00	

All standards used are either traceable to the National Institute of Standards or have intrinsic accuracy. All services performed have used proper manufacturer and industrial service techniques and are warranted for no less than (30) days. This report may not be reproduced in part without written permission of Micro Precision's Quality Assurance Manager.





5.2 FCC Acceptance

Final Agreement of FCC to SIEMENS Proposal for Noise in RX Measurement Procedure from 09/20/2001 by Frank Coperich

Subj: Fwd: Part 22.917(f) Test Method Question Date: 9/20/2001 3:15:22 PM Central Daylight Time From: FCOPERIC@fcc.gov (Frank Coperich) To: SBerger822@aol.com

File:Part.zip (60598 bytes) DL Time (42666 bps): < 1 minute

This test procedure is acceptable.

Received: from gatekeeper2.fcc.gov ([165.135.0.253]) by fcc.gov; Thu, 20 Sep 2001 07:16:39 -0400 Received: by gatekeeper2.fcc.gov; id HAA03743; Thu, 20 Sep 2001 07:16:37 -0400 (EDT) From: <SBerger822@aol.com> Received: from unknown(64.12.136.7) by gatekeeper2.fcc.gov via smap (V5.5) id xma003727; Thu, 20 Sep 01 07:16:17 -0400 Received: from SBerger822@aol.com by imo-m04.mx.aol.com (mail_out_v31_r1.7.) id 2.16e.129b4ac (4068) for <fcoperic@fcc.gov>; Thu, 20 Sep 2001 07:16:11 -0400 (EDT) Message-ID: <16e.129b4ac.28db29fa@aol.com> Date: Thu, 20 Sep 2001 07:16:10 EDT Subject: Part 22.917(f) Test Method Question To: fcoperic@fcc.gov X-Mailer: AOL 6.0 for Windows US sub 10536 Mime-Version: 1.0 Content-Type: multipart/mixed; boundary="=_B3E92F04.5130F84A"

Frank,

It was good talking to you yesterday. I appreciate your help in resolving this question regarding the correct test method for Part 22.917(f). My client must make a design decision tomorrow and after that it will be very difficult and expensive for them to change the design. Therefore, assuring that they correctly understand this test is important to them.

Attached is a memo giving a detailed description of the test method being used implementing the averaging, per our conversation yesterday. Test results from this product are included that show a little over 3 dB of margin using this test method.

I will look forward to your reply. If you want to discuss this further please feel free to call me at 512-864-3365.

Best Regards,

Stephen Berger

Test Method described in Part.zip:

"Based on this rational, we would ask if you agree that the correct measurement settings for the 22.917(f) test are as follows:

- 1. Limit Line = -80 dBm
- 2. Detector = Sample
- 3. Trace = Averaging over time for 200 cycles
- 4. Sweep Time = Auto selected (approx. 140 ms)
- 5. Trigger = pulsed, gated to transmit pulse
- 6. Bandwidths, RBW = 30 kHz, VBW = 30 kHz or greater
- 7. Transmit Channels (Frequencies) = Measure at low, mid and high channels."