

FCC PART 18
EMI MEASUREMENT AND TEST REPORT
For
Guangdong MD Microwave Oven Manufacturing Co., Ltd

Penglai Road, Beijiao, Shunde, Foshan, Guangdong Province, People's Republic of China

FCC ID: RSFMM617CYY

August 25, 2006

This Report Concerns: ☒ Original Report	Equipment Type: Microwave Oven
Test Engineer: Hansen Hu <i>Hansen Hu</i>	
Report Number: RSZ06081151	
Test Date: August 14-17, 2006	
Reviewed By: EMC Manager: Boni Baniqued <i>Boni Baniqued</i>	
Prepared By: Bay Area Compliance Lab Corp. (ShenZhen) 6/F, the 3rd Phase of WanLi Industrial Building, ShiHua Road, FuTian Free Trade Zone, ShenZhen, Guangdong 518038, P.R.China Tel: +86-755-33320018 Fax: +86-755-33320008	

Note: The test report is specially limited to the above company and this particular sample only.
It may not be duplicated without prior written consent of Bay Area Compliance Lab Corp.
(ShenZhen). This report **must not** be used by the client to claim product certification, approval,
or endorsement by NVLAP, NIST or any agency of the US Government.

TABLE OF CONTENTS

GENERAL INFORMATION.....	3
PRODUCT DESCRIPTION FOR EQUIPMENT UNDER TEST (EUT)	3
OBJECTIVE	3
RELATED SUBMITTAL(S)/GRANT(S).....	3
TEST METHODOLOGY	3
TEST FACILITY	3
EXTERNAL CABLE LIST AND DETAILS	4
OPERATING CONDITION/TEST CONFIGURATION.....	5
JUSTIFICATION	5
EQUIPMENT MODIFICATIONS	5
CONFIGURATION OF TEST SETUP	5
BLOCK DIAGRAM OF TEST SETUP	5
CONDUCTED EMISSION.....	6
MEASUREMENT UNCERTAINTY	6
EUT SETUP	6
EMI TEST RECEIVER SETUP.....	7
TEST EQUIPMENT LIST AND DETAILS.....	7
TEST PROCEDURE	7
TEST RESULTS SUMMARY	7
TEST DATA	8
PLOT(S) OF TEST DATA	8
RADIATION HAZARD MEASUREMENT	11
TEST EQUIPMENT LIST AND DETAILS.....	11
RADIATION HAZARD MEASUREMENT	11
INPUT POWER.....	11
LOAD FOR MICROWAVE OVENS	12
RF OUTPUT POWER MEASUREMENT.....	12
OPERATING FREQUENCY MEASUREMENT	14
RADIATED EMISSION DATA.....	20
MEASUREMENT UNCERTAINTY	20
EUT SETUP	20
EMI TEST RECEIVER SETUP AND SPECTRUM ANALYZER.....	21
TEST EQUIPMENT LIST AND DETAILS.....	21
TEST PROCEDURE	21
CORRECTED AMPLITUDE & MARGIN CALCULATION	21
TEST RESULTS SUMMARY	22
TEST DATA	22

GENERAL INFORMATION

Product Description for Equipment Under Test (EUT)

The *Guangdong MD Microwave Oven Manufacturing Co., Ltd*'s model: MM617CKE or the "EUT" as referred to in this report is a Microwave Oven which measures approximately 43.5cmL x 33.0cmW x 24.5cmH, rated input voltage: AC 120 V/60 Hz.

The series products, model MM617CYY(Y=A-Z, 0-9, means different color or aspect), we select MM617CKE to test.

** The test data gathered are from production sample, serial number: 0608103, provided by the manufacturer, we receive the EUT on 2006-8-11.*

Objective

The following test report is prepared on behalf of *Guangdong MD Microwave Oven Manufacturing Co., Ltd* in accordance with Part 2, Subpart J, and Part 18, Subparts A, B and C of the Federal Communication Commissions rules.

The objective of the manufacturer is to determine compliance with FCC Part 18 limits.

Related Submittal(s)/Grant(s)

No related submittal(s).

Test Methodology

All measurements contained in this report were conducted with MP-5, FCC Methods of Measurements of Radio Noise Emissions from ISM Equipment, February 1986. All measurement was performed at Bay Area Compliance Laboratory Corporation. The radiated testing was performed at an antenna-to-EUT distance of 3 meters.

Test Facility

The Test site used by Bay Area Compliance Lab Corp. (ShenZhen) to collect test data is located in the 6/F, the 3rd Phase of WanLi Industrial Building, ShiHua Road, FuTian Free Trade Zone, ShenZhen, Guangdong 518038, P.R.China.

Test site at Bay Area Compliance Lab Corp. (ShenZhen) has been fully described in reports submitted to the Federal Communication Commission (FCC). The details of these reports have been found to be in compliance with the requirements of Section 2.948 of the FCC Rules on November 04, 2004. The facility also complies with the radiated and AC line conducted test site criteria set forth in ANSI C63.4-2003.

The Federal Communications Commission has the reports on file and is listed under FCC Registration No.: 382179. The test site has been approved by the FCC for public use and is listed in the FCC Public Access Link (PAL) database.

Additionally, Bay Area Compliance Lab Corp. (ShenZhen) is a National Institute of Standards and Technology (NIST) accredited laboratory, under the National Voluntary Laboratory Accredited Program (Lab Code 200707-0). The current scope of accreditations can be found at <http://ts.nist.gov/ts/htdocs/210/214/scopes/2007070.htm>

External Cable List and Details

Cable Description	Length (M)	From/Port	To
Unshielded Undetachable AC Power Cable	1.0	EUT	AC Power

OPERATING CONDITION/TEST CONFIGURATION


Justification

The EUT was provided for tests as a stand-alone device. It was prepared for testing in accordance with the manufacturer's instructions. The EUT was operated at maximum (continuous) RF output power. The loads consisted of water in a glass beaker in the amounts specified in the test procedure.


Equipment Modifications

Bay Area Compliance Lab Corp. (ShenZhen) has not done any modification on the EUT.

Configuration of Test Setup



Block Diagram of Test Setup




CONDUCTED EMISSION

Measurement Uncertainty

All measurements involve certain levels of uncertainties, especially in field of EMC. The factors contributing to uncertainties are spectrum analyzer, cable loss, and LISN.

Based on NIS 81, The Treatment of Uncertainty in EMC Measurements, the best estimate of the uncertainty of any conducted emissions measurement at Bay Area Compliance Lab Corp. (ShenZhen) is ± 2.4 dB.

EUT Setup



- Note: 1. Support units were connected to second LISN.
2. Both of LISNs (AMN) 80 cm from EUT and at the least 80 cm from other units and other metal planes support units.

The setup of EUT is according with per MP-5: 1986 measurement procedure. Specification used was with the FCC Part 18.

The EUT was connected to a 120 VAC/ 60Hz power source.

EMI Test Receiver Setup

The EMI test receiver was set to investigate the spectrum from 150 kHz to 30 MHz.

During the conducted emission test, the EMI test receiver was set with the following configurations:

<u>Frequency Range</u>	<u>IF B/W</u>
150 kHz – 30 MHz	9 kHz

Test Equipment List and Details

Manufacturer	Description	Model	Serial Number	Calibration Date	Calibration Due Date
Com-Power	L.I.S.N.	LI-200	12005	N/A	N/A
Com-Power	L.I.S.N.	LI-200	12008	N/A	N/A
Rohde & Schwarz	EMI Test Receiver	ESCS30	DE25330 or 830245/006	2006-1-26	2007-1-26
Rohde & Schwarz	L.I.S.N.	ESH2-Z5	892107/021	2006-3-1	2007-3-1

* Com-Power's LISN were used as the supporting equipment.

* **Statement of Traceability:** Bay Area Compliance Lab Corp. (ShenZhen) attests that all calibrations have been performed in accordance to NVLAP requirements, traceable to the NIST.

Test Procedure

During the conducted emission test, the EUT power cord was connected to the outlet of the LISN.

Maximizing procedure was performed on the six (6) highest emissions of the EUT.

All data was recorded in the Quasi-peak and average detection mode.

Test Results Summary

According to the recorded data in following table, the EUT complied with the FCC PART 18, with the worst margin reading of:

-2.10 dB at 0.675 MHz in the Live conductor mode.

Test Data**Environmental Conditions**

Temperature:	25°C
Relative Humidity:	56%
ATM Pressure:	1002mbar

The testing was performed by Hansen Hu on 2006-8-14.

Test Mode: On (Max Power)

LINE CONDUCTED EMISSIONS				FCC PART 18	
Frequency MHz	Amplitude dBμV	Detector QP/AV	Phase Live/Neutral	Limit dBμV	Margin dB
0.675	53.90	QP	Live	56.00	-2.10 *
0.590	52.90	QP	Live	56.00	-3.10
0.150	61.00	QP	Neutral	66.00	-5.00
0.270	56.10	QP	Neutral	61.12	-5.02
0.755	50.80	QP	Neutral	56.00	-5.20
0.900	50.30	QP	Live	56.00	-5.70
0.360	52.80	QP	Neutral	58.73	-5.93
0.325	53.60	QP	Live	59.58	-5.98
0.160	55.40	QP	Live	65.46	-10.06
16.115	48.30	QP	Neutral	60.00	-11.70
12.935	44.40	QP	Neutral	60.00	-15.60
0.590	27.40	AV	Live	46.00	-18.60
2.680	36.60	QP	Live	56.00	-19.40
0.675	26.40	AV	Live	46.00	-19.60
0.900	26.30	AV	Live	46.00	-19.70
0.270	30.90	AV	Neutral	51.12	-20.22
0.325	27.00	AV	Live	49.58	-22.58
0.150	29.80	AV	Neutral	56.00	-26.20
0.755	19.50	AV	Neutral	46.00	-26.50
0.160	28.30	AV	Live	55.46	-27.16
0.360	18.60	AV	Neutral	48.73	-30.13
16.115	17.40	AV	Neutral	50.00	-32.60
2.680	13.00	AV	Live	46.00	-33.00
12.935	16.70	AV	Neutral	50.00	-33.30


* Within measurement uncertainty.

Plot(s) of Test Data

Plot(s) of Test Data is presented hereinafter as reference.


Conducted disturbance Test FCC Part 18

EUT: Microwave Oven M/N:MM617C**
Manuf: MD
Op Cond: ON (Max. power)
Operator: hansen
Test Spec: AC 120V/60Hz L
Comment: Temp:29 Humi:58%
Date: 14. Aug 06 16:19



Conducted disturbance Test FCC Part 18

EUT: Microwave Oven M/N:MM617C**
Manuf: MD
Op Cond: ON(Max.power)
Operator: hansen
Test Spec: AC 120V/60Hz N
Comment: Temp:29 Humi:58%
Date: 14. Aug 06 16:08



RADIATION HAZARD MEASUREMENT

Environmental Conditions

Temperature:	26°C
Relative Humidity:	58%
ATM Pressure:	1010mbar

Test Equipment List and Details

Manufacturer	Description	Model	Serial Number	Calibration Date	Calibration Due Date
Rohde & Schwarz	EMI Test Receiver	ESCI	100035	2005-8-17	2006-8-17
Sunol Sciences	Horn Antenna	DRH-118	A052604	2006-7-20	2007-7-20
HP	Amplifier	8449B	3008A00277	2005-8-17	2006-8-17
Ainuo	Digital Power Analyzer	8732B	028706117	2005-12-23	2006-12-23
HY	AC Power Source	9020117	GY053(1)	2005-8-21	2006-8-21
Holday	Leakage Meter	HI-1710	05/2731	2006-6-2	2007-6-2

* **Statement of Traceability:** Bay Area Compliance Lab Corp. (ShenZhen) attests that all calibrations have been performed in accordance to NVLAP requirements, traceable to the NIST.

Radiation Hazard Measurement

Radiation leakage was measured in the as-received condition with the oven door closed using a microwave leakage meter.

A 1000ml water load was placed in the center of the oven and the oven was operated at maximum output power.

☒ There was no microwave leakage exceeding a power level of $0.72\text{mW}/\text{cm}^2$ observed at any point 5cm or more from the external surface of the oven.

A maximum of $1.0\text{mW}/\text{cm}^2$ is allowed in accordance with the applicable Federal Standards. Hence, microwave leakage in the as-received condition with the oven door closed was below the maximum allowed.

Input Power

Input power and current was measured using a power analyzer. A 1000ml water load was placed in the center of the oven and the oven was operated at maximum output power. A 1000ml water load was chosen for its compatibility with the procedure commonly used by manufacturers to determine their input ratings.

Input Voltage (Vac/Hz)	Input Current (amps)	Measured Input Power (watts)	Rated Input Power (watts)
120/60	8.9	957.0	1000

☒ Based on the measured input power, the EUT was found to be operating within the intended specifications.

Load for Microwave Ovens

For all measurements, the energy developed by the oven was absorbed by a dummy load consisting of a quantity of tap water in a beaker. If the oven was provided with a shelf or other utensil support, this support was in its initial normal position. For ovens rated at 1000 watts or less power output, the beaker contained quantities of water as listed in the following subparagraphs. For ovens rated at more than 1000watts output, each quantity was increased by 50% for each 500watts or fraction thereof in excess of 1000watts. Additional beakers were used if necessary.

- Load for power output measurement: 1000 milliliters of water in the beaker located in the center of the oven.
- Load for frequency measurement: 1000 milliliters of water in the beaker located in the center of the oven.
- Load for measurement of radiation on second and third harmonic: Two loads, one of 700 and the other of 300 milliliters, of water are used. Each load is tested both with the beaker located in the center of the oven and with it in the right front corner.

The RF output power is rated at 1000 W

Load used for power output measurement = 1000 milliliters of water
 Load used for frequency measurement = 1000 milliliters of water
 Load used for harmonic measurement = 700 & 300 milliliters of water
 Load used for other measurement = 700 milliliters of water

RF Output Power Measurement

The Caloric Method was used to determine maximum RF output power. The initial temperature of the water load was measured. The water load was placed in the center of the oven. The oven was operated at maximum output power for 200 seconds, the temperature of the water was re-measured.

Quality of Water (ml)	Starting Temperature (°C)	Final Temperature (°C)	Elapsed Time (Seconds)
1000	20	46	200

Power = (4.2 joules/calorie)(volume in milliliters)(temperature rise)/(time in seconds)

Power = 4.2 joules/calorie x 1000 x (46-20) / 200

Power = 546 watts

☐ The measurement output power was found to be less than 500watts. Therefore, in accordance with Section 18.305 of Subpart-C, the measured out-of-band emissions were compared to the limit of 25µV/meter at a 300-meter measurement distance.

- ☒ The measured output power was found to exceed 500watts. Therefore, in accordance with Section 18.305 of Subpart-C, the measured out-of-band emissions were compared with the limit calculated as following:

$$\text{LFS} = 25 * \text{SQRT}(\text{Power Output}/500)$$

$$\text{LFS} = 25 * \text{SQRT}(546/500)$$

$$\text{LFS} \approx 26.12$$

Where: LFS is the maximum allowable field strength for out-of-band emissions in $\mu\text{V}/\text{meter}$ at a 300-meter measurement distance. Power Output is the measured output power in watts.

Manufacturer	Model Number	LFS	dB($\mu\text{V}/\text{M}$)	dB($\mu\text{V}/\text{M}$)@3m
Guangdong MD Microwave Oven Manufacturing Co., Ltd	MM617CKE	26.12	28.34	68.34

Operating Frequency Measurement


Variation in Operating Frequency with Time


The operating frequency was measured using a spectrum analyzer. Starting with the EUT at room temperature, a 1000ml water load was placed in the center of the oven and the oven was operated at maximum output power. The fundamental operating frequency was monitored until the water load was reduced to 20 percent of the original load.

The results of this test are as follows:

Manufacturer	Model Number	Minimum Frequency (MHz)	Maximum Frequency (MHz)
Guangdong MD Microwave Oven Manufacturing Co., Ltd	MM617CKE	2459.2	2461.2

Refer to data pages for details of the variation in operating frequency with time measurement.





Variation in Operating Frequency with Line Voltage


The EUT was operated / warmed by at least 10 minutes of use with a 1000ml water load at room temperature at the beginning of the test. Then the operating frequency was monitored as the input voltage was varied between 80 and 125 percent of the nominal rating.


The results of this test are as follows:

Line voltage varied from 96Vac to 150Vac.

Manufacturer	Model Number	Minimum Frequency (MHz)	Maximum Frequency (MHz)
Guangdong MD Microwave Oven Manufacturing Co., Ltd	MM617CKE	2457.8	2461.3

Please refer to following pages for details of the variation in operating frequency with line voltage measurement.






RADIATED EMISSION DATA

Measurement Uncertainty

All measurements involve certain levels of uncertainties, especially in field of EMC. The factors contributing to uncertainties are spectrum analyzer, cable loss, antenna factor calibration, antenna directivity, antenna factor variation with height, antenna phase center variation, antenna factor frequency interpolation, measurement distance variation, site imperfections, mismatch (average), and system repeatability.

Based on NIS 81, The Treatment of Uncertainty in EMC Measurements, the best estimate of the uncertainty of a radiation emissions measurement at Bay Area Compliance Lab Corp. (ShenZhen) is ± 4.0 dB.

EUT Setup



The radiated emission tests were performed in the 3 meters chamber A test site, using the setup accordance with the FCC MP - 5. The specification used was the FCC part 18.

The EUT was connected to 120 VAC/60 Hz power source.

EMI Test Receiver Setup and Spectrum Analyzer

The system was investigated from 30 MHz to 25 GHz.

During the radiated emission test, the spectrum analyzer was set with the following configurations:

<i>Frequency Range</i>	<i>R B/W</i>	<i>Video B/W</i>	<i>IF B/W</i>
30 – 1000 MHz	100 kHz	300 kHz	120 kHz
Above 1000 MHz	1 MHz	30 Hz	

Test Equipment List and Details

Manufacturer	Description	Model	Serial Number	Calibration Date	Calibration Due Date
Rohde & Schwarz	EMI Test Receiver	ESCI	100035	2005-8-17	2006-8-17
HP	Amplifier	HP8447D	2944A09795	2005-8-17	2006-8-17
Sunol Sciences	Broadband Antenna	JB1	A040904-1	2006-4-28	2007-4-28
Rohde & Schwarz	Spectrum Analyzer	FSEM30	849720/019	2005-11-10	2006-11-10
Sunol Sciences	Horn Antenna	DRH-118	A052604	2006-7-20	2007-7-20
HP	Preamplifier	8449B	3008A00277	2005-8-17	2006-8-17

*** Statement of Traceability:** Bay Area Compliance Lab Corp. (ShenZhen) attests that all calibrations have been performed per the NVLAP requirements, traceable to NIST.

Test Procedure

For the radiated emissions test, the EUT power cord was connected to the AC floor outlet.

Maximizing procedure was performed on the six (6) highest emissions to ensure that the EUT complied with all installation combinations.

All data was recorded in the Quasi-peak detection mode from 30 MHz to 1000 MHz, and average detection mode above 1 GHz.

The EUT was in the normal (naïve) operating mode during the final qualification test to represent the worst results.

Corrected Amplitude & Margin Calculation

The Corrected Amplitude is calculated by adding the Antenna Loss and Cable Loss, and subtracting the Amplifier Gain from the Meter Reading. The basic equation is as follows:

$$\text{Corr. Ampl.} = \text{Meter Reading} + \text{Antenna Loss} + \text{Cable Loss} - \text{Amplifier Gain}$$

The “**Margin**” column of the following data tables indicates the degree of compliance with the applicable limit. For example, a margin of -7dB means the emission is 7dB below the limit. The equation for margin calculation is as follows:

$$\text{Margin} = \text{Corr. Ampl.} - \text{Limit}$$

Test Results Summary

According to the data in the following table, the EUT complied with the FCC Part 18, with the worst margin reading of:

30MHz to 1000MHz: **-23.2 dB** at **535.70 MHz** in the **Horizontal** polarization.
Above 1 GHz: **-10.10 dB** at **4928.7 MHz** in the **Vertical** polarization.

Test Data

Environmental Conditions


Temperature:	27°C
Relative Humidity:	56%
ATM Pressure:	1009mbar

The testing was performed by Hansen Hu on 2006-8-17.

Test Mode: On (Max Power)


INDICATED		TABLE	ANTENNA		CORRECTION FACTOR			CORRECTED AMPLITUDE	FCC PART 18		PK/QP/AV
Frequency	Meter Reading	Angle	Height	Polar	Antenna Loss	Cable Loss	Amplifier Gain	Corr. Ampl.	Limit	Margin	
MHz	dBμV/m	Degree	Meter	H/ V	dB	dB	dB	dBμV/m	dBμV/m	dB	
30 MHz to 1000 MHz											
535.70	52.6	270	1.0	H	18.6	2.5	28.6	45.1	68.3	-23.2	QP
599.32	44.9	45	1.2	H	19.3	2.7	28.6	38.3	68.3	-30.0	QP
616.37	44.9	180	1.2	H	19.1	2.8	28.7	38.1	68.3	-30.2	QP
269.42	48.0	180	1.2	H	12.3	1.4	27.6	34.1	68.3	-34.2	QP
729.19	38.0	90	1.2	H	20.7	3.1	28.4	33.4	68.3	-34.9	QP
547.09	37.6	45	1.2	V	18.8	2.5	28.6	30.3	68.3	-38.0	QP
32.17	34.2	120	1.0	V	24.1	0.6	28.8	30.1	68.3	-38.2	QP
30.42	33.9	180	1.2	V	24.1	0.6	28.8	29.8	68.3	-38.5	QP
33.56	33.3	60	1.0	V	24.1	0.6	28.8	29.2	68.3	-39.1	QP
524.55	32.3	90	1.0	V	18.3	2.5	28.6	24.5	68.3	-43.8	QP
40.84	38.3	90	1.2	V	14.3	0.6	28.8	24.3	68.3	-44.0	QP
181.92	38.0	45	1.0	H	11.8	1.3	28.1	23.0	68.3	-45.3	QP

INDICATED		TABLE	ANTENNA		CORRECTION FACTOR			CORRECTED AMPLITUDE	FCC PART 18		COMMENTS
Frequency MHz	Meter Reading dB μ V/m	Angle Degree	Height Meter	Polar H/ V	Antenna Loss dB	Cable Loss dB	Amplifier Gain dB	Corr. Ampl. dB μ V/m	Limit dB μ V/m	Margin dB	
Above 1 GHz											
4928.7	52.24	180	1.2	V	33.8	5.2	33.00	58.24	68.34	-10.10	Harmonic
4905.8	51.77	45	1.2	H	33.8	5.2	33.00	57.77	68.34	-10.57	Harmonic
7332.1	47.72	45	1.0	V	35.8	6.1	34.11	55.51	68.34	-12.83	Harmonic
12315.1	39.73	45	1.2	H	41.2	8.3	34.58	54.65	68.34	-13.69	Harmonic
12384.7	39.56	45	1.2	V	41.2	8.3	34.58	54.48	68.34	-13.86	Harmonic
7356.4	46.33	60	1.0	H	35.8	6.1	34.11	54.12	68.34	-14.22	Harmonic
9872.1	43.35	60	1.0	V	37.6	7.3	34.50	53.75	68.34	-14.59	Harmonic
9879.2	42.92	180	1.2	H	37.6	7.3	34.50	53.32	68.34	-15.02	Harmonic
4267.5	38.41	45	1.0	H	32	4.9	32.66	42.65	68.34	-25.69	Spurious
4281.5	35.14	45	1.0	V	31.7	4.7	32.66	38.88	68.34	-29.46	Spurious
2459.2	65.50	45	1.0	V	28.1	3.7	0	97.30			Fundamental
2461.6	66.61	180	1.2	H	28.1	3.7	0	98.41			Fundamental



MD microwave oven MM617c## 30-1000 horizontal

Date: 17.AUG.2006 10:32:39



MD microwave oven MM617c## 30-1000 vertical

Date: 17.AUG.2006 10:46:46