

Appendix A

Detailed System Check Results

1. System Performance Check
System Performance Check 2450 MHz Head

System Performance Check 2450 MHz Head

D2450V2-SN 733

Communication System: D2450; Frequency: 2450.000
Medium: HSL. Medium parameters used: $f=2450.000$ MHz; $\sigma=1.82$ S/m; $\epsilon_r=41.0$

- DASY8 Configuration:
- Probe: EX3DV4 - SN7821; ConvF(6.97, 7.23, 7.47); Calibrated: 2023-07-17
 - Sensor-Surface: 1.4 mm
 - Electronics: DAE4ip Sn1830; Calibrated: 2023-09-12
 - Phantom: Twin-SAM V8.0 (30deg probe tilt); Serial: 2256
 - Measurement Software: cDASY8 V16.2.4.2524

Area Scan (96.0 mm x 120.0 mm): Measurement Grid: 12.0 mm x 12.0 mm
SAR (1g) = 13.0 W/kg; SAR (10g) = 6.34 W/kg;

Zoom Scan (30.0 mm x 30.0 mm x 30.0 mm): Measurement Grid: 5.0 mm x 5.0 mm x 5.0 mm
Power Drift = 0.00 dB
SAR (1g) = 13.5 W/kg; SAR (10g) = 6.42 W/kg;

